

Report Name: South-end Water Quality Report

Report Subtitle: Water Quality Report

	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd - Well 1	Boys Rd - Well 3	Boys Rd - Well 5	Boys Rd PS
January 2021	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Turbidity (NTU)	Turbidity (NTU)	Turbidity (NTU)	Flow (Volumetric Rate) (m ³ /d)
1								5,576
2								5,801
3								5,746
4								5,637
5	0.41	0.50	0.52	0.30	0.09			5,542
6								5,551
7								5,497
8								5,550
9								6,227
10								7,083
11								6,928
12		0.32						6,543
13	0.37		0.31	0.21				5,663
14								5,349
15								5,155
16								5,576
17			0.44					5,611
18								5,016
19				0.26				5,246
20		0.45						6,064
21								5,331
22								4,908
23								5,228
24								5,574
25			0.35	0.20	0.09			5,010
26								5,231
27	0.52	0.44						5,327
28								5,130
29								5,006
30								5,137
31								5,093
Average	0.43	0.43	0.41	0.24	0.09			5,559
Minimum	0.37	0.32	0.31	0.20	0.09			4,908
Maximum	0.52	0.50	0.52	0.30	0.09			7,083
Count	3	4	4	4	2	0	0	31
Total								172,336
95 Percentile					0.09			
Exceedences	0	0	0	0	0	0	0	0
Median	0.41	0.45	0.40	0.24	0.09			5,542

February 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1		0.41	0.43	0.24	0.11			5,068
2								5,289
3	0.33							5,178
4								4,892
5								5,021
6								5,587
7								5,280
8								5,061
9								4,982
10								5,194
11	0.25		0.30	0.18				5,029
12		0.38						5,202
13								5,150
14								5,215
15								5,298
16		0.37	0.43	0.25				5,051
17								5,135
18	0.51					0.13		4,931
19								5,014
20								4,970
21								5,179
22	0.55	0.41	0.51	0.25			0.102	4,998
23								5,435
24								4,710
25								5,013
26								4,826
27								4,915
28								5,307

Average	0.41	0.39	0.42	0.23	0.11	0.13	0.102	5,105
Minimum	0.25	0.37	0.30	0.18	0.11	0.13	0.102	4,710
Maximum	0.55	0.41	0.51	0.25	0.11	0.13	0.102	5,587
Count	4	4	4	4	1	1	1	28
Total								142,930
95 Percentile					0.11	0.13	0.102	
Exceedences	0	0	0	0	0	0	0	0
Median	0.42	0.40	0.43	0.25	0.11	0.13	0.102	5,065

March 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1			0.57	0.35	0.111			5,524
2	0.57	0.46						5,566
3								4,977
4								5,118
5								5,117
6								4,688
7								5,109
8		0.41	0.53	0.27				5,136
9								4,805
10	0.32							4,969
11								5,109
12								5,052
13								5,524
14								5,010
15		0.47	0.57	0.30				5,322
16	0.53							4,960
17								5,249
18								5,248
19								4,886
20								5,495
21								5,172
22			0.39	0.22				5,478
23	0.42	0.36						5,103
24								5,033
25								5,615
26								5,231
27								5,160
28								5,519
29								5,505
30	0.44	0.53	0.50	0.28				5,415
31								5,776

Average	0.46	0.45	0.51	0.28	0.111			5,222
Minimum	0.32	0.36	0.39	0.22	0.111			4,688
Maximum	0.57	0.53	0.57	0.35	0.111			5,776
Count	5	5	5	5	1	0	0	31
Total								161,871
95 Percentile					0.111			
Exceedences	0	0	0	0	0	0	0	0
Median	0.44	0.46	0.53	0.28	0.111			5,160

April 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								5,347
2								5,409
3								5,461
4								5,970
5								5,999
6	0.50	0.41	0.56	0.31				6,044
7					0.09			6,118
8								8,686
9								10,256
10								6,353
11								6,163
12								6,493
13								6,854
14								7,306
15								7,408
16								8,219
17								8,501
18								8,806
19								8,759
20	0.51			0.35				8,765
21		0.41	0.41			0.05		8,577
22								8,074
23								7,604
24								6,797
25								6,812
26			0.30	0.40				6,730
27		0.37						6,850
28								7,066
29	0.57							7,406
30								7,032

Average	0.53	0.40	0.42	0.35	0.09	0.05		7,196
Minimum	0.50	0.37	0.30	0.31	0.09	0.05		5,347
Maximum	0.57	0.41	0.56	0.40	0.09	0.05		10,256
Count	3	3	3	3	1	1	0	30
Total								215,865
95 Percentile					0.09	0.05		
Exceedences	0	0	0	0	0	0	0	0
Median	0.51	0.41	0.41	0.35	0.09	0.05		6,943

May 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								7,437
2								8,022
3		0.37			0.7			6,967
4								7,370
5	0.27		0.57	0.38				7,573
6								7,506
7								7,568
8								7,611
9								8,111
10	0.33	0.28						8,332
11			0.46	0.34				7,956
12								7,742
13								8,719
14								9,873
15								10,227
16								11,069
17	0.45	0.27						8,865
18								8,195
19			0.36	0.34				8,744
20								10,288
21								11,446
22								11,009
23								9,805
24								8,855
25	0.39		0.41	0.30			0.07	8,455
26								7,921
27		0.45						7,997
28								8,871
29								10,679
30								10,958
31	0.44	0.38	0.49	0.37				11,795

Average	0.38	0.35	0.46	0.35	0.7		0.07	8,902
Minimum	0.27	0.27	0.36	0.30	0.7		0.07	6,967
Maximum	0.45	0.45	0.57	0.38	0.7		0.07	11,795
Count	5	5	5	5	1	0	1	31
Total								275,966
95 Percentile					0.7		0.07	
Exceedences	0	0	0	0	1	0	0	0
Median	0.39	0.37	0.46	0.34	0.7		0.07	8,455

June 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1					0.01			13,034
2								13,398
3								12,963
4								10,989
5								10,747
6								10,071
7				0.29				9,300
8	0.40	0.42	0.41					9,051
9								9,010
10								8,701
11								8,377
12								7,918
13								8,107
14	0.40			0.48		0.09		8,257
15		0.39						8,053
16			0.53					9,551
17								13,076
18								13,864
19								13,903
20								14,771
21			0.32	0.23				14,821
22	0.42							14,716
23								14,179
24								14,776
25		0.20						15,857
26								16,333
27								17,262
28								18,363
29								17,608
30	0.48	0.48	0.48	0.32				16,263
Average	0.43	0.37	0.44	0.33	0.01	0.09		12,444
Minimum	0.40	0.20	0.32	0.23	0.01	0.09		7,918
Maximum	0.48	0.48	0.53	0.48	0.01	0.09		18,363
Count	4	4	4	4	1	1	0	30
Total								373,319
95 Percentile					0.01	0.09		
Exceedences	0	0	0	0	0	0	0	0
Median	0.41	0.41	0.45	0.31	0.01	0.09		13,055

July 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								15,458
2								14,330
3								14,954
4								15,073
5	0.41	0.43	0.41	0.32				15,183
6								15,361
7								15,698
8								15,157
9								15,046
10								15,384
11								15,437
12								14,613
13	0.42	0.42	0.40	0.29				14,855
14								15,301
15					0.08			14,520
16								12,540
17								12,320
18								12,433
19	0.35	0.45		0.23		0.08		12,887
20			0.39					12,871
21								13,179
22								12,819
23								12,464
24								12,236
25								12,652
26								13,015
27	0.38							12,833
28		0.30	0.35	0.29			0.07	13,167
29								13,395
30								13,291
31								12,113

Average	0.39	0.40	0.39	0.28	0.08	0.08	0.07	13,890
Minimum	0.35	0.30	0.35	0.23	0.08	0.08	0.07	12,113
Maximum	0.42	0.45	0.41	0.32	0.08	0.08	0.07	15,698
Count	4	4	4	4	1	1	1	31
Total								430,585
95 Percentile					0.08	0.08	0.07	
Exceedences	0	0	0	0	0	0	0	0
Median	0.40	0.43	0.40	0.29	0.08	0.08	0.07	13,395

August 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								12,327
2								13,008
3		0.38						12,543
4	0.28		0.34	0.23				12,369
5								12,544
6								11,615
7								10,616
8								11,957
9								12,507
10		0.30	0.31	0.33				12,750
11	0.38							12,804
12								13,165
13								12,746
14								12,414
15								12,069
16	0.35	0.57						11,364
17				0.23		0.07		12,988
18			0.34					20,489
19								16,161
20								11,131
21								12,398
22								18,269
23								11,279
24	0.41	0.42	0.20	0.29			0.075	10,199
25								10,009
26								9,770
27								9,478
28								11,083
29								17,381
30								10,740
31	0.40	0.46	0.50	0.2				9,737

Average	0.36	0.43	0.34	0.26		0.07	0.075	12,513
Minimum	0.28	0.30	0.20	0.2		0.07	0.075	9,478
Maximum	0.41	0.57	0.50	0.33		0.07	0.075	20,489
Count	5	5	5	5	0	1	1	31
Total								387,910
95 Percentile						0.07	0.075	
Exceedences	0	0	0	0	0	0	0	0
Median	0.38	0.42	0.34	0.23		0.07	0.075	12,369

September 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								9,763
2								9,781
3								9,607
4								8,796
5								8,183
6								8,710
7		0.25			0.072			9,020
8								8,682
9								8,860
10								8,870
11				0.18				8,388
12								8,245
13								7,948
14		0.25	0.46	0.22				7,676
15								7,597
16								7,270
17								7,085
18								7,523
19								7,034
20								7,003
21		0.45	0.35	0.10				7,030
22	0.36							6,946
23								6,644
24								7,410
25								6,967
26								6,737
27		0.41	0.45	0.10			0.05	6,573
28								6,467
29								6,868
30								9,669

Average	0.36	0.34	0.42	0.15	0.072		0.05	7,912
Minimum	0.36	0.25	0.35	0.10	0.072		0.05	6,467
Maximum	0.36	0.45	0.46	0.22	0.072		0.05	9,781
Count	1	4	3	4	1	0	1	30
Total								237,352
95 Percentile					0.072		0.05	
Exceedences	0	0	0	0	0	0	0	0
Median	0.36	0.33	0.45	0.14	0.072		0.05	7,637

October 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1	0.20							11,296
2								6,785
3								6,287
4		0.38	0.33	0.22				6,312
5	0.24							6,180
6								5,967
7								6,200
8								6,099
9								5,891
10								6,138
11								6,162
12								5,627
13	0.30	0.26	0.35	0.20				5,720
14								5,815
15								5,549
16								5,608
17								5,701
18								5,763
19								5,280
20	0.32		0.36	0.21				5,446
21								5,120
22		0.40						5,668
23								5,375
24								5,569
25			0.36	0.17			0.06	5,276
26	0.35	0.26						5,237
27								5,245
28								5,210
29								5,098
30								5,606
31								5,434

Average	0.28	0.33	0.35	0.20			0.06	5,892
Minimum	0.20	0.26	0.33	0.17			0.06	5,098
Maximum	0.35	0.40	0.36	0.22			0.06	11,296
Count	5	4	4	4	0	0	1	31
Total								182,664
95 Percentile							0.06	
Exceedences	0	0	0	0	0	0	0	0
Median	0.30	0.32	0.36	0.21			0.06	5,668

November 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1		0.28			0.08			5,634
2	0.32		0.28	0.12				5,252
3								5,255
4								5,223
5								5,211
6								5,340
7								5,861
8			0.25					5,113
9								5,337
10	0.36	0.27		0.27				5,265
11								5,270
12								4,722
13								5,307
14								5,087
15								5,281
16			0.36					5,263
17								5,226
18	0.32	0.26		0.28				5,033
19								5,257
20								4,795
21								5,190
22			0.32	0.21				5,528
23	0.32	0.22						4,877
24								5,182
25								5,094
26								4,977
27								5,461
28								5,111
29		0.39						5,132
30	0.47		0.33					5,202
Average	0.36	0.28	0.31	0.22	0.08			5,216
Minimum	0.32	0.22	0.25	0.12	0.08			4,722
Maximum	0.47	0.39	0.36	0.28	0.08			5,861
Count	5	5	5	4	1	0	0	30
Total								156,486
95 Percentile					0.08			
Exceedences	0	0	0	0	0	0	0	0
Median	0.32	0.27	0.32	0.24	0.08			5,225

December 2021	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1				0.15				5,270
2								5,260
3								5,077
4								5,081
5								5,354
6	0.42	0.37	0.41	0.20				5,050
7								5,343
8								5,229
9								5,162
10								5,392
11								5,381
12								5,468
13	0.40		0.39	0.18				5,117
14		0.39						5,168
15								5,446
16								5,353
17								5,206
18								5,597
19								6,225
20	0.48		0.47	0.16				5,680
21		0.38						5,049
22								5,756
23								5,554
24								5,969
25								5,614
26								5,626
27								5,939
28								5,807
29								5,978
30			0.46					5,760
31								5,929

Average	0.43	0.38	0.43	0.17				5,479
Minimum	0.40	0.37	0.39	0.15				5,049
Maximum	0.48	0.39	0.47	0.20				6,225
Count	3	3	4	4	0	0	0	31
Total								169,840
95 Percentile								
Exceedences	0	0	0	0	0	0	0	0
Median	0.42	0.38	0.44	0.17				5,392

* indicates Geometric Mean
** indicates Intraday Average

MICROORGANISMS

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
02/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
04/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
05/10/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Municipal Hall	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
02/16/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
03/15/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
04/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
05/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
06/14/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
07/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
09/21/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined
10/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Pump House	<=0, OG, P User-Defined

# samples:	9	min:	0 CFU/100ml
# detects:	9	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 9 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/04/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
02/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
03/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
04/06/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
05/03/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
06/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
07/05/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
08/03/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
09/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
10/04/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined
11/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Water Pump Station	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)



of Exceedences: 0

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
02/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
04/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
05/10/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Stonehouse Reservoir	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/26/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
02/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
03/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
04/26/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
05/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
06/21/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
07/28/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
08/24/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
09/27/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
10/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Properties Reservoir	<=0, OG, P User-Defined
# samples: 10	min: 0 CFU/100ml		
# detects: 10	max: 0 CFU/100ml		
# non-detects: 0	Geometric Mean: 0 CFU/100ml (based on 10 numerical results)		
# of Exceedences: 0			

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
02/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
04/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
05/10/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Lakeview Reservoir	<=0, OG, P User-Defined
# samples: 11	min: 0 CFU/100ml		



# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
02/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
03/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
04/26/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
05/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
06/21/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
07/28/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
08/24/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
09/27/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined
10/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Mtn Reservoir	<=0, OG, P User-Defined

# samples:	10	min:	0 CFU/100ml
# detects:	10	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 10 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/04/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
02/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
03/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
04/06/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
05/03/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
06/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
07/05/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
08/03/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
09/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
10/04/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
11/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Bell McKinnon Reservoir	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
02/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
03/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
04/26/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
05/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
06/21/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
07/28/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
08/24/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
09/27/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined
10/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Marina	<=0, OG, P User-Defined



# samples:	10	min:	0 CFU/100ml
# detects:	10	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 10 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/19/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
02/16/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
03/15/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
04/20/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
06/14/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
07/19/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
09/21/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined
10/20/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	1820 Herd Road	<=0, OG, P	User-Defined

# samples:	8	min:	0 CFU/100ml
# detects:	8	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 8 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/12/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P	User-Defined
02/08/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P	User-Defined
03/08/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P	User-Defined
04/12/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P	User-Defined
06/07/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P	User-Defined
07/12/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P	User-Defined

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	North Rd Reservoir #2	<=0, OG, P User-Defined

# samples:	10	min:	0 CFU/100ml
# detects:	10	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 10 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
02/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
03/22/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
04/26/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
05/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
06/21/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
07/29/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
08/24/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
09/27/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
10/25/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Maple Bay Reservoir #2	<=0, OG, P User-Defined

# samples:	10	min:	0 CFU/100ml
# detects:	10	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 10 numerical results)
# of Exceedences:	0		



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Vancouver Island Motorsports	<=0, OG, P User-Defined
04/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Vancouver Island Motorsports	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Vancouver Island Motorsports	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Vancouver Island Motorsports	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Vancouver Island Motorsports	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Vancouver Island Motorsports	<=0, OG, P User-Defined

# samples:	6	min:	0 CFU/100ml
# detects:	6	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 6 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 1 (3-2-SR, 3B169)

Aluminum(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.0050 mg/L	Aluminum	Boys Rd - Well 1	<=0.2 Secondary Standard

# samples: 1	min: < 0.0050 mg/L
# detects: 0	max: < 0.0050 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Antimony (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.00020 mg/L	Antimony (total)	Boys Rd - Well 1	<=0.006 MCL

# samples: 1	min: < 0.00020 mg/L
# detects: 0	max: < 0.00020 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Arsenic (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.00050 mg/L	Arsenic (total)	Boys Rd - Well 1	<=0.010 MCL

# samples: 1	min: < 0.00050 mg/L
# detects: 0	max: < 0.00050 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Barium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.0050 mg/L	Barium (total)	Boys Rd - Well 1	<=2 MCL

# samples: 1	min: < 0.0050 mg/L
# detects: 0	max: < 0.0050 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Beryllium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.00010 mg/L	Beryllium (total)	Boys Rd - Well 1	<=0.004 MCL

# samples: 1	min: < 0.00010 mg/L
# detects: 0	max: < 0.00010 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.10 ug/L	Bismuth (total)	Boys Rd - Well 1		

# samples:	1	min:	< 0.10 ug/L		
# detects:	0	max:	< 0.10 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.0500 mg/L	Boron (total)	Boys Rd - Well 1	<=5	MAC

# samples:	1	min:	< 0.0500 mg/L		
# detects:	0	max:	< 0.0500 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.01 mg/L	Bromate	Boys Rd - Well 1	<=0.01	MAC

# samples:	1	min:	< 0.01 mg/L		
# detects:	0	max:	< 0.01 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Cadmium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.000010 mg/L	Cadmium (total)	Boys Rd - Well 1	<=0.005	MCL

# samples:	1	min:	< 0.000010 mg/L		
# detects:	0	max:	< 0.000010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Calcium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	6,270 ug/L	Calcium (total)	Boys Rd - Well 1		

# samples:	1	min:	6,270 ug/L		
# detects:	1	max:	6,270 ug/L		
# non-detects:	0	avg:	6,270 ug/L (based on 1 numerical results)		
# of Exceedences:	0				

Chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	1.63 mg/L	Chloride	Boys Rd - Well 1	<=250	Secondary Standard

# samples:	1	min:	1.63 mg/L
# detects:	1	max:	1.63 mg/L
# non-detects:	0	avg:	1.63 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.00050 mg/L	Chromium (total)	Boys Rd - Well 1	<=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.10 ug/L	Cobalt (total)	Boys Rd - Well 1	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 0.00523 mg/L	Copper (total)	Boys Rd - Well 1	<=1 Secondary Standard

# samples:	1	min:	0.00523 mg/L
# detects:	1	max:	0.00523 mg/L
# non-detects:	0	avg:	0.00523 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.0020 mg/L	Cyanide (total)	Boys Rd - Well 1	<=0.2 MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.0100 mg/L	Diquat	Boys Rd - Well 1	<=0.02 MCL

# samples:	1	min:	< 0.0100 mg/L
------------	---	------	---------------

# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.1 mg/L	Fluoride	Boys Rd - Well 1	<=4.0	MCL

# samples:	1	min:	< 0.1 mg/L
# detects:	0	max:	< 0.1 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.05 mg/L	Glyphosate	Boys Rd - Well 1	<=0.7	MCL

# samples:	1	min:	< 0.05 mg/L
# detects:	0	max:	< 0.05 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Hardness (total, as CaCO3)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	18.7 mg/L	Hardness (total, as CaCO3)	Boys Rd - Well 1		

# samples:	1	min:	18.7 mg/L
# detects:	1	max:	18.7 mg/L
# non-detects:	0	avg:	18.7 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	0.148 mg/L	Iron (total)	Boys Rd - Well 1	<=0.3	Secondary Standard

# samples:	1	min:	0.148 mg/L
# detects:	1	max:	0.148 mg/L
# non-detects:	0	avg:	0.148 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	0.00045 mg/L	Lead (total)	Boys Rd - Well 1	<=0.015	MCL

# samples:	1	min:	0.00045 mg/L
# detects:	1	max:	0.00045 mg/L

# non-detects:	0	avg:	0.00045 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lithium (dissolved)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	< 0.10 ug/L	Lithium (dissolved)	Boys Rd - Well 1	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (dissolved)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	745 ug/L	Magnesium (dissolved)	Boys Rd - Well 1	

# samples:	1	min:	745 ug/L
# detects:	1	max:	745 ug/L
# non-detects:	0	avg:	745 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	0.00084 mg/L	Manganese (total)	Boys Rd - Well 1	<=0.05 Secondary Standard

# samples:	1	min:	0.00084 mg/L
# detects:	1	max:	0.00084 mg/L
# non-detects:	0	avg:	0.00084 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	< 0.000010 mg/L	Mercury (total)	Boys Rd - Well 1	<=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	< 0.10 ug/L	Molybdenum (total)	Boys Rd - Well 1	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Nickel (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.00040 mg/L	Nickel (total)	Boys Rd - Well 1	<=0.1	MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	0.093 mg/L	Nitrate (as N)	Boys Rd - Well 1	<=10	MCL

# samples:	1	min:	0.093 mg/L
# detects:	1	max:	0.093 mg/L
# non-detects:	0	avg:	0.093 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.2 mg/L	Nitrilotriacetic acid / NTA	Boys Rd - Well 1	<=0.4	MAC

# samples:	1	min:	< 0.2 mg/L
# detects:	0	max:	< 0.2 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
-----------------------------	--	------------------	---------------------	----------	--

01/18/2021 09:40	< 0.0050 mg/L	Paraquat	Boys Rd - Well 1	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride
------------------	---------------	----------	------------------	---------	--

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
-----------------------	--	------------------	---------------------	----------	--

01/04/2021	7.39	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
01/25/2021	7.50	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard



pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/01/2021	7.52	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
03/01/2021	7.59	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
04/07/2021	7.67	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
05/03/2021	7.6	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
06/01/2021	6.96	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
07/15/2021	6.60	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
09/07/2021	6.75	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
11/01/2021	6.7	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard

# samples:	10	min:	6.60
# detects:	10	max:	7.67
# non-detects:	0	avg:	7.23 (based on 10 numerical results)
# of Exceedences:	0		

pH(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	7.08	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard

# samples:	1	min:	7.08
# detects:	1	max:	7.08
# non-detects:	0	avg:	7.08 (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	170 ug/L	Potassium (total)	Boys Rd - Well 1		

# samples:	1	min:	170 ug/L
# detects:	1	max:	170 ug/L
# non-detects:	0	avg:	170 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.00050 mg/L	Selenium (total)	Boys Rd - Well 1	<=0.05	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	2,000 ug/L	Silicon (total, as Si)	Boys Rd - Well 1		

# samples:	1	min:	2,000 ug/L
# detects:	1	max:	2,000 ug/L
# non-detects:	0	avg:	2,000 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.000050 mg/L	Silver (total)	Boys Rd - Well 1	<=0.1	Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	1.52 mg/L	Sodium (total)	Boys Rd - Well 1	<=160	MCL

# samples:	1	min:	1.52 mg/L
# detects:	1	max:	1.52 mg/L
# non-detects:	0	avg:	1.52 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	20.0 ug/L	Strontium (total)	Boys Rd - Well 1		

# samples:	1	min:	20.0 ug/L
# detects:	1	max:	20.0 ug/L
# non-detects:	0	avg:	20.0 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 3,000 ug/L	Sulfur (total)	Boys Rd - Well 1		

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	1.5 mg/L	Sulphate	Boys Rd - Well 1	<=250	Secondary Standard

# samples:	1	min:	1.5 mg/L
# detects:	1	max:	1.5 mg/L

# non-detects:	0	avg:	1.5 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 20 ug/L	Sulphide (total, as S)	Boys Rd - Well 1	

# samples:	1	min:	< 20 ug/L
# detects:	0	max:	< 20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
--------------------------------	------------------	---------------------	----------

* 01/04/2021	15.2 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
01/25/2021	14.7 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
02/01/2021	12.7 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
03/01/2021	12.4 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
04/07/2021	13.2 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
05/03/2021	11.5 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
07/15/2021	14.8 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 09/07/2021	17.3 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 11/01/2021	16 degrees C	Temperature	Boys Rd - Well 1	<=15	AO

# samples:	9	min:	11.5 degrees C
# detects:	9	max:	17.3 degrees C
# non-detects:	0	avg:	14.2 degrees C (based on 9 numerical results)
# of Exceedences:	3		

Thallium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.000020 mg/L	Thallium (total)	Boys Rd - Well 1	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.20 ug/L	Tin (total)	Boys Rd - Well 1	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Titanium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	< 5.0 ug/L	Titanium (total)	Boys Rd - Well 1	

samples: 1 min: < 5.0 ug/L
 # detects: 0 max: < 5.0 ug/L
 # non-detects: 1 avg: n/a (based on 0 numerical results)
 # of Exceedences: 0

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/04/2021	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
01/25/2021	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
02/01/2021	0.11 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
03/01/2021	0.111 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
04/07/2021	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
* 05/03/2021	0.7 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
06/01/2021	0.01 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
07/15/2021	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
09/07/2021	0.072 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
11/01/2021	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined

samples: 10 min: 0.01 NTU
 # detects: 10 max: 0.7 NTU
 # non-detects: 0 avg: 0.143 NTU (based on 10 numerical results)
 # of Exceedences: 1 95th percentile: 0.700 NTU

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/18/2021 09:40	< 0.000020 mg/L	Uranium (total)	Boys Rd - Well 1	<=0.02	MAC

samples: 1 min: < 0.000020 mg/L
 # detects: 0 max: < 0.000020 mg/L
 # non-detects: 1 avg: n/a (based on 0 numerical results)
 # of Exceedences: 0

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40	< 1.0 ug/L	Vanadium (total)	Boys Rd - Well 1	

samples: 1 min: < 1.0 ug/L
 # detects: 0 max: < 1.0 ug/L
 # non-detects: 1 avg: n/a (based on 0 numerical results)



of Exceedences: 0

Zinc (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 0.0056 mg/L	Zinc (total)	Boys Rd - Well 1	<=5 Secondary Standard

# samples:	1	min:	0.0056 mg/L
# detects:	1	max:	0.0056 mg/L
# non-detects:	0	avg:	0.0056 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/18/2021 09:40 < 0.10 ug/L	Zirconium (total)	Boys Rd - Well 1	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 3 (3-4-SR, 3B16B)

1,1,1-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.0010 mg/L	1,1,1-Trichloroethane	Boys Rd - Well 3	<=0.2 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2,2-Tetrachloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.5 ug/L	1,1,2,2-Tetrachloroethane	Boys Rd - Well 3	

# samples:	1	min:	< 0.5 ug/L
# detects:	0	max:	< 0.5 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.0010 mg/L	1,1,2-Trichloroethane	Boys Rd - Well 3	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
1,1-Dichloroethane(Lab Data Transfer) 08/10/2021 11:00 < 1.0 ug/L	1,1-Dichloroethane	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
1,1-Dichloroethylene(Lab Data Transfer) 08/10/2021 11:00 < 0.0010 mg/L	1,1-Dichloroethylene	Boys Rd - Well 3	<=0.007 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
1,2-Dichlorobenzene(Lab Data Transfer) 08/10/2021 11:00 < 0.0005 mg/L	1,2-Dichlorobenzene	Boys Rd - Well 3	<=0.6 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
1,2-Dichloroethene(Lab Data Transfer) 08/10/2021 11:00 < 1.0 ug/L	1,2-Dichloroethene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
1,2-Dichloropropane(Lab Data Transfer) 08/10/2021 11:00 < 0.0010 mg/L	1,2-Dichloropropane	Boys Rd - Well 3	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 1.0 ug/L	1,3-Dichlorobenzene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichloropropene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 1.0 ug/L	1,3-Dichloropropene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,4-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.0010 mg/L	1,4-Dichlorobenzene	Boys Rd - Well 3	<=0.075 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.100 ug/L	1-Methylnaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.50 ug/L	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
------------	---	------	-------------

# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.00050 mg/L	2,3,4,6-Tetrachlorophenol	Boys Rd - Well 3	<=0.001 AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.50 ug/L	2,3,4-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.50 ug/L	2,3,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.50 ug/L	2,3,6-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.20 ug/L	2,3-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.20 ug/L	2,4 + 2,5-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.50 ug/L	2,4,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.10 ug/L	2,4,5-Trichloropheno xyacetic acid / 2,4,5-T	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.00050 mg/L	2,4,6-Trichlorophenol	Boys Rd - Well 3	<=0.002 AO (MAC is 0.005 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
2,4-Dichlorophenoxy acetic acid / 2,4-D	Boys Rd - Well 3	<=0.07 MCL
08/10/2021 11:00	< 0.00010 mg/L	
# samples:	1	min: < 0.00010 mg/L
# detects:	0	max: < 0.00010 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

2,6-Dichlorophenol(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
2,6-Dichlorophenol	Boys Rd - Well 3	
08/10/2021 11:00	< 0.20 ug/L	
# samples:	1	min: < 0.20 ug/L
# detects:	0	max: < 0.20 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

2-Chloronaphthalene(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
2-Chloronaphthalene	Boys Rd - Well 3	
08/10/2021 11:00	< 0.100 ug/L	
# samples:	1	min: < 0.100 ug/L
# detects:	0	max: < 0.100 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

2-Chlorophenol(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
2-Chlorophenol	Boys Rd - Well 3	
08/10/2021 11:00	< 0.10 ug/L	
# samples:	1	min: < 0.10 ug/L
# detects:	0	max: < 0.10 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
2-methyl-4-chlorophe noxyacetic acid / MCPA	Boys Rd - Well 3	
08/10/2021 11:00	< 0.02 ug/L	
# samples:	1	min: < 0.02 ug/L
# detects:	0	max: < 0.02 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)



of Exceedences: 0

2-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.100 ug/L	2-Methylnaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.10 ug/L	3 and 4-Chlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.50 ug/L	3,4,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.20 ug/L	3,4-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.20 ug/L	3,5-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
4-Chloro-3-methylphenol (Parachlorometacresol)	Boys Rd - Well 3	

08/10/2021 11:00	< 0.50 ug/L	
# samples:	1	min: < 0.50 ug/L
# detects:	0	max: < 0.50 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Acenaphthene(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Acenaphthene	Boys Rd - Well 3	

08/10/2021 11:00	< 0.050 ug/L	
# samples:	1	min: < 0.050 ug/L
# detects:	0	max: < 0.050 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Acenaphthylene(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Acenaphthylene	Boys Rd - Well 3	

08/10/2021 11:00	< 0.200 ug/L	
# samples:	1	min: < 0.200 ug/L
# detects:	0	max: < 0.200 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Acridine(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Acridine	Boys Rd - Well 3	

08/10/2021 11:00	< 0.050 ug/L	
# samples:	1	min: < 0.050 ug/L
# detects:	0	max: < 0.050 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Alachlor(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Alachlor	Boys Rd - Well 3	<=0.002 MCL

08/10/2021 11:00	< 0.000100 mg/L	
# samples:	1	min: < 0.000100 mg/L
# detects:	0	max: < 0.000100 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)



of Exceedences: 0

Aldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.006 ug/L	Aldrin	Boys Rd - Well 3	

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	alpha-BHC	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aluminum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0050 mg/L	Aluminum (total)	Boys Rd - Well 3	<=0.2 Secondary Standard
10/25/2021 08:40	0.0083 mg/L	Aluminum (total)	Boys Rd - Well 3	<=0.2 Secondary Standard

# samples:	2	min:	< 0.0050 mg/L
# detects:	1	max:	0.0083 mg/L
# non-detects:	1	avg:	0.0083 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Anthracene	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00020 mg/L	Antimony (total)	Boys Rd - Well 3	<=0.006 MCL
10/25/2021 08:40	< 0.00020 mg/L	Antimony (total)	Boys Rd - Well 3	<=0.006 MCL

# samples:	2	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Aroclor 1016(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1016	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1221	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1232	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1242	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1248	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1254	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1260(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1260	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1262(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1262	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1268(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1268	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Arsenic (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	Arsenic (total)	Boys Rd - Well 3	<=0.010 MCL
10/25/2021 08:40	< 0.00050 mg/L	Arsenic (total)	Boys Rd - Well 3	<=0.010 MCL
# samples:	2	min:	< 0.00050 mg/L	
# detects:	0	max:	< 0.00050 mg/L	
# non-detects:	2	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			



Atrazine + N-dealkylated metabolites(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Atrazine + N-dealkylated metabolites	Boys Rd - Well 3	<=0.005 MAC
08/10/2021 11:00	< 0.000100 mg/L	
# samples:	1	min: < 0.000100 mg/L
# detects:	0	max: < 0.000100 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Azinphos-methyl(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Azinphos-methyl	Boys Rd - Well 3	<=0.02 MAC
08/10/2021 11:00	< 0.000200 mg/L	
# samples:	1	min: < 0.000200 mg/L
# detects:	0	max: < 0.000200 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Barium (total)(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Barium (total)	Boys Rd - Well 3	<=2 MCL
08/10/2021 11:00	< 0.0050 mg/L	
10/25/2021 08:40	< 0.0050 mg/L	<=2 MCL
# samples:	2	min: < 0.0050 mg/L
# detects:	0	max: < 0.0050 mg/L
# non-detects:	2	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Bendiocarb(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Bendiocarb	Boys Rd - Well 3	
08/10/2021 11:00	< 0.0010 mg/L	
# samples:	1	min: < 0.0010 mg/L
# detects:	0	max: < 0.0010 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Benzene(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Benzene	Boys Rd - Well 3	<=0.001 MCL
08/10/2021 11:00	< 0.0005 mg/L	
# samples:	1	min: < 0.0005 mg/L
# detects:	0	max: < 0.0005 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)



of Exceedences: 0

Benzo(a)anthracene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.010 ug/L	Benzo(a)anthracene	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.010 ug/L	Benzo(b)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.050 ug/L	Benzo(b,j)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(g,h,i)perylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.050 ug/L	Benzo(g,h,i)perylene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(k)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.050 ug/L	Benzo(k)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

non-detects: 1 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Beryllium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Beryllium (total)	Boys Rd - Well 3	<=0.004 MCL
10/25/2021 08:40	< 0.00010 mg/L	Beryllium (total)	Boys Rd - Well 3	<=0.004 MCL

samples: 2 min: < 0.00010 mg/L
detects: 0 max: < 0.00010 mg/L
non-detects: 2 avg: n/a (based on 0 numerical results)
of Exceedences: 0

beta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	beta-BHC	Boys Rd - Well 3	

samples: 1 min: < 0.050 ug/L
detects: 0 max: < 0.050 ug/L
non-detects: 1 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.10 ug/L	Bismuth (total)	Boys Rd - Well 3	
10/25/2021 08:40	< 0.10 ug/L	Bismuth (total)	Boys Rd - Well 3	

samples: 2 min: < 0.10 ug/L
detects: 0 max: < 0.10 ug/L
non-detects: 2 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0500 mg/L	Boron (total)	Boys Rd - Well 3	<=5 MAC
10/25/2021 08:40	< 0.0500 mg/L	Boron (total)	Boys Rd - Well 3	<=5 MAC

samples: 2 min: < 0.0500 mg/L
detects: 0 max: < 0.0500 mg/L
non-detects: 2 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Bromacil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Bromacil	Boys Rd - Well 3	

samples: 1 min: < 0.100 ug/L

# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.01 mg/L	Bromate	Boys Rd - Well 3	<=0.01	MAC
10/25/2021 08:40	< 0.01 mg/L	Bromate	Boys Rd - Well 3	<=0.01	MAC

# samples:	2	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0010 mg/L	Bromodichloromethane (dichlorobromomethane)	Boys Rd - Well 3	<=0.016	MAC

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 1.0 ug/L	Bromoform	Boys Rd - Well 3		

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoxynil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Bromoxynil	Boys Rd - Well 3	<=0.005	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Butachlor	Boys Rd - Well 3	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Cadmium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000010 mg/L	Cadmium (total)	Boys Rd - Well 3	<=0.005 MCL
10/25/2021 08:40	< 0.000010 mg/L	Cadmium (total)	Boys Rd - Well 3	<=0.005 MCL
# samples:	2	min:	< 0.000010 mg/L	
# detects:	0	max:	< 0.000010 mg/L	
# non-detects:	2	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Calcium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	8,390 ug/L	Calcium (total)	Boys Rd - Well 3	
10/25/2021 08:40	9,470 ug/L	Calcium (total)	Boys Rd - Well 3	
# samples:	2	min:	8,390 ug/L	
# detects:	2	max:	9,470 ug/L	
# non-detects:	0	avg:	8,930 ug/L (based on 2 numerical results)	
# of Exceedences:	0			

Captan(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Captan	Boys Rd - Well 3	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Carbaryl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0010 mg/L	Carbaryl	Boys Rd - Well 3	<=0.09 MAC
# samples:	1	min:	< 0.0010 mg/L	
# detects:	0	max:	< 0.0010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Carbofuran(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0010 mg/L	Carbofuran	Boys Rd - Well 3	<=0.04	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Carbon tetrachloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0005 mg/L	Carbon tetrachloride	Boys Rd - Well 3	<=0.003	MCL
# samples:	1	min:	< 0.0005 mg/L		
# detects:	0	max:	< 0.0005 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chlordane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000050 mg/L	Chlordane	Boys Rd - Well 3	<=0.002	MCL
# samples:	1	min:	< 0.000050 mg/L		
# detects:	0	max:	< 0.000050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	1.77 mg/L	Chloride	Boys Rd - Well 3	<=250	Secondary Standard
10/25/2021 08:40	1.96 mg/L	Chloride	Boys Rd - Well 3	<=250	Secondary Standard
# samples:	2	min:	1.77 mg/L		
# detects:	2	max:	1.96 mg/L		
# non-detects:	0	avg:	1.87 mg/L (based on 2 numerical results)		
# of Exceedences:	0				

Chlorobenzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0010 mg/L	Chlorobenzene	Boys Rd - Well 3	<=0.1	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 2.0 ug/L	Chloroethane	Boys Rd - Well 3	
# samples:	1	min:	< 2.0 ug/L	
# detects:	0	max:	< 2.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chloroform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 1.0 ug/L	Chloroform	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chlorothalonil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Chlorothalonil	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chlorpyrifos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000010 mg/L	Chlorpyrifos	Boys Rd - Well 3	<=0.09 MAC
# samples:	1	min:	< 0.000010 mg/L	
# detects:	0	max:	< 0.000010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chromium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	Chromium (total)	Boys Rd - Well 3	<=0.1 MCL
10/25/2021 08:40	< 0.00050 mg/L	Chromium (total)	Boys Rd - Well 3	<=0.1 MCL
# samples:	2	min:	< 0.00050 mg/L	
# detects:	0	max:	< 0.00050 mg/L	
# non-detects:	2	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chrysene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 ug/L	Chrysene	Boys Rd - Well 3		
# samples:	1	min:	< 0.050 ug/L		
# detects:	0	max:	< 0.050 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

cis-1,2-Dichloroethylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0010 mg/L	cis-1,2-Dichloroethylene	Boys Rd - Well 3	<=0.07	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Cobalt (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.10 ug/L	Cobalt (total)	Boys Rd - Well 3		
10/25/2021 08:40	< 0.10 ug/L	Cobalt (total)	Boys Rd - Well 3		
# samples:	2	min:	< 0.10 ug/L		
# detects:	0	max:	< 0.10 ug/L		
# non-detects:	2	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Copper (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.0101 mg/L	Copper (total)	Boys Rd - Well 3	<=1	Secondary Standard
10/25/2021 08:40	0.00453 mg/L	Copper (total)	Boys Rd - Well 3	<=1	Secondary Standard
# samples:	2	min:	0.00453 mg/L		
# detects:	2	max:	0.0101 mg/L		
# non-detects:	0	avg:	0.00732 mg/L (based on 2 numerical results)		
# of Exceedences:	0				

Cyanazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.100 ug/L	Cyanazine	Boys Rd - Well 3		
# samples:	1	min:	< 0.100 ug/L		
# detects:	0	max:	< 0.100 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				



Cyanide (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0020 mg/L	Cyanide (total)	Boys Rd - Well 3	<=0.2	MAC for Cyanide (free)
10/25/2021 08:40	0.0043 mg/L	Cyanide (total)	Boys Rd - Well 3	<=0.2	MAC for Cyanide (free)

# samples:	2	min:	< 0.0020 mg/L		
# detects:	1	max:	0.0043 mg/L		
# non-detects:	1	avg:	0.0043 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

DDT + metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.010 ug/L	DDT + metabolites	Boys Rd - Well 3		

# samples:	1	min:	< 0.010 ug/L		
# detects:	0	max:	< 0.010 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

delta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 ug/L	delta-BHC	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L		
# detects:	0	max:	< 0.050 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Deltamethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.100 ug/L	Deltamethrin	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L		
# detects:	0	max:	< 0.100 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Diazinon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000020 mg/L	Diazinon	Boys Rd - Well 3	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L		
# detects:	0	max:	< 0.000020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Dibenzo(a,h)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Dibenzo(a,h)anthracene	Boys Rd - Well 3	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 1.0 ug/L	Dibromochloromethane (Chlorodibromomethane)	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromomethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 1.0 ug/L	Dibromomethane	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dicamba(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Dicamba	Boys Rd - Well 3	<=0.12 MAC
# samples:	1	min:	< 0.00010 mg/L	
# detects:	0	max:	< 0.00010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dichloromethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0030 mg/L	Dichloromethane	Boys Rd - Well 3	<=0.005 MCL
# samples:	1	min:	< 0.0030 mg/L	
# detects:	0	max:	< 0.0030 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	

of Exceedences: 0

Dichlorvos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Dichlorvos	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diclofop-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000100 mg/L	Diclofop-methyl	Boys Rd - Well 3	<=0.009 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Dieldrin	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000200 mg/L	Dimethoate	Boys Rd - Well 3	<=0.02 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dinoseb(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Dinoseb	Boys Rd - Well 3	<=0.007 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0100 mg/L	Diquat	Boys Rd - Well 3	<=0.02	MCL
10/25/2021 08:40	< 0.0100 mg/L	Diquat	Boys Rd - Well 3	<=0.02	MCL
# samples:	2	min:	< 0.0100 mg/L		
# detects:	0	max:	< 0.0100 mg/L		
# non-detects:	2	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Disulfoton(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.100 ug/L	Disulfoton	Boys Rd - Well 3		
# samples:	1	min:	< 0.100 ug/L		
# detects:	0	max:	< 0.100 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Diuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Diuron	Boys Rd - Well 3	<=0.15	MAC
# samples:	1	min:	< 0.000200 mg/L		
# detects:	0	max:	< 0.000200 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Endosulfan (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.010 ug/L	Endosulfan (total)	Boys Rd - Well 3		
# samples:	1	min:	< 0.010 ug/L		
# detects:	0	max:	< 0.010 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Endosulfan sulfate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 ug/L	Endosulfan sulfate	Boys Rd - Well 3		
# samples:	1	min:	< 0.050 ug/L		
# detects:	0	max:	< 0.050 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Endrin aldehyde(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Endrin aldehyde	Boys Rd - Well 3	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Endrin ketone(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Endrin ketone	Boys Rd - Well 3	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Endrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000020 mg/L	Endrin	Boys Rd - Well 3	<=0.002 MCL
# samples:	1	min:	< 0.000020 mg/L	
# detects:	0	max:	< 0.000020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Ethylbenzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0010 mg/L	Ethylbenzene	Boys Rd - Well 3	<=0.7 MCL
# samples:	1	min:	< 0.0010 mg/L	
# detects:	0	max:	< 0.0010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Ethylene dibromide / EDB(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0003 mg/L	Ethylene dibromide / EDB	Boys Rd - Well 3	<=0.00002 MCL
# samples:	1	min:	< 0.0003 mg/L	
# detects:	0	max:	< 0.0003 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fenchlorphos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Fenchlorphos	Boys Rd - Well 3	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.030 ug/L	Fluoranthene	Boys Rd - Well 3	
# samples:	1	min:	< 0.030 ug/L	
# detects:	0	max:	< 0.030 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluorene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Fluorene	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluoride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.1 mg/L	Fluoride	Boys Rd - Well 3	<=4.0 MCL
10/25/2021 08:40	< 0.1 mg/L	Fluoride	Boys Rd - Well 3	<=4.0 MCL
# samples:	2	min:	< 0.1 mg/L	
# detects:	0	max:	< 0.1 mg/L	
# non-detects:	2	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.05 mg/L	Glyphosate	Boys Rd - Well 3	<=0.7 MCL
10/25/2021 08:40	< 0.05 mg/L	Glyphosate	Boys Rd - Well 3	<=0.7 MCL
# samples:	2	min:	< 0.05 mg/L	
# detects:	0	max:	< 0.05 mg/L	
# non-detects:	2	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Hardness (total, as CaCO3)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	25.3 mg/L	Hardness (total, as CaCO3)	Boys Rd - Well 3	
10/25/2021 08:40	27.9 mg/L	Hardness (total, as CaCO3)	Boys Rd - Well 3	
# samples:	2	min:	25.3 mg/L	
# detects:	2	max:	27.9 mg/L	
# non-detects:	0	avg:	26.6 mg/L (based on 2 numerical results)	
# of Exceedences:	0			

Heptachlor epoxide(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000010 mg/L	Heptachlor epoxide	Boys Rd - Well 3	<=0.0002 MCL
# samples:	1	min:	< 0.000010 mg/L	
# detects:	0	max:	< 0.000010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Heptachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000010 mg/L	Heptachlor	Boys Rd - Well 3	<=0.0004 MCL
# samples:	1	min:	< 0.000010 mg/L	
# detects:	0	max:	< 0.000010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Indeno(1,2,3-c,d)pyrene	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Iron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.01 mg/L	Iron (total)	Boys Rd - Well 3	<=0.3 Secondary Standard
10/25/2021 08:40	< 0.01 mg/L	Iron (total)	Boys Rd - Well 3	<=0.3 Secondary Standard
# samples:	2	min:	< 0.01 mg/L	
# detects:	0	max:	< 0.01 mg/L	

# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.00078 mg/L	Lead (total)	Boys Rd - Well 3	<=0.015 MCL
10/25/2021 08:40	0.00022 mg/L	Lead (total)	Boys Rd - Well 3	<=0.015 MCL

# samples:	2	min:	0.00022 mg/L
# detects:	2	max:	0.00078 mg/L
# non-detects:	0	avg:	0.00050 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000050 mg/L	Lindane	Boys Rd - Well 3	<=0.0002 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Linuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Linuron	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lithium (dissolved)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.10 ug/L	Lithium (dissolved)	Boys Rd - Well 3	
10/25/2021 08:40	< 0.10 ug/L	Lithium (dissolved)	Boys Rd - Well 3	

# samples:	2	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (dissolved)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	1,050 ug/L	Magnesium (dissolved)	Boys Rd - Well 3	
10/25/2021 08:40	1,030 ug/L	Magnesium (dissolved)	Boys Rd - Well 3	

# samples:	2	min:	1,030 ug/L
# detects:	2	max:	1,050 ug/L
# non-detects:	0	avg:	1,040 ug/L (based on 2 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000100 mg/L	Malathion	Boys Rd - Well 3	<=0.19	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00020 mg/L	Manganese (total)	Boys Rd - Well 3	<=0.05	Secondary Standard
10/25/2021 08:40	< 0.00020 mg/L	Manganese (total)	Boys Rd - Well 3	<=0.05	Secondary Standard

# samples:	2	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000010 mg/L	Mercury (total)	Boys Rd - Well 3	<=0.002	MCL
10/25/2021 08:40	< 0.000010 mg/L	Mercury (total)	Boys Rd - Well 3	<=0.002	MCL

# samples:	2	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methoxychlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000050 mg/L	Methoxychlor	Boys Rd - Well 3	<=0.04	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.100 ug/L	Methyl parathion	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methyl tert-butyl ether / MTBE(Lab Data Transfer)		
08/10/2021 11:00 < 1.0 ug/L	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Metolachlor(Lab Data Transfer)		
08/10/2021 11:00 < 0.000100 mg/L	Boys Rd - Well 3	<=0.05 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Metribuzin(Lab Data Transfer)		
08/10/2021 11:00 < 0.000200 mg/L	Boys Rd - Well 3	<=0.08 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Molybdenum (total)(Lab Data Transfer)		
08/10/2021 11:00 < 0.10 ug/L	Boys Rd - Well 3	
10/25/2021 08:40 < 0.10 ug/L	Boys Rd - Well 3	

# samples:	2	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Naphthalene(Lab Data Transfer)		
08/10/2021 11:00 < 0.200 ug/L	Boys Rd - Well 3	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00040 mg/L	Nickel (total)	Boys Rd - Well 3	<=0.1	MCL
10/25/2021 08:40	< 0.00040 mg/L	Nickel (total)	Boys Rd - Well 3	<=0.1	MCL

# samples:	2	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.086 mg/L	Nitrate (as N)	Boys Rd - Well 3	<=10	MCL
10/25/2021 08:40	0.073 mg/L	Nitrate (as N)	Boys Rd - Well 3	<=10	MCL

# samples:	2	min:	0.073 mg/L
# detects:	2	max:	0.086 mg/L
# non-detects:	0	avg:	0.080 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.2 mg/L	Nitrilotriacetic acid / NTA	Boys Rd - Well 3	<=0.4	MAC
10/25/2021 08:40	< 0.2 mg/L	Nitrilotriacetic acid / NTA	Boys Rd - Well 3	<=0.4	MAC

# samples:	2	min:	< 0.2 mg/L
# detects:	0	max:	< 0.2 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0050 mg/L	Paraquat	Boys Rd - Well 3	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
10/25/2021 08:40	< 0.0050 mg/L	Paraquat	Boys Rd - Well 3	<=0.007

MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	2	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Parathion	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Pentachloronitrobenzene / PCNB	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachlorophenol / PCP(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	Pentachlorophenol / PCP	Boys Rd - Well 3	<=0.001 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Permethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Permethrin	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
------------	---	------	--------------

# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
02/18/2021 7.34	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard
04/21/2021 7.48	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard
06/14/2021 6.66	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard
07/19/2021 6.58	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard
08/17/2021 6.5	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard

# samples:	5	min:	6.5
# detects:	5	max:	7.48
# non-detects:	0	avg:	6.91 (based on 5 numerical results)
# of Exceedences:	0		

pH(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 7.04	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard
10/25/2021 08:40 7.27	pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard

# samples:	2	min:	7.04
# detects:	2	max:	7.27
# non-detects:	0	avg:	7.16 (based on 2 numerical results)
# of Exceedences:	0		

Phenanthrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.100 ug/L	Phenanthrene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phorate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.000100 mg/L	Phorate	Boys Rd - Well 3	<=0.002 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Picloram(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Picloram	Boys Rd - Well 3	<=0.5 MCL
# samples:	1	min:	< 0.00010 mg/L	
# detects:	0	max:	< 0.00010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.150 ug/L	Polychlorinated Biphenyls / PCBs (as arochlor total)	Boys Rd - Well 3	
# samples:	1	min:	< 0.150 ug/L	
# detects:	0	max:	< 0.150 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Potassium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	240 ug/L	Potassium (total)	Boys Rd - Well 3	
10/25/2021 08:40	270 ug/L	Potassium (total)	Boys Rd - Well 3	
# samples:	2	min:	240 ug/L	
# detects:	2	max:	270 ug/L	
# non-detects:	0	avg:	255 ug/L (based on 2 numerical results)	
# of Exceedences:	0			

Prometon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.300 ug/L	Prometon	Boys Rd - Well 3	
# samples:	1	min:	< 0.300 ug/L	
# detects:	0	max:	< 0.300 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Prometryn(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Prometryn	Boys Rd - Well 3	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Pyrene	Boys Rd - Well 3	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Quinoline(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Quinoline	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Selenium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	Selenium (total)	Boys Rd - Well 3	<=0.05 MCL
10/25/2021 08:40	< 0.00050 mg/L	Selenium (total)	Boys Rd - Well 3	<=0.05 MCL
# samples:	2	min:	< 0.00050 mg/L	
# detects:	0	max:	< 0.00050 mg/L	
# non-detects:	2	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Silicon (total, as Si)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	3,100 ug/L	Silicon (total, as Si)	Boys Rd - Well 3	
10/25/2021 08:40	3,100 ug/L	Silicon (total, as Si)	Boys Rd - Well 3	
# samples:	2	min:	3,100 ug/L	
# detects:	2	max:	3,100 ug/L	
# non-detects:	0	avg:	3,100 ug/L (based on 2 numerical results)	
# of Exceedences:	0			

Silver (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000050 mg/L	Silver (total)	Boys Rd - Well 3	<=0.1 Secondary Standard
10/25/2021 08:40	< 0.000050 mg/L	Silver (total)	Boys Rd - Well 3	<=0.1 Secondary Standard
# samples:	2	min:	< 0.000050 mg/L	
# detects:	0	max:	< 0.000050 mg/L	

# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Simazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Simazine	Boys Rd - Well 3	<=0.004	MCL

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	1.92 mg/L	Sodium (total)	Boys Rd - Well 3	<=160	MCL
10/25/2021 08:40	2.33 mg/L	Sodium (total)	Boys Rd - Well 3	<=160	MCL

# samples:	2	min:	1.92 mg/L
# detects:	2	max:	2.33 mg/L
# non-detects:	0	avg:	2.13 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	29.9 ug/L	Strontium (total)	Boys Rd - Well 3		
10/25/2021 08:40	27.0 ug/L	Strontium (total)	Boys Rd - Well 3		

# samples:	2	min:	27.0 ug/L
# detects:	2	max:	29.9 ug/L
# non-detects:	0	avg:	28.5 ug/L (based on 2 numerical results)
# of Exceedences:	0		

Styrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0010 mg/L	Styrene	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.100 ug/L	Sulfotep	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L

non-detects: 1 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Sulfur (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 3,000 ug/L	Sulfur (total)	Boys Rd - Well 3	
10/25/2021 08:40	< 3,000 ug/L	Sulfur (total)	Boys Rd - Well 3	

samples: 2 min: < 3,000 ug/L
detects: 0 max: < 3,000 ug/L
non-detects: 2 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Sulphate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	1.6 mg/L	Sulphate	Boys Rd - Well 3	<=250 Secondary Standard
10/25/2021 08:40	1.3 mg/L	Sulphate	Boys Rd - Well 3	<=250 Secondary Standard

samples: 2 min: 1.3 mg/L
detects: 2 max: 1.6 mg/L
non-detects: 0 avg: 1.5 mg/L (based on 2 numerical results)
of Exceedences: 0

Sulphide (total, as S)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 20 ug/L	Sulphide (total, as S)	Boys Rd - Well 3	
10/25/2021 08:40	< 20 ug/L	Sulphide (total, as S)	Boys Rd - Well 3	

samples: 2 min: < 20 ug/L
detects: 0 max: < 20 ug/L
non-detects: 2 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Tebuthiuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.200 ug/L	Tebuthiuron	Boys Rd - Well 3	

samples: 1 min: < 0.200 ug/L
detects: 0 max: < 0.200 ug/L
non-detects: 1 avg: n/a (based on 0 numerical results)
of Exceedences: 0

Temephos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.500 ug/L	Temephos	Boys Rd - Well 3	

samples: 1 min: < 0.500 ug/L

# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
02/18/2021	11.8 degrees C	Temperature	Boys Rd - Well 3 <=15 AO
04/21/2021	13.9 degrees C	Temperature	Boys Rd - Well 3 <=15 AO
06/14/2021	13.2 degrees C	Temperature	Boys Rd - Well 3 <=15 AO
* 07/19/2021	15.4 degrees C	Temperature	Boys Rd - Well 3 <=15 AO
* 08/17/2021	17 degrees C	Temperature	Boys Rd - Well 3 <=15 AO

# samples:	5	min:	11.8 degrees C
# detects:	5	max:	17 degrees C
# non-detects:	0	avg:	14.3 degrees C (based on 5 numerical results)
# of Exceedences:	2		

Terbufos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000100 mg/L	Terbufos	Boys Rd - Well 3 <=0.001 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tetrachloroethylene / PCE(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0010 mg/L	Tetrachloroethylene / PCE	Boys Rd - Well 3 <=0.003 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Thallium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000020 mg/L	Thallium (total)	Boys Rd - Well 3 <=0.002 MCL
10/25/2021 08:40	< 0.000020 mg/L	Thallium (total)	Boys Rd - Well 3 <=0.002 MCL

# samples:	2	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Time(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
02/18/2021	1,030	Time	Boys Rd - Well 3
04/21/2021	1,145	Time	Boys Rd - Well 3
06/14/2021	1,055	Time	Boys Rd - Well 3
07/19/2021	930	Time	Boys Rd - Well 3
08/17/2021	1,000	Time	Boys Rd - Well 3

# samples:	5	min:	930
# detects:	5	max:	1,145
# non-detects:	0	avg:	1,032 (based on 5 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.20 ug/L	Tin (total)	Boys Rd - Well 3
10/25/2021 08:40	< 0.20 ug/L	Tin (total)	Boys Rd - Well 3

# samples:	2	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 5.0 ug/L	Titanium (total)	Boys Rd - Well 3
10/25/2021 08:40	< 5.0 ug/L	Titanium (total)	Boys Rd - Well 3

# samples:	2	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Toluene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0010 mg/L	Toluene	Boys Rd - Well 3

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

trans-1,2-Dichloroethylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0010 mg/L	trans-1,2-Dichloroethylene	Boys Rd - Well 3

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.100 ug/L	Triallate	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trichloroethylene / TCE(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.0010 mg/L	Trichloroethylene / TCE	Boys Rd - Well 3	<=0.003 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trichlorofluoromethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 1.0 ug/L	Trichlorofluoromethane	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trifluralin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.000200 mg/L	Trifluralin	Boys Rd - Well 3	<=0.045 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Turbidity(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
02/18/2021 0.13 NTU	Turbidity	Boys Rd - Well 3	<=0.5 User-Defined
04/21/2021 0.05 NTU	Turbidity	Boys Rd - Well 3	<=0.5 User-Defined

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
06/14/2021	0.09 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
07/19/2021	0.08 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
08/17/2021	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined

# samples:	5	min:	0.05 NTU
# detects:	5	max:	0.13 NTU
# non-detects:	0	avg:	0.08 NTU (based on 5 numerical results)
# of Exceedences:	0	95th percentile:	0.13 NTU

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000020 mg/L	Uranium (total)	Boys Rd - Well 3	<=0.02	MAC
10/25/2021 08:40	< 0.000020 mg/L	Uranium (total)	Boys Rd - Well 3	<=0.02	MAC

# samples:	2	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 1.0 ug/L	Vanadium (total)	Boys Rd - Well 3		
10/25/2021 08:40	1.5 ug/L	Vanadium (total)	Boys Rd - Well 3		

# samples:	2	min:	< 1.0 ug/L
# detects:	1	max:	1.5 ug/L
# non-detects:	1	avg:	1.5 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Vinyl chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0010 mg/L	Vinyl chloride	Boys Rd - Well 3	<=0.001	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Xylenes (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0020 mg/L	Xylenes (total)	Boys Rd - Well 3	<=10	MCL

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Zinc (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.0129 mg/L	Zinc (total)	Boys Rd - Well 3	<=5	Secondary Standard
10/25/2021 08:40	0.0065 mg/L	Zinc (total)	Boys Rd - Well 3	<=5	Secondary Standard

samples: 2 min: 0.0065 mg/L
 # detects: 2 max: 0.0129 mg/L
 # non-detects: 0 avg: 0.0097 mg/L (based on 2 numerical results)
 # of Exceedences: 0

Zirconium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.10 ug/L	Zirconium (total)	Boys Rd - Well 3		
10/25/2021 08:40	< 0.10 ug/L	Zirconium (total)	Boys Rd - Well 3		

samples: 2 min: < 0.10 ug/L
 # detects: 0 max: < 0.10 ug/L
 # non-detects: 2 avg: n/a (based on 0 numerical results)
 # of Exceedences: 0

Facility: Water - Raw; Water - Raw
 Sampling Point: Boys Rd - Well 5 (3-6-SR, 3B16D)

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/22/2021	7.53	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
05/25/2021	6.76	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
07/28/2021	6.74	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
08/24/2021	6.67	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
09/27/2021	6.78	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
10/25/2021	6.8	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard

samples: 6 min: 6.67
 # detects: 6 max: 7.53
 # non-detects: 0 avg: 6.88 (based on 6 numerical results)
 # of Exceedences: 0

Temperature(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/22/2021	13.3 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
05/25/2021	12.7 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 07/28/2021	15.9 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 08/24/2021	16.0 degrees C	Temperature	Boys Rd - Well 5	<=15	AO



Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 09/27/2021 18.9 degrees C	Temperature	Boys Rd - Well 5	<=15 AO
* 10/25/2021 16 degrees C	Temperature	Boys Rd - Well 5	<=15 AO
# samples: 6	min: 12.7 degrees C		
# detects: 6	max: 18.9 degrees C		
# non-detects: 0	avg: 15.5 degrees C (based on 6 numerical results)		
# of Exceedences: 4			

Time(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
02/22/2021 1,000	Time	Boys Rd - Well 5	
05/25/2021 1,330	Time	Boys Rd - Well 5	
07/28/2021 1,120	Time	Boys Rd - Well 5	
08/24/2021 910	Time	Boys Rd - Well 5	
09/27/2021 1,125	Time	Boys Rd - Well 5	
10/25/2021 845	Time	Boys Rd - Well 5	
# samples: 6	min: 845		
# detects: 6	max: 1,330		
# non-detects: 0	avg: 1,055 (based on 6 numerical results)		
# of Exceedences: 0			

Turbidity(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
02/22/2021 0.102 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
05/25/2021 0.07 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
07/28/2021 0.07 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
08/24/2021 0.075 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
09/27/2021 0.05 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
10/25/2021 0.06 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
# samples: 6	min: 0.05 NTU		
# detects: 6	max: 0.102 NTU		
# non-detects: 0	avg: 0.071 NTU (based on 6 numerical results)		
# of Exceedences: 0	95th percentile: 0.102 NTU		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 < means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown



* Indicates Criteria is exceeded

DISINFECTANTS

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	User-Defined	
* 01/05/2021	0.00080 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 01/11/2021	0.00089 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 01/20/2021	0.00111 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 01/27/2021	0.00109 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 02/01/2021	0.00095 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 02/08/2021	0.00093 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 02/18/2021	0.00097 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 02/24/2021	0.00084 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 03/01/2021	0.00074 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 03/12/2021	0.00081 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 03/16/2021	0.00083 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 03/23/2021	0.00084 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 03/30/2021	0.00077 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 04/07/2021	0.00075 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 04/15/2021	0.00092 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 04/21/2021	0.00072 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 04/26/2021	0.00075 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 05/04/2021	0.00087 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 05/11/2021	0.00096 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 05/18/2021	0.00100 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 05/26/2021	0.00092 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 06/15/2021	0.00086 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 06/22/2021	0.00065 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 07/08/2021	0.00084 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 07/12/2021	0.00078 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 07/20/2021	0.00075 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 07/28/2021	0.00073 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 08/03/2021	0.00041 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 08/12/2021	0.00071 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 08/18/2021	0.00050 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 08/24/2021	0.00070 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 08/31/2021	0.00067 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 09/07/2021	0.00075 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 09/15/2021	0.00086 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 09/22/2021	0.00080 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 10/01/2021	0.00080 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
* 10/04/2021	0.00045 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 10/13/2021	0.00065 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 10/22/2021	0.00062 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 11/01/2021	0.00050 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 11/10/2021	0.00065 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 11/18/2021	0.00051 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 11/24/2021	0.00068 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 11/29/2021	0.00073 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 12/07/2021	0.00073 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 12/16/2021	0.00087 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 12/23/2021	0.00086 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 12/31/2021	0.00093 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined

# samples:	48	min:	0.00041 mg/L
# detects:	48	max:	0.00111 mg/L
# non-detects:	0	avg:	0.00078 mg/L (based on 48 numerical results)
# of Exceedences:	48		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 01/07/2021	0.00074 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 01/13/2021	0.00069 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 01/20/2021	0.00086 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 01/27/2021	0.00088 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 02/08/2021	0.00078 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 02/18/2021	0.00092 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 02/24/2021	0.00068 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/02/2021	0.00073 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/12/2021	0.00070 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/16/2021	0.00062 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/23/2021	0.00076 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/31/2021	0.00074 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 04/08/2021	0.00065 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 04/15/2021	0.00065 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 04/21/2021	0.00078 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 04/27/2021	0.00075 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 05/06/2021	0.00041 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 05/11/2021	0.00095 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 05/26/2021	0.00083 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 06/15/2021	0.00078 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 06/21/2021	0.00032 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 07/08/2021	0.00086 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 07/23/2021	0.00068 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 08/12/2021	0.00069 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 08/18/2021	0.00072 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 08/27/2021	0.00058 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 09/01/2021	0.00061 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 09/15/2021	0.00078 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 09/23/2021	0.00067 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 10/01/2021	0.00065 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 10/06/2021	0.00074 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 10/14/2021	0.00050 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 10/22/2021	0.00065 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 11/03/2021 0.00047 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 11/09/2021 0.00035 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 11/18/2021 0.00055 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 11/24/2021 0.00040 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 11/30/2021 0.00058 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 12/14/2021 0.00101 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 12/22/2021 0.00069 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined

# samples:	40	min:	0.00032 mg/L
# detects:	40	max:	0.00101 mg/L
# non-detects:	0	avg:	0.00069 mg/L (based on 40 numerical results)
# of Exceedences:	40		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/05/2021 0.00050 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 01/11/2021 0.00048 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 01/18/2021 0.00045 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 01/27/2021 0.00054 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 02/09/2021 0.00044 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 02/17/2021 0.00058 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 02/24/2021 0.00058 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 03/02/2021 0.00062 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 03/12/2021 0.00065 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 03/15/2021 0.00056 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 03/23/2021 0.00065 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 03/30/2021 0.00065 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 04/07/2021 0.00052 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 04/13/2021 0.00061 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 04/20/2021 0.00056 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 04/26/2021 0.00070 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 05/06/2021 0.00061 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 05/11/2021 0.00050 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
05/26/2021 0.59 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 06/14/2021 0.00059 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 06/22/2021	0.00066 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 07/08/2021	0.00068 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 07/12/2021	0.00062 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 07/19/2021	0.00050 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 07/28/2021	0.00052 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 08/06/2021	0.00043 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 08/12/2021	0.00043 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 08/16/2021	0.00065 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 08/24/2021	0.00037 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 09/01/2021	0.00049 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 09/07/2021	0.00047 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 09/14/2021	0.00059 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 09/20/2021	0.00037 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 09/27/2021	0.00036 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 10/05/2021	0.00024 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 10/12/2021	0.00032 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
* 10/19/2021	0.00043 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
11/03/2021	0.44 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
11/09/2021	0.31 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
11/16/2021	0.34 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
11/25/2021	0.49 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
11/30/2021	0.43 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
12/09/2021	0.51 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
12/13/2021	0.67 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
12/21/2021	0.64 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined

# samples:	45	min:	0.00024 mg/L
# detects:	45	max:	0.67 mg/L
# non-detects:	0	avg:	0.09864 mg/L (based on 45 numerical results)
# of Exceedences:	36		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 01/07/2021	0.00070 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 01/11/2021	0.00035 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 01/20/2021	0.00118 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 01/27/2021	0.00115 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 02/08/2021	0.00103 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 02/18/2021	0.00096 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 02/23/2021	0.00096 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/02/2021	0.00080 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/12/2021	0.00078 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/16/2021	0.00093 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/23/2021	0.00078 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/31/2021	0.00082 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 04/08/2021	0.00096 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 04/12/2021	0.00093 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 04/21/2021	0.00048 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 04/27/2021	0.00072 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 05/06/2021	0.00091 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 05/11/2021	0.00097 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 05/17/2021	0.00095 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 05/26/2021	0.00081 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 06/15/2021	0.00085 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 06/21/2021	0.00091 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 07/08/2021	0.00091 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 07/12/2021	0.00072 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 07/21/2021	0.00043 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 07/28/2021	0.00055 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 08/06/2021	0.00036 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 08/09/2021	0.00024 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 08/18/2021	0.00039 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 08/24/2021	0.00087 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 09/02/2021	0.00068 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 09/07/2021	0.00083 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 09/13/2021	0.00081 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 09/15/2021	0.00085 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 09/21/2021	0.00073 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 09/29/2021	0.00069 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 10/06/2021	0.00075 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 10/12/2021	0.00059 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 10/22/2021	0.00055 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 11/02/2021	0.00072 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 11/08/2021	0.00079 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 11/18/2021	0.00083 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 11/25/2021	0.00101 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 11/30/2021	0.00081 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 12/06/2021	0.00094 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 12/17/2021	0.00080 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 12/23/2021 0.00090 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 12/31/2021 0.00061 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined

# samples:	48	min:	0.00024 mg/L
# detects:	48	max:	0.00118 mg/L
# non-detects:	0	avg:	0.00078 mg/L (based on 48 numerical results)
# of Exceedences:	48		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/05/2021 0.00070 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 01/11/2021 0.00080 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 01/20/2021 0.00086 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 01/27/2021 0.00090 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 02/01/2021 0.00097 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 02/09/2021 0.00088 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 02/17/2021 0.00074 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 02/24/2021 0.00087 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 03/01/2021 0.00083 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 03/12/2021 0.00069 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 03/16/2021 0.00074 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 03/23/2021 0.00081 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 03/30/2021 0.00078 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 04/07/2021 0.00075 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 04/13/2021 0.00082 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 04/21/2021 0.00069 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 04/26/2021 0.00073 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 05/04/2021 0.00071 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 05/11/2021 0.00059 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 05/19/2021 0.00084 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 05/25/2021 0.00082 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 06/15/2021 0.00080 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 06/21/2021 0.00084 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 07/08/2021 0.00106 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 07/12/2021 0.00073 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 07/21/2021 0.00070 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 07/28/2021 0.00072 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 08/03/2021 0.00040 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 08/10/2021 0.00060 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 08/17/2021	0.00058 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 08/24/2021	0.00070 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 09/01/2021	0.00069 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 09/07/2021	0.00076 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 09/15/2021	0.00080 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 09/21/2021	0.00068 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 09/27/2021	0.00071 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 10/04/2021	0.00052 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 10/12/2021	0.00066 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 10/22/2021	0.00056 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 11/01/2021	0.00079 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 11/09/2021	0.00072 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 11/16/2021	0.0007 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 11/25/2021	0.00077 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 11/29/2021	0.00063 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 12/09/2021	0.00110 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 12/16/2021	0.00072 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
* 12/20/2021	0.00066 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined

# samples:	47	min:	0.00040 mg/L
# detects:	47	max:	0.00110 mg/L
# non-detects:	0	avg:	0.00075 mg/L (based on 47 numerical results)
# of Exceedences:	47		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.82 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
01/11/2021	0.98 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
01/20/2021	1.12 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
01/27/2021	1.12 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
02/01/2021	0.99 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
02/08/2021	0.96 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
02/18/2021	1.03 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
02/24/2021	0.93 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
03/01/2021	0.86 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
03/12/2021	0.80 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
03/16/2021	0.85 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
03/23/2021	0.93 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
03/30/2021	0.88 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
04/07/2021	0.87 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
04/15/2021	0.98 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
04/21/2021	0.73 mg/L	Total Cl2	Crofton Auto Service
04/26/2021	0.78 mg/L	Total Cl2	Crofton Auto Service
05/04/2021	0.90 mg/L	Total Cl2	Crofton Auto Service
05/11/2021	1.01 mg/L	Total Cl2	Crofton Auto Service
05/18/2021	1.04 mg/L	Total Cl2	Crofton Auto Service
05/26/2021	0.91 mg/L	Total Cl2	Crofton Auto Service
06/15/2021	0.89 mg/L	Total Cl2	Crofton Auto Service
06/22/2021	0.66 mg/L	Total Cl2	Crofton Auto Service
07/08/2021	0.87 mg/L	Total Cl2	Crofton Auto Service
07/12/2021	0.76 mg/L	Total Cl2	Crofton Auto Service
07/20/2021	0.78 mg/L	Total Cl2	Crofton Auto Service
07/28/2021	0.76 mg/L	Total Cl2	Crofton Auto Service
08/03/2021	0.47 mg/L	Total Cl2	Crofton Auto Service
08/12/2021	0.76 mg/L	Total Cl2	Crofton Auto Service
08/18/2021	0.61 mg/L	Total Cl2	Crofton Auto Service
08/24/2021	0.86 mg/L	Total Cl2	Crofton Auto Service
08/31/2021	0.74 mg/L	Total Cl2	Crofton Auto Service
09/07/2021	0.72 mg/L	Total Cl2	Crofton Auto Service
09/15/2021	0.89 mg/L	Total Cl2	Crofton Auto Service
09/22/2021	0.63 mg/L	Total Cl2	Crofton Auto Service
10/01/2021	0.80 mg/L	Total Cl2	Crofton Auto Service
10/04/2021	0.66 mg/L	Total Cl2	Crofton Auto Service
10/13/2021	0.82 mg/L	Total Cl2	Crofton Auto Service
10/22/2021	0.71 mg/L	Total Cl2	Crofton Auto Service
11/01/2021	0.60 mg/L	Total Cl2	Crofton Auto Service
11/10/2021	0.81 mg/L	Total Cl2	Crofton Auto Service
11/18/2021	0.56 mg/L	Total Cl2	Crofton Auto Service
11/24/2021	0.81 mg/L	Total Cl2	Crofton Auto Service
11/29/2021	0.85 mg/L	Total Cl2	Crofton Auto Service
12/07/2021	0.84 mg/L	Total Cl2	Crofton Auto Service
12/16/2021	0.94 mg/L	Total Cl2	Crofton Auto Service
12/23/2021	0.94 mg/L	Total Cl2	Crofton Auto Service
12/31/2021	1.02 mg/L	Total Cl2	Crofton Auto Service

# samples:	48	min:	0.47 mg/L
# detects:	48	max:	1.12 mg/L
# non-detects:	0	avg:	0.84 mg/L (based on 48 numerical results)
# of Exceedences:	0		



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.71 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
01/11/2021	0.85 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
01/20/2021	1.05 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
01/27/2021	0.92 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/01/2021	1.07 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/09/2021	0.77 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/17/2021	0.84 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/24/2021	0.91 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/01/2021	0.84 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/12/2021	0.86 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/16/2021	0.70 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/23/2021	0.89 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/30/2021	0.90 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/07/2021	0.86 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/13/2021	0.87 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/21/2021	0.70 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/26/2021	0.77 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/04/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/11/2021	0.80 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/19/2021	0.78 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/25/2021	0.83 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
06/15/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
06/21/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/08/2021	0.98 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/12/2021	0.68 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/21/2021	0.77 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/28/2021	0.73 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/03/2021	0.57 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/10/2021	0.67 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/17/2021	0.72 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/24/2021	0.77 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/01/2021	0.82 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/07/2021	0.77 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/15/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/21/2021	0.70 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/27/2021	0.66 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/04/2021	0.54 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/12/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/22/2021	0.57 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
11/01/2021	0.86 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/09/2021	0.74 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/16/2021	0.82 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/25/2021	0.94 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/29/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
12/09/2021	0.90 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
12/16/2021	0.81 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
12/20/2021	0.84 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined

# samples:	47	min:	0.54 mg/L
# detects:	47	max:	1.07 mg/L
# non-detects:	0	avg:	0.80 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/07/2021	0.82 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
01/11/2021	0.38 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
01/20/2021	1.21 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
01/27/2021	1.16 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
02/08/2021	0.97 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
02/18/2021	1.05 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
02/23/2021	0.97 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
03/02/2021	0.94 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
03/12/2021	0.92 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
03/16/2021	0.89 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
03/23/2021	0.80 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
03/31/2021	0.95 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
04/08/2021	0.91 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
04/12/2021	1.03 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
04/21/2021	0.52 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
04/27/2021	0.78 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
05/06/2021	0.94 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
05/11/2021	1.01 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
05/17/2021	0.99 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
05/26/2021	0.88 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
06/15/2021	0.87 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
06/21/2021	0.87 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
07/08/2021	0.91 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
07/12/2021	0.74 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
07/21/2021	0.49 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
07/28/2021	0.57 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
08/06/2021	0.41 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
08/09/2021	0.26 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
08/18/2021	0.52 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
08/24/2021	0.89 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
09/02/2021	0.77 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
09/07/2021	0.84 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
09/13/2021	0.85 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
09/15/2021	0.87 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
09/21/2021	0.88 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
09/29/2021	0.83 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
10/06/2021	0.79 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
10/12/2021	0.72 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
10/22/2021	0.61 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
11/02/2021	0.83 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
11/08/2021	0.82 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
11/18/2021	0.84 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
11/25/2021	1.02 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
11/30/2021	0.83 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
12/06/2021	1.04 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
12/17/2021	0.96 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
12/23/2021	1.01 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
12/31/2021	0.76 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined

# samples:	48	min:	0.26 mg/L
# detects:	48	max:	1.21 mg/L
# non-detects:	0	avg:	0.83 mg/L (based on 48 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.53 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
01/11/2021	0.57 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
01/18/2021	0.58 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
01/27/2021	0.55 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
02/09/2021	0.51 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
02/17/2021	0.65 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
02/24/2021	0.65 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
03/02/2021	0.64 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
03/12/2021	0.68 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
03/15/2021	0.67 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
03/23/2021	0.58 mg/L	Total Cl2	1414 Tatlo
03/30/2021	0.58 mg/L	Total Cl2	1414 Tatlo
04/07/2021	0.65 mg/L	Total Cl2	1414 Tatlo
04/13/2021	0.71 mg/L	Total Cl2	1414 Tatlo
04/20/2021	0.51 mg/L	Total Cl2	1414 Tatlo
04/26/2021	0.62 mg/L	Total Cl2	1414 Tatlo
05/06/2021	0.67 mg/L	Total Cl2	1414 Tatlo
05/11/2021	0.55 mg/L	Total Cl2	1414 Tatlo
05/26/2021	0.55 mg/L	Total Cl2	1414 Tatlo
06/14/2021	0.55 mg/L	Total Cl2	1414 Tatlo
06/22/2021	0.65 mg/L	Total Cl2	1414 Tatlo
07/08/2021	0.64 mg/L	Total Cl2	1414 Tatlo
07/12/2021	0.56 mg/L	Total Cl2	1414 Tatlo
07/19/2021	0.55 mg/L	Total Cl2	1414 Tatlo
07/28/2021	0.58 mg/L	Total Cl2	1414 Tatlo
08/06/2021	0.59 mg/L	Total Cl2	1414 Tatlo
08/12/2021	0.47 mg/L	Total Cl2	1414 Tatlo
08/16/2021	0.61 mg/L	Total Cl2	1414 Tatlo
08/24/2021	0.51 mg/L	Total Cl2	1414 Tatlo
09/01/2021	0.51 mg/L	Total Cl2	1414 Tatlo
09/07/2021	0.47 mg/L	Total Cl2	1414 Tatlo
09/14/2021	0.55 mg/L	Total Cl2	1414 Tatlo
09/20/2021	0.38 mg/L	Total Cl2	1414 Tatlo
09/27/2021	0.38 mg/L	Total Cl2	1414 Tatlo
10/05/2021	0.36 mg/L	Total Cl2	1414 Tatlo
10/12/2021	0.40 mg/L	Total Cl2	1414 Tatlo
10/19/2021	0.46 mg/L	Total Cl2	1414 Tatlo
11/03/2021	0.47 mg/L	Total Cl2	1414 Tatlo
11/09/2021	0.41 mg/L	Total Cl2	1414 Tatlo
11/16/2021	0.39 mg/L	Total Cl2	1414 Tatlo
11/25/2021	0.51 mg/L	Total Cl2	1414 Tatlo
11/30/2021	0.44 mg/L	Total Cl2	1414 Tatlo
12/09/2021	0.57 mg/L	Total Cl2	1414 Tatlo
12/13/2021	0.78 mg/L	Total Cl2	1414 Tatlo
12/21/2021	0.60 mg/L	Total Cl2	1414 Tatlo

# samples:	45	min:	0.36 mg/L
# detects:	45	max:	0.78 mg/L
# non-detects:	0	avg:	0.55 mg/L (based on 45 numerical results)
# of Exceedences:	0		



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/07/2021	0.85 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
01/13/2021	0.71 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
01/20/2021	0.87 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
01/27/2021	1.02 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
02/08/2021	0.86 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
02/18/2021	0.92 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
02/24/2021	0.87 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/02/2021	0.79 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/12/2021	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/16/2021	0.60 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/23/2021	0.79 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/31/2021	0.78 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
04/08/2021	0.75 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
04/15/2021	0.73 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
04/21/2021	0.78 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
04/27/2021	0.87 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/06/2021	0.41 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/11/2021	1.03 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/26/2021	0.85 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/15/2021	0.79 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/21/2021	0.34 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
07/08/2021	0.92 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/23/2021	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/12/2021	0.84 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/18/2021	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/27/2021	0.61 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/01/2021	0.70 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/15/2021	0.79 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/23/2021	0.64 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/01/2021	0.75 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/06/2021	0.64 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/14/2021	0.54 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/22/2021	0.68 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/03/2021	0.60 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/09/2021	0.51 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/18/2021	0.50 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/24/2021	0.32 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/30/2021	0.59 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
12/14/2021	0.9 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
12/22/2021	0.81 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined

# samples:	40	min:	0.32 mg/L
# detects:	40	max:	1.03 mg/L
# non-detects:	0	avg:	0.73 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* **Indicates Criteria is exceeded**