

November 5, 2021

File: 5630-55

Environmental Health Officer  
Central Vancouver Island Health Region  
1665 Grant Avenue  
NANAIMO BC V9S 5K7

**Re: South End Water System Water Quality Report  
Premises Number 1310818  
Report for the Period Jan 1/20 to Dec 31/20**

Please find the Municipality of North Cowichan's Water quality report for the South-end Water System attached.

Sincerely

Clay Reitsma, M. Eng., P. Eng  
Senior Manager, Engineering

[clay.reitsma@northcowichan.ca](mailto:clay.reitsma@northcowichan.ca)



## 1 Operator Information

Contact Name Clay Reitsma, M.Eng. , P.Eng.  
Phone 250-746-3100  
Email [clay.reitsma@northcowichan.ca](mailto:clay.reitsma@northcowichan.ca)

## 2 System Description

This is a groundwater supply. Water is pumped from the Boys Road wells. In 2018, Vancouver Island Health Authority amended the operating certificate for the South End Water System and the Municipality is now required to Chlorinate continuously to reduce bacterial growth in the distribution system. In December of 2019 a new sodium hypochlorite injection system was installed to replace the existing calcium hypochlorite system.

## 3 Boil Advisories

None.

## 4 Future Improvements

A UV disinfection system has been installed and has been operating since June of 2013.

## 5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

Sincerely



Clay Reitsma, M.Eng., P.Eng.  
Senior Manager, Engineering  
cc: Robert Bell – Utilities, Manager

## 6 Results

N/A

Report Name: South End Water Quality Report

Report Subtitle: South End Water Quality Report

	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd - Well 1	Boys Rd - Well 3	Boys Rd - Well 5	Boys Rd PS
January 2020	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Turbidity (NTU)	Turbidity (NTU)	Turbidity (NTU)	Flow (Volumetric Rate) (m³/d)
1								4,785
2								5,278
3								6,645
4								5,189
5								4,788
6		0.45						4,702
7			0.29					5,001
8	0.42				0.11			5,207
9								4,626
10								4,452
11								4,996
12								5,505
13			0.9	0.6				8,216
14	0.54	0.51						5,435
15								5,047
16								5,088
17								4,654
18								4,899
19								5,111
20		0.44	0.35	0.23				4,803
21	0.49					0.098		4,642
22								4,901
23								4,813
24								4,829
25								4,829
26								4,705
27			0.29	0.26				4,807
28								4,622
29	0.44	0.50					0.11	4,938
30								4,727
31								4,709
<b>Average</b>	0.47	0.48	0.46	0.36	0.11	0.098	0.11	5,063
<b>Minimum</b>	0.42	0.44	0.29	0.23	0.11	0.098	0.11	4,452
<b>Maximum</b>	0.54	0.51	0.9	0.6	0.11	0.098	0.11	8,216
<b>Count</b>	4	4	4	3	1	1	1	31
<b>Total</b>								156,949
<b>95 Percentile Exceedences</b>	0	0	0	0	0.11	0.098	0.11	0
<b>Median</b>	0.47	0.48	0.32	0.26	0.11	0.098	0.11	4,829

February 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								4,843
2								4,783
3		0.47			0.12			4,892
4								4,871
5	0.46		0.32	0.25				4,679
6								4,703
7								4,717
8								4,850
9								4,905
10		0.38	0.35	0.29				4,743
11								4,751
12	0.52							4,880
13								4,737
14								4,628
15								4,899
16								4,819
17								4,739
18				0.34				4,831
19		0.36	0.32				0.09	4,706
20	0.45							4,692
21								4,600
22								4,633
23								4,748
24	0.45	0.34	0.24	0.36		0.09		4,730
25								4,569
26								4,790
27								5,206
28								6,591
29								6,266

Average	0.47	0.39	0.31	0.31	0.12	0.09	0.09	4,890
Minimum	0.45	0.34	0.24	0.25	0.12	0.09	0.09	4,569
Maximum	0.52	0.47	0.35	0.36	0.12	0.09	0.09	6,591
Count	4	4	4	4	1	1	1	29
Total								141,801
95 Percentile Exceedences	0	0	0	0	0.12	0.09	0.09	0
Median	0.46	0.37	0.32	0.32	0.12	0.09	0.09	4,751

March 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m <sup>3</sup> /d)
1								6,146
2		0.41	0.36	0.38	0.09			6,788
3	0.46							5,283
4								4,987
5								4,874
6								4,727
7								4,756
8								4,796
9	0.41		0.38	0.34				5,091
10		0.39						4,781
11								4,876
12								4,691
13								4,851
14								4,865
15								5,046
16								5,142
17			0.47			0.12		5,047
18	0.42	0.42		0.26				5,059
19								5,281
20								5,543
21								5,257
22								5,235
23	0.39		0.41	0.31				5,182
24								5,258
25		0.57					0.06	5,318
26								4,855
27								4,950
28								5,023
29								5,213
30								5,466
31								4,906

<b>Average</b>	0.42	0.45	0.41	0.32	0.09	0.12	0.06	5,138
<b>Minimum</b>	0.39	0.39	0.36	0.26	0.09	0.12	0.06	4,691
<b>Maximum</b>	0.46	0.57	0.47	0.38	0.09	0.12	0.06	6,788
<b>Count</b>	4	4	4	4	1	1	1	31
<b>Total</b>								159,293
<b>95 Percentile</b>					0.09	0.12	0.06	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.42	0.42	0.40	0.33	0.09	0.12	0.06	5,047

April 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m <sup>3</sup> /d)
1								5,325
2								5,435
3								5,440
4								5,298
5								5,325
6		0.45	0.56	0.39				5,481
7	0.65				0.05			5,975
8								5,806
9								5,897
10								6,267
11								6,454
12		0.31	0.35	0.20				6,610
13	0.37							7,242
14								7,450
15								7,494
16								8,043
17								7,227
18								7,549
19								8,052
20	0.53		0.60	0.40				7,949
21		0.41						7,304
22								6,798
23								6,782
24								6,808
25								5,911
26								6,654
27		0.23	0.32	0.32				6,596
28	0.46						0.01	6,830
29								6,764
30								6,695
<b>Average</b>	0.50	0.35	0.46	0.33	0.05		0.01	6,582
<b>Minimum</b>	0.37	0.23	0.32	0.20	0.05		0.01	5,298
<b>Maximum</b>	0.65	0.45	0.60	0.40	0.05		0.01	8,052
<b>Count</b>	4	4	4	4	1	0	1	30
<b>Total</b>								197,461
<b>95 Percentile</b>					0.05		0.01	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.50	0.36	0.46	0.36	0.05		0.01	6,675

May 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m <sup>3</sup> /d)
1								6,886
2								6,057
3								6,541
4		0.43	0.49	0.88	0.05			6,762
5	0.25							6,974
6								7,808
7								8,386
8								9,319
9								10,140
10								9,519
11	0.73							8,194
12		0.54	0.60	0.40				6,945
13								6,857
14								6,499
15								7,012
16								6,207
17								6,442
18								6,957
19		0.47	0.54	0.25				7,271
20								7,368
21	0.44					0.03		7,129
22								6,887
23								7,601
24								7,381
25								7,054
26			0.54	0.42			0.07	7,570
27	0.47	0.50						8,661
28								8,977
29								8,979
30								7,813
31								8,204

<b>Average</b>	0.47	0.49	0.54	0.49	0.05	0.03	0.07	7,561
<b>Minimum</b>	0.25	0.43	0.49	0.25	0.05	0.03	0.07	6,057
<b>Maximum</b>	0.73	0.54	0.60	0.88	0.05	0.03	0.07	10,140
<b>Count</b>	4	4	4	4	1	1	1	31
<b>Total</b>								234,400
<b>95 Percentile</b>					0.05	0.03	0.07	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.46	0.49	0.54	0.41	0.05	0.03	0.07	7,271

June 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m <sup>3</sup> /d)
1		0.27	0.40	0.34	0.03			8,550
2								7,891
3	0.24							8,292
4								7,744
5								7,778
6								7,984
7								8,212
8	0.32							8,179
9		0.51	0.36	0.32				7,082
10								6,821
11								6,909
12								6,545
13								6,648
14								6,522
15			0.43	0.28				6,724
16	0.35	0.36				0.05		7,175
17								8,229
18								8,779
19								8,228
20								7,497
21								8,373
22			0.37	0.33				9,150
23		0.47						9,190
24								9,469
25	0.28						0.04	10,336
26								9,669
27								9,504
28								9,759
29	0.19	0.40						10,578
30			0.37	0.27				10,097
<b>Average</b>	0.28	0.40	0.39	0.31	0.03	0.05	0.04	8,264
<b>Minimum</b>	0.19	0.27	0.36	0.27	0.03	0.05	0.04	6,522
<b>Maximum</b>	0.35	0.51	0.43	0.34	0.03	0.05	0.04	10,578
<b>Count</b>	5	5	5	5	1	1	1	30
<b>Total</b>								247,914
<b>95 Percentile</b>					0.03	0.05	0.04	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.28	0.40	0.37	0.32	0.03	0.05	0.04	8,220



July 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m <sup>3</sup> /d)
1								9,668
2								9,466
3								7,829
4								7,507
5								8,765
6		0.39						9,526
7	0.41		0.31	0.33	0.04			9,222
8								9,131
9								8,794
10								9,429
11								9,038
12								9,931
13								11,078
14	0.43	0.49	0.33	0.25				12,003
15								12,293
16								11,785
17								11,973
18								12,288
19								12,779
20								13,478
21		0.41	0.24	0.22		0.03		12,926
22								12,569
23	0.34							13,079
24								12,579
25								13,325
26								13,771
27	0.25			0.26			0.02	13,759
28			0.22					13,796
29		0.28						14,014
30								14,015
31								13,161

<b>Average</b>	0.36	0.39	0.28	0.27	0.04	0.03	0.02	11,386
<b>Minimum</b>	0.25	0.28	0.22	0.22	0.04	0.03	0.02	7,507
<b>Maximum</b>	0.43	0.49	0.33	0.33	0.04	0.03	0.02	14,015
<b>Count</b>	4	4	4	4	1	1	1	31
<b>Total</b>								352,977
<b>95 Percentile</b>					0.04	0.03	0.02	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.38	0.40	0.28	0.26	0.04	0.03	0.02	12,003

August 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								13,711
2								13,343
3								13,506
4		0.42	0.38	0.36	0.07			13,588
5	0.29							13,310
6								11,454
7								10,481
8								10,112
9								11,921
10		0.23						12,552
11								12,516
12	0.33							12,556
13			0.35	0.42				13,078
14								12,916
15								13,357
16								13,918
17			0.27	0.37		0.07		13,606
18		0.30						12,764
19	0.30							11,546
20								9,729
21								9,302
22								9,433
23								10,002
24			0.27	0.32				10,754
25	0.27							11,204
26		0.29					0.08	11,630
27								11,783
28								10,846
29								11,047
30								10,620
31	0.30							9,662

<b>Average</b>	0.30	0.31	0.32	0.37	0.07	0.07	0.08	11,814
<b>Minimum</b>	0.27	0.23	0.27	0.32	0.07	0.07	0.08	9,302
<b>Maximum</b>	0.33	0.42	0.38	0.42	0.07	0.07	0.08	13,918
<b>Count</b>	5	4	4	4	1	1	1	31
<b>Total</b>								366,247
<b>95 Percentile</b>					0.07	0.07	0.08	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.30	0.30	0.31	0.37	0.07	0.07	0.08	11,783

September 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m <sup>3</sup> /d)
1		0.23	0.44	0.27	0.07			10,584
2								10,993
3								11,355
4								11,424
5								11,390
6								11,232
7								11,669
8	0.41							11,830
9		0.38	0.41	0.42				12,514
10								12,133
11								11,152
12								9,943
13								10,012
14	0.44		0.53	0.29				9,391
15		0.44						9,036
16								8,827
17						0.08		8,503
18								7,894
19								8,591
20								8,617
21	0.38		0.32	0.28				8,187
22								7,403
23		0.27					0.08	7,091
24								6,806
25								6,434
26								6,532
27								6,601
28								6,701
29	0.44		0.28	0.25				7,048
30		0.32						7,152
<b>Average</b>	0.42	0.33	0.40	0.30	0.07	0.08	0.08	9,235
<b>Minimum</b>	0.38	0.23	0.28	0.25	0.07	0.08	0.08	6,434
<b>Maximum</b>	0.44	0.44	0.53	0.42	0.07	0.08	0.08	12,514
<b>Count</b>	4	5	5	5	1	1	1	30
<b>Total</b>								277,045
<b>95 Percentile</b>					0.07	0.08	0.08	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.43	0.32	0.41	0.28	0.07	0.08	0.08	8,932

October 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								7,187
2								6,987
3								7,116
4								6,922
5		0.59	0.40	0.32	0.08			7,088
6	0.30							6,848
7								6,723
8								6,584
9								6,232
10								6,375
11								6,443
12								6,575
13								6,696
14	0.38	0.33	0.35	0.27				6,710
15								6,753
16								6,958
17								6,958
18								6,861
19	0.32	0.31	0.35	0.25		0.09		7,001
20								6,952
21								6,874
22								6,796
23								6,718
24								6,640
25								6,561
26			0.34	0.18			0.08	6,483
27	0.23	0.38						6,405
28								6,327
29								6,159
30								5,647
31								

<b>Average</b>	0.31	0.40	0.36	0.26	0.08	0.09	0.08	6,686
<b>Minimum</b>	0.23	0.31	0.34	0.18	0.08	0.09	0.08	5,647
<b>Maximum</b>	0.38	0.59	0.40	0.32	0.08	0.09	0.08	7,187
<b>Count</b>	4	4	4	4	1	1	1	30
<b>Total</b>								200,579
<b>95 Percentile</b>					0.08	0.09	0.08	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.31	0.36	0.35	0.26	0.08	0.09	0.08	6,721

November 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								5,536
2		0.43	0.52	0.23	0.07			5,534
3	0.36							5,384
4								5,350
5								5,485
6								5,561
7								5,565
8								5,580
9	0.47		0.21	0.23				5,614
10		0.26						5,265
11								5,632
12								5,637
13								5,277
14								5,119
15								5,822
16		0.22		0.17		0.08		5,458
17	0.20		0.38					5,496
18								5,651
19								5,318
20								5,473
21								5,402
22								5,446
23	0.45		0.46	0.18			0.26	5,535
24		0.40						5,259
25								5,380
26								5,236
27								5,135
28								5,492
29								5,493
30	0.38	0.47	0.39	0.27				5,517
<b>Average</b>	0.37	0.36	0.39	0.22	0.07	0.08	0.26	5,455
<b>Minimum</b>	0.20	0.22	0.21	0.17	0.07	0.08	0.26	5,119
<b>Maximum</b>	0.47	0.47	0.52	0.27	0.07	0.08	0.26	5,822
<b>Count</b>	5	5	5	5	1	1	1	30
<b>Total</b>								163,652
<b>95 Percentile</b>					0.07	0.08	0.26	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.38	0.40	0.39	0.23	0.07	0.08	0.26	5,489

December 2020	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1					0.12			5,524
2								5,307
3								5,142
4								5,190
5								5,366
6								5,817
7	0.53	0.38						5,546
8			0.46	0.27			0.13	5,381
9								5,534
10								5,864
11								5,284
12								4,474
13								5,599
14	0.50							6,298
15		0.40	0.43	0.24		0.01		5,828
16								5,484
17								5,240
18								5,123
19								5,434
20								5,724
21			0.35					5,122
22		0.39						5,317
23	0.43							5,713
24								5,592
25								5,602
26								5,380
27								5,635
28								5,490
29			0.46	0.24				5,800
30								5,483
31	0.47	0.45						5,627

<b>Average</b>	0.48	0.41	0.43	0.25	0.12	0.01	0.13	5,481
<b>Minimum</b>	0.43	0.38	0.35	0.24	0.12	0.01	0.13	4,474
<b>Maximum</b>	0.53	0.45	0.46	0.27	0.12	0.01	0.13	6,298
<b>Count</b>	4	4	4	3	1	1	1	31
<b>Total</b>								169,920
<b>95 Percentile</b>					0.12	0.01	0.13	
<b>Exceedences</b>	0	0	0	0	0	0	0	0
<b>Median</b>	0.49	0.40	0.45	0.24	0.12	0.01	0.13	5,490

\* indicates Geometric Mean  
\*\* indicates Intraday Average

Report Name: E.Coli and Total Coliforms

Water System	Facility	Sampling Point	Collection Date	Escherichia coli / E. coli (Count)	Total Coliforms (count)
				Escherichia coli / E. coli (counts)	Total Coliforms (counts)
				Laboratory Report counts/100ml	Laboratory Report counts/100ml
South End Drinking Water	Facility 1	1820 Herd Road	01/20/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	02/24/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	03/16/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	04/20/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	05/19/2020	0	11
South End Drinking Water	Facility 1	1820 Herd Road	06/15/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	07/21/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	08/17/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	09/14/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	10/19/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	11/16/2020	0	0
South End Drinking Water	Facility 1	1820 Herd Road	12/15/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	01/06/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	02/03/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	03/02/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	04/06/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	05/04/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	06/01/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	07/06/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	08/04/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	09/01/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	10/05/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	11/02/2020	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	12/01/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	01/13/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	02/10/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	03/09/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	04/15/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	05/11/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	06/08/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	07/13/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	09/08/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	10/13/2020	0	0

## E.Coli and Total Coliforms

## South End Drinking Water

01 January 2020 - 31 December 2020

South End Drinking Water	Facility 1	Lakeview Reservoir	11/09/2020	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	12/07/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	01/27/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	02/18/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	03/23/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	04/27/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	05/26/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	06/22/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	07/27/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	08/24/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	09/21/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	10/26/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	12/08/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	01/27/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	02/18/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	03/23/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	04/27/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	05/26/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	06/22/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	07/27/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	08/24/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	09/21/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	10/26/2020	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	12/07/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	01/20/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	02/24/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	03/16/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	04/20/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	05/19/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	06/15/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	07/21/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	08/17/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	09/14/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	10/19/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	11/16/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	12/15/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	01/27/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	02/18/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	03/23/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	04/27/2020	0	0



## E.Coli and Total Coliforms

## South End Drinking Water

01 January 2020 - 31 December 2020

South End Drinking Water	Facility 1	Maple Mtn Reservoir	05/26/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	06/22/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	07/27/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	08/24/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	09/21/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	10/26/2020	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	12/08/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	01/13/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	02/10/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	03/09/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	04/15/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	05/11/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	06/08/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	07/13/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	09/08/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	10/13/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	11/09/2020	0	0
South End Drinking Water	Facility 1	Municipal Hall	12/07/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	01/13/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	02/10/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	03/09/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	04/15/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	05/11/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	06/08/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	07/13/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	09/08/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	10/13/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	11/09/2020	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	12/07/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	01/27/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	02/18/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	03/23/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	04/27/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	05/26/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	06/22/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	07/27/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	08/24/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	09/21/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	10/26/2020	0	0
South End Drinking Water	Facility 1	Properties Reservoir	12/08/2020	0	0

01 January 2020 - 31 December 2020

E.Coli and Total Coliforms

South End Drinking Water

South End Drinking Water	Facility 1	Properties Water Pump Station	01/06/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	02/03/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	03/02/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	04/06/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	05/04/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	06/01/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	07/06/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	08/04/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	09/01/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	10/05/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	11/02/2020	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	12/01/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	01/13/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	02/10/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	03/09/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	04/15/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	05/11/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	06/08/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	07/13/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	09/08/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	10/13/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	11/09/2020	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	12/07/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	01/13/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	02/10/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	03/09/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	05/19/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	06/08/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	07/13/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	08/18/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	09/14/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	10/20/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	11/09/2020	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	12/07/2020	0	0

\* indicates Geometric Mean

\*\* indicates Intraday Average

**Facility:** Facility 1  
**Sampling Point:** Properties Water Pump Station (1-3-EP, 3B107)

Total Chloramines (as combined chlorine)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:00 < 0.0400 mg/L	Properties Water Pump Station	Total Chloramines (as combined chlorine)	<=3.0 MAC

<b># samples:</b>	1	<b>min:</b>	< 0.0400 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0400 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

**Facility:** Water - Raw; Water - Raw  
**Sampling Point:** Boys Rd - Well 1 (3-2-SR, 3B169)

Aluminum(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40 < 0.0050 mg/L	Boys Rd - Well 1	Aluminum	<=0.2 Secondary Standard

<b># samples:</b>	1	<b>min:</b>	< 0.0050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

Antimony (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40 < 0.00020 mg/L	Boys Rd - Well 1	Antimony (total)	<=0.006 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

Arsenic (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40 < 0.00050 mg/L	Boys Rd - Well 1	Arsenic (total)	<=0.010 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Barium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.0050 mg/L	Boys Rd - Well 1	Barium (total)	<=2	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0050 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.0050 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Beryllium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.00010 mg/L	Boys Rd - Well 1	Beryllium (total)	<=0.004	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00010 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.00010 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Bismuth (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.10 ug/L	Boys Rd - Well 1	Bismuth (total)		

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L		
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Boron (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	0.0100 mg/L	Boys Rd - Well 1	Boron (total)	<=5	MAC

<b># samples:</b>	1	<b>min:</b>	0.0100 mg/L		
<b># detects:</b>	1	<b>max:</b>	0.0100 mg/L		
<b># non-detects:</b>	0	<b>avg:</b>	0.0100 mg/L (based on 1 numerical results)		
<b># of Exceedences:</b>	0				

<b>Bromate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.01 mg/L	Boys Rd - Well 1	Bromate	<=0.01	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.01 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.01 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Cadmium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.000010 mg/L	Boys Rd - Well 1	Cadmium (total)	<=0.005	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Calcium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40	6,900 ug/L	Boys Rd - Well 1	Calcium (total)	

<b># samples:</b>	1	<b>min:</b>	6,900 ug/L
<b># detects:</b>	1	<b>max:</b>	6,900 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	6,900 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Chloride(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40	1.88 mg/L	Boys Rd - Well 1	Chloride	<=250 Secondary Standard

<b># samples:</b>	1	<b>min:</b>	1.88 mg/L
<b># detects:</b>	1	<b>max:</b>	1.88 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	1.88 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Chromium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40	< 0.00050 mg/L	Boys Rd - Well 1	Chromium (total)	<=0.1 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Cobalt (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40	< 0.10 ug/L	Boys Rd - Well 1	Cobalt (total)	

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Copper (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40	0.00403 mg/L	Boys Rd - Well 1	Copper (total)	<=1 Secondary Standard

<b># samples:</b>	1	<b>min:</b>	0.00403 mg/L
<b># detects:</b>	1	<b>max:</b>	0.00403 mg/L

<b># non-detects:</b>	0	<b>avg:</b>	0.00403 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Cyanide (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 < 0.0020 mg/L	Boys Rd - Well 1	Cyanide (total)	<=0.2 MAC for Cyanide (free)

<b># samples:</b>	1	<b>min:</b>	< 0.0020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Diquat(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 < 0.0100 mg/L	Boys Rd - Well 1	Diquat	<=0.02 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0100 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0100 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Fluoride(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 < 0.1 mg/L	Boys Rd - Well 1	Fluoride	<=4.0 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.1 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.1 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Glyphosate(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 < 0.05 mg/L	Boys Rd - Well 1	Glyphosate	<=0.7 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.05 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.05 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Hardness (total, as CaCO3)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 20.5 mg/L	Boys Rd - Well 1	Hardness (total, as CaCO3)	

<b># samples:</b>	1	<b>min:</b>	20.5 mg/L
<b># detects:</b>	1	<b>max:</b>	20.5 mg/L

**# non-detects:** 0                      **avg:** 20.5 mg/L (based on 1 numerical results)  
**# of Exceedences:** 0

Iron (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40      < 0.01 mg/L	Boys Rd - Well 1	Iron (total)	<=0.3      Secondary Standard

**# samples:** 1                      **min:** < 0.01 mg/L  
**# detects:** 0                      **max:** < 0.01 mg/L  
**# non-detects:** 1                      **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40      0.00022 mg/L	Boys Rd - Well 1	Lead (total)	<=0.015      MCL

**# samples:** 1                      **min:** 0.00022 mg/L  
**# detects:** 1                      **max:** 0.00022 mg/L  
**# non-detects:** 0                      **avg:** 0.00022 mg/L (based on 1 numerical results)  
**# of Exceedences:** 0

Lithium (dissolved)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40      < 0.10 ug/L	Boys Rd - Well 1	Lithium (dissolved)	

**# samples:** 1                      **min:** < 0.10 ug/L  
**# detects:** 0                      **max:** < 0.10 ug/L  
**# non-detects:** 1                      **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Magnesium (dissolved)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40      784 ug/L	Boys Rd - Well 1	Magnesium (dissolved)	

**# samples:** 1                      **min:** 784 ug/L  
**# detects:** 1                      **max:** 784 ug/L  
**# non-detects:** 0                      **avg:** 784 ug/L (based on 1 numerical results)  
**# of Exceedences:** 0

Manganese (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40      < 0.00020 mg/L	Boys Rd - Well 1	Manganese (total)	<=0.05      Secondary Standard

**# samples:** 1                      **min:** < 0.00020 mg/L  
**# detects:** 0                      **max:** < 0.00020 mg/L  
**# non-detects:** 1                      **avg:** n/a (based on 0 numerical results)

**# of Exceedences:** 0

<b>Mercury (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.000010 mg/L	Boys Rd - Well 1	Mercury (total)	<=0.002	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Molybdenum (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.10 ug/L	Boys Rd - Well 1	Molybdenum (total)		

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Nickel (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.00040 mg/L	Boys Rd - Well 1	Nickel (total)	<=0.1	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00040 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00040 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Nitrate (as N)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	0.114 mg/L	Boys Rd - Well 1	Nitrate (as N)	<=10	MCL

<b># samples:</b>	1	<b>min:</b>	0.114 mg/L
<b># detects:</b>	1	<b>max:</b>	0.114 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.114 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Nitrilotriacetic acid / NTA(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.2 mg/L	Boys Rd - Well 1	Nitrilotriacetic acid / NTA	<=0.4	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.2 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.2 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		



Paraquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	< 0.0050 mg/L	Boys Rd - Well 1	Paraquat	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

<b># samples:</b>	1	<b>min:</b>	< 0.0050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

pH(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
01/08/2020	7.1	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
02/03/2020	6.9	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
03/02/2020	6.8	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
04/07/2020	6.88	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
05/04/2020	7.11	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
06/01/2020	7.06	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
07/07/2020	7.22	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
08/04/2020	7.13	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
09/01/2020	7.11	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
10/05/2020	7.13	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
11/02/2020	7.35	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
12/01/2020	7.5	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard

<b># samples:</b>	12	<b>min:</b>	6.8
<b># detects:</b>	12	<b>max:</b>	7.5
<b># non-detects:</b>	0	<b>avg:</b>	7.11 (based on 12 numerical results)
<b># of Exceedences:</b>	0		

pH(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	7.16	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard

<b># samples:</b>	1	<b>min:</b>	7.16
<b># detects:</b>	1	<b>max:</b>	7.16
<b># non-detects:</b>	0	<b>avg:</b>	7.16 (based on 1 numerical results)
<b># of Exceedences:</b>	0		

Potassium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	210 ug/L	Boys Rd - Well 1	Potassium (total)		

<b># samples:</b>	1	<b>min:</b>	210 ug/L
<b># detects:</b>	1	<b>max:</b>	210 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	210 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Selenium (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 < 0.00050 mg/L	Boys Rd - Well 1	Selenium (total)	<=0.05 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Silicon (total, as Si)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 2,300 ug/L	Boys Rd - Well 1	Silicon (total, as Si)	

<b># samples:</b>	1	<b>min:</b>	2,300 ug/L
<b># detects:</b>	1	<b>max:</b>	2,300 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	2,300 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Silver (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 < 0.000050 mg/L	Boys Rd - Well 1	Silver (total)	<=0.1 Secondary Standard

<b># samples:</b>	1	<b>min:</b>	< 0.000050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Sodium (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 1.64 mg/L	Boys Rd - Well 1	Sodium (total)	<=160 MCL

<b># samples:</b>	1	<b>min:</b>	1.64 mg/L
<b># detects:</b>	1	<b>max:</b>	1.64 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	1.64 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Strontium (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/27/2020 13:40 20.6 ug/L	Boys Rd - Well 1	Strontium (total)	

<b># samples:</b>	1	<b>min:</b>	20.6 ug/L
<b># detects:</b>	1	<b>max:</b>	20.6 ug/L

# non-detects:	0	avg:	20.6 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40 < 3,000 ug/L	Boys Rd - Well 1	Sulfur (total)	

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40 1.7 mg/L	Boys Rd - Well 1	Sulphate	<=250 Secondary Standard

# samples:	1	min:	1.7 mg/L
# detects:	1	max:	1.7 mg/L
# non-detects:	0	avg:	1.7 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 13:40 < 20 ug/L	Boys Rd - Well 1	Sulphide (total, as S)	

# samples:	1	min:	< 20 ug/L
# detects:	0	max:	< 20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
01/08/2020 12 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
02/03/2020 10 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
03/02/2020 9.6 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
04/07/2020 13.1 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
05/04/2020 12 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
06/01/2020 14.6 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
07/07/2020 13.8 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
* 07/27/2020 1,230 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
* 08/04/2020 17.4 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
* 09/01/2020 17.5 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
* 10/05/2020 16.8 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
* 11/02/2020 17.3 degrees C	Boys Rd - Well 1	Temperature	<=15 AO
12/01/2020 14.7 degrees C	Boys Rd - Well 1	Temperature	<=15 AO



<b># samples:</b>	13	<b>min:</b>	9.6 degrees C
<b># detects:</b>	13	<b>max:</b>	1,230 degrees C
<b># non-detects:</b>	0	<b>avg:</b>	107.6 degrees C (based on 13 numerical results)
<b># of Exceedences:</b>	5		

<b>Thallium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.000020 mg/L	Boys Rd - Well 1	Thallium (total)	<=0.002	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Tin (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 0.20 ug/L	Boys Rd - Well 1	Tin (total)		

<b># samples:</b>	1	<b>min:</b>	< 0.20 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.20 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Titanium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/27/2020 13:40	< 5.0 ug/L	Boys Rd - Well 1	Titanium (total)		

<b># samples:</b>	1	<b>min:</b>	< 5.0 ug/L
<b># detects:</b>	0	<b>max:</b>	< 5.0 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Turbidity(Inline Instrument)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
01/08/2020	0.11 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
02/03/2020	0.12 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
03/02/2020	0.09 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
04/07/2020	0.05 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
05/04/2020	0.05 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
06/01/2020	0.03 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
07/07/2020	0.04 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
08/04/2020	0.07 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
09/01/2020	0.07 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
10/05/2020	0.08 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
11/02/2020	0.07 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined

Turbidity(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
12/01/2020	0.12 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined

<b># samples:</b>	12	<b>min:</b>	0.03 NTU
<b># detects:</b>	12	<b>max:</b>	0.12 NTU
<b># non-detects:</b>	0	<b>avg:</b>	0.08 NTU (based on 12 numerical results)
<b># of Exceedences:</b>	0	<b>95th percentile:</b>	0.12 NTU

Uranium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	< 0.000020 mg/L	Boys Rd - Well 1	Uranium (total)	<=0.02	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

Vanadium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	1.3 ug/L	Boys Rd - Well 1	Vanadium (total)		

<b># samples:</b>	1	<b>min:</b>	1.3 ug/L
<b># detects:</b>	1	<b>max:</b>	1.3 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	1.3 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

Zinc (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	< 0.0040 mg/L	Boys Rd - Well 1	Zinc (total)	<=5	Secondary Standard

<b># samples:</b>	1	<b>min:</b>	< 0.0040 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0040 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

Zirconium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020 13:40	< 0.10 ug/L	Boys Rd - Well 1	Zirconium (total)		

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Facility:</b>	Water - Raw; Water - Raw
<b>Sampling Point:</b>	Boys Rd - Well 3 (3-4-SR, 3B16B)



1,1,1-Trichloroethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	1,1,1-Trichloroethane	<=0.2 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

1,1,2,2-Tetrachloroethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.5 ug/L	Boys Rd - Well 3	1,1,2,2-Tetrachloroethane	
<b># samples:</b>	1	<b>min:</b>	< 0.5 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.5 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

1,1,2-Trichloroethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	1,1,2-Trichloroethane	<=0.005 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

1,1-Dichloroethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 1.0 ug/L	Boys Rd - Well 3	1,1-Dichloroethane	
<b># samples:</b>	1	<b>min:</b>	< 1.0 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 1.0 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

1,1-Dichloroethylene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	1,1-Dichloroethylene	<=0.007 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

1,2-Dichlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0005 mg/L	Boys Rd - Well 3	1,2-Dichlorobenzene	<=0.6 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichloroethene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 1.0 ug/L	Boys Rd - Well 3	1,2-Dichloroethene	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichloropropane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,2-Dichloropropane	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 1.0 ug/L	Boys Rd - Well 3	1,3-Dichlorobenzene	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichloropropene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 1.0 ug/L	Boys Rd - Well 3	1,3-Dichloropropene	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,4-Dichlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,4-Dichlorobenzene	<=0.075 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>1-Methylnaphthalene(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.100 ug/L	Boys Rd - Well 3	1-Methylnaphthalene	

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	

<b># samples:</b>	1	<b>min:</b>	< 0.50 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.50 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>2,3,4,6-Tetrachlorophenol(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.00050 mg/L	Boys Rd - Well 3	2,3,4,6-Tetrachlorop henol	<=0.001 AO (MAC is 0.1 mg/L)

<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>2,3,4-Trichlorophenol(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,3,4-Trichlorophenol	

<b># samples:</b>	1	<b>min:</b>	< 0.50 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.50 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		



2,3,5-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,3,5-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,3,6-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.20 ug/L	Boys Rd - Well 3	2,3-Dichlorophenol	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.20 ug/L	Boys Rd - Well 3	2,4 + 2,5-Dichlorophenol	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,4,5-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



**2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)**      **Sampling Point Name**      **Measurement Name**      **Criteria**

08/04/2020 13:30      < 0.10 ug/L      Boys Rd - Well 3      2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T

**# samples:**                      1                      **min:**                      < 0.10 ug/L  
**# detects:**                      0                      **max:**                      < 0.10 ug/L  
**# non-detects:**                  1                      **avg:**                      n/a (based on 0 numerical results)  
**# of Exceedences:**              0

**2,4,6-Trichlorophenol(Lab Data Transfer)**      **Sampling Point Name**      **Measurement Name**      **Criteria**

08/04/2020 13:30      < 0.00050 mg/L      Boys Rd - Well 3      2,4,6-Trichlorophenol      <=0.002      AO (MAC is 0.005 mg/L)

**# samples:**                      1                      **min:**                      < 0.00050 mg/L  
**# detects:**                      0                      **max:**                      < 0.00050 mg/L  
**# non-detects:**                  1                      **avg:**                      n/a (based on 0 numerical results)  
**# of Exceedences:**              0

**2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)**      **Sampling Point Name**      **Measurement Name**      **Criteria**

08/04/2020 13:30      < 0.00010 mg/L      Boys Rd - Well 3      2,4-Dichlorophenoxyacetic acid / 2,4-D      <=0.07      MCL

**# samples:**                      1                      **min:**                      < 0.00010 mg/L  
**# detects:**                      0                      **max:**                      < 0.00010 mg/L  
**# non-detects:**                  1                      **avg:**                      n/a (based on 0 numerical results)  
**# of Exceedences:**              0

**2,6-Dichlorophenol(Lab Data Transfer)**      **Sampling Point Name**      **Measurement Name**      **Criteria**

08/04/2020 13:30      < 0.20 ug/L      Boys Rd - Well 3      2,6-Dichlorophenol

**# samples:**                      1                      **min:**                      < 0.20 ug/L  
**# detects:**                      0                      **max:**                      < 0.20 ug/L  
**# non-detects:**                  1                      **avg:**                      n/a (based on 0 numerical results)  
**# of Exceedences:**              0

**2-Chloronaphthalene(Lab Data Transfer)**      **Sampling Point Name**      **Measurement Name**      **Criteria**

08/04/2020 13:30      < 0.100 ug/L      Boys Rd - Well 3      2-Chloronaphthalene

**# samples:**                      1                      **min:**                      < 0.100 ug/L  
**# detects:**                      0                      **max:**                      < 0.100 ug/L



<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

2-Chlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.10 ug/L	Boys Rd - Well 3	2-Chlorophenol	

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
---	---------------------	------------------	----------

08/04/2020 13:30 < 0.20 ug/L	Boys Rd - Well 3	2-methyl-4-chlorophe noxyacetic acid / MCPA	
------------------------------	------------------	---	--

<b># samples:</b>	1	<b>min:</b>	< 0.20 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.20 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

2-Methylnaphthalene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
--	---------------------	------------------	----------

08/04/2020 13:30 < 0.100 ug/L	Boys Rd - Well 3	2-Methylnaphthalene	
-------------------------------	------------------	---------------------	--

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

3 and 4-Chlorophenol (Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
--	---------------------	------------------	----------

08/04/2020 13:30 < 0.10 ug/L	Boys Rd - Well 3	3 and 4-Chlorophenol	
------------------------------	------------------	-------------------------	--

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

3,4,5-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
--	---------------------	------------------	----------

08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	3,4,5-Trichlorophenol	
------------------------------	------------------	-----------------------	--

<b># samples:</b>	1	<b>min:</b>	< 0.50 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.50 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>3,4-Dichlorophenol(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.20 ug/L	Boys Rd - Well 3	3,4-Dichlorophenol	

<b># samples:</b>	1	<b>min:</b>	< 0.20 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.20 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>3,5-Dichlorophenol(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.40 ug/L	Boys Rd - Well 3	3,5-Dichlorophenol	

<b># samples:</b>	1	<b>min:</b>	< 0.40 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.40 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.50 ug/L	Boys Rd - Well 3	4-Chloro-3-methylphenol (Parachlorometacresol)	

<b># samples:</b>	1	<b>min:</b>	< 0.50 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.50 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Acenaphthene(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Acenaphthene	

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Acenaphthylene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.200 ug/L	Boys Rd - Well 3	Acenaphthylene	

<b># samples:</b>	1	<b>min:</b>	< 0.200 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.200 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Acridine(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Acridine	

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Alachlor(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Alachlor	<=0.002 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Aldicarb(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Aldicarb	

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Aldrin(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.006 ug/L	Boys Rd - Well 3	Aldrin	

<b># samples:</b>	1	<b>min:</b>	< 0.006 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.006 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>alpha-BHC(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.010 ug/L	Boys Rd - Well 3	alpha-BHC	



<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Aluminum (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.0050 mg/L	Boys Rd - Well 3	Aluminum (total)	<=0.2	Secondary Standard

<b># samples:</b>	1	<b>min:</b>	< 0.0050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Anthracene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.010 ug/L	Boys Rd - Well 3	Anthracene		

<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Antimony (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.00020 mg/L	Boys Rd - Well 3	Antimony (total)	<=0.006	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Aroclor 1016(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1016		

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Aroclor 1221(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1221		

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L

**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Aroclor 1232(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1232	

**# samples:** 1 **min:** < 0.050 ug/L  
**# detects:** 0 **max:** < 0.050 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Aroclor 1242(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1242	

**# samples:** 1 **min:** < 0.050 ug/L  
**# detects:** 0 **max:** < 0.050 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Aroclor 1248(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1248	

**# samples:** 1 **min:** < 0.050 ug/L  
**# detects:** 0 **max:** < 0.050 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Aroclor 1254(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1254	

**# samples:** 1 **min:** < 0.050 ug/L  
**# detects:** 0 **max:** < 0.050 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Aroclor 1260(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1260	

**# samples:** 1 **min:** < 0.050 ug/L  
**# detects:** 0 **max:** < 0.050 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

<b>Aroclor 1262(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1262	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Aroclor 1268(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1268	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Arsenic (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.00050 mg/L	Boys Rd - Well 3	Arsenic (total)	<=0.010 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Atrazine + N-dealkylated metabolites(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Atrazine + N-dealkylated metabolites	<=0.005 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Azinphos-methyl(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Azinphos-methyl	<=0.02 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000200 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000200 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			





<b>Barium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0050 mg/L	Boys Rd - Well 3	Barium (total)	<=2 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0050 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0050 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Bendiocarb(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Bendiocarb	
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Benzene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0005 mg/L	Boys Rd - Well 3	Benzene	<=0.001 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0005 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0005 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Benzo(a)anthracene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.010 ug/L	Boys Rd - Well 3	Benzo(a)anthracene	
<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Benzo(b)fluoranthene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.010 ug/L	Boys Rd - Well 3	Benzo(b)fluoranthene	
<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			



Benzo(b,j)fluoranthene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Benzo(b,j)fluoranthene	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Benzo(g,h,i)perylene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Benzo(g,h,i)perylene	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Benzo(k)fluoranthene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Benzo(k)fluoranthene	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Beryllium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Beryllium (total)	<=0.004 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.00010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.00010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

beta-BHC(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	beta-BHC	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Bismuth (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.10 ug/L	Boys Rd - Well 3	Bismuth (total)	
<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Boron (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	0.0841 mg/L	Boys Rd - Well 3	Boron (total)	<=5 MAC
<b># samples:</b>	1	<b>min:</b>	0.0841 mg/L	
<b># detects:</b>	1	<b>max:</b>	0.0841 mg/L	
<b># non-detects:</b>	0	<b>avg:</b>	0.0841 mg/L (based on 1 numerical results)	
<b># of Exceedences:</b>	0			

<b>Bromacil(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Bromacil	
<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Bromate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.01 mg/L	Boys Rd - Well 3	Bromate	<=0.01 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.01 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.01 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Bromodichloromethane (dichlorobromomethane)	<=0.016 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	



**# of Exceedences:** 0

Bromoform(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 1.0 ug/L	Boys Rd - Well 3	Bromoform	

<b># samples:</b> 1	<b>min:</b> < 1.0 ug/L
<b># detects:</b> 0	<b>max:</b> < 1.0 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Bromoxynil(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000200 mg/L	Boys Rd - Well 3	Bromoxynil	<=0.005 MAC

<b># samples:</b> 1	<b>min:</b> < 0.000200 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.000200 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Butachlor(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.020 ug/L	Boys Rd - Well 3	Butachlor	

<b># samples:</b> 1	<b>min:</b> < 0.020 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.020 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Cadmium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000010 mg/L	Boys Rd - Well 3	Cadmium (total)	<=0.005 MCL

<b># samples:</b> 1	<b>min:</b> < 0.000010 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.000010 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Calcium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 8,470 ug/L	Boys Rd - Well 3	Calcium (total)	

<b># samples:</b> 1	<b>min:</b> 8,470 ug/L
<b># detects:</b> 1	<b>max:</b> 8,470 ug/L
<b># non-detects:</b> 0	<b>avg:</b> 8,470 ug/L (based on 1 numerical results)
<b># of Exceedences:</b> 0	

<b>Captan(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Captan		

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Carbaryl(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Carbaryl	<=0.09	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Carbofuran(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Carbofuran	<=0.04	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Carbon tetrachloride(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.0005 mg/L	Boys Rd - Well 3	Carbon tetrachloride	<=0.003	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0005 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0005 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Chlordane(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000050 mg/L	Boys Rd - Well 3	Chlordane	<=0.002	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Chloride(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	1.86 mg/L	Boys Rd - Well 3	Chloride	<=250	Secondary Standard



<b># samples:</b>	1	<b>min:</b>	1.86 mg/L
<b># detects:</b>	1	<b>max:</b>	1.86 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	1.86 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Chlorobenzene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Chlorobenzene	<=0.1 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Chloroethane(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 2.0 ug/L	Boys Rd - Well 3	Chloroethane	

<b># samples:</b>	1	<b>min:</b>	< 2.0 ug/L
<b># detects:</b>	0	<b>max:</b>	< 2.0 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Chloroform(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 1.0 ug/L	Boys Rd - Well 3	Chloroform	

<b># samples:</b>	1	<b>min:</b>	< 1.0 ug/L
<b># detects:</b>	0	<b>max:</b>	< 1.0 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Chlorothalonil(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Chlorothalonil	

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Chlorpyrifos(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000010 mg/L	Boys Rd - Well 3	Chlorpyrifos	<=0.09 MAC

<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L

**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Chromium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.00050 mg/L	Boys Rd - Well 3	Chromium (total)	<=0.1 MCL

**# samples:** 1 **min:** < 0.00050 mg/L  
**# detects:** 0 **max:** < 0.00050 mg/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Chrysene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Chrysene	

**# samples:** 1 **min:** < 0.050 ug/L  
**# detects:** 0 **max:** < 0.050 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

cis-1,2-Dichloroethylene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0010 mg/L	Boys Rd - Well 3	cis-1,2-Dichloroethyl ene	<=0.07 MCL

**# samples:** 1 **min:** < 0.0010 mg/L  
**# detects:** 0 **max:** < 0.0010 mg/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Cobalt (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.10 ug/L	Boys Rd - Well 3	Cobalt (total)	

**# samples:** 1 **min:** < 0.10 ug/L  
**# detects:** 0 **max:** < 0.10 ug/L  
**# non-detects:** 1 **avg:** n/a (based on 0 numerical results)  
**# of Exceedences:** 0

Copper (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 0.0111 mg/L	Boys Rd - Well 3	Copper (total)	<=1 Secondary Standard

**# samples:** 1 **min:** 0.0111 mg/L  
**# detects:** 1 **max:** 0.0111 mg/L  
**# non-detects:** 0 **avg:** 0.0111 mg/L (based on 1 numerical results)

**# of Exceedences:** 0

<b>Cyanazine(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.100 ug/L	Boys Rd - Well 3	Cyanazine	

<b># samples:</b> 1	<b>min:</b> < 0.100 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.100 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

<b>Cyanide (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.0020 mg/L	Boys Rd - Well 3	Cyanide (total)	<=0.2 MAC for Cyanide (free)

<b># samples:</b> 1	<b>min:</b> < 0.0020 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.0020 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

<b>DDT + metabolites(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.010 ug/L	Boys Rd - Well 3	DDT + metabolites	

<b># samples:</b> 1	<b>min:</b> < 0.010 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.010 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

<b>delta-BHC(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	delta-BHC	

<b># samples:</b> 1	<b>min:</b> < 0.050 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.050 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

<b>Deltamethrin(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.100 ug/L	Boys Rd - Well 3	Deltamethrin	

<b># samples:</b> 1	<b>min:</b> < 0.100 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.100 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	





<b>Diazinon(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000020 mg/L	Boys Rd - Well 3	Diazinon	<=0.02 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Dibenzo(a,h)anthracene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.010 ug/L	Boys Rd - Well 3	Dibenzo(a,h)anthracene	
<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 1.0 ug/L	Boys Rd - Well 3	Dibromochloromethane (Chlorodibromomethane)	
<b># samples:</b>	1	<b>min:</b>	< 1.0 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 1.0 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Dibromomethane(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 1.0 ug/L	Boys Rd - Well 3	Dibromomethane	
<b># samples:</b>	1	<b>min:</b>	< 1.0 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 1.0 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Dicamba(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Dicamba	<=0.12 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.00010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.00010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	



**# of Exceedences:** 0

Dichloromethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0030 mg/L	Boys Rd - Well 3	Dichloromethane	<=0.005 MCL

<b># samples:</b> 1	<b>min:</b> < 0.0030 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.0030 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Dichlorvos(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.100 ug/L	Boys Rd - Well 3	Dichlorvos	

<b># samples:</b> 1	<b>min:</b> < 0.100 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.100 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Diclofop-methyl(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000100 mg/L	Boys Rd - Well 3	Diclofop-methyl	<=0.009 MAC

<b># samples:</b> 1	<b>min:</b> < 0.000100 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.000100 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Dieldrin(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.010 ug/L	Boys Rd - Well 3	Dieldrin	

<b># samples:</b> 1	<b>min:</b> < 0.010 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.010 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Dimethoate(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000200 mg/L	Boys Rd - Well 3	Dimethoate	<=0.02 MAC

<b># samples:</b> 1	<b>min:</b> < 0.000200 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.000200 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

<b>Dinoseb(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Dinoseb	<=0.007	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Diquat(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.0100 mg/L	Boys Rd - Well 3	Diquat	<=0.02	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0100 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0100 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Disulfoton(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Disulfoton		

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Diuron(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Diuron	<=0.15	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.000200 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000200 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Endosulfan (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.010 ug/L	Boys Rd - Well 3	Endosulfan (total)		

<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Endosulfan sulfate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Endosulfan sulfate		

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Endrin aldehyde(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.020 ug/L	Boys Rd - Well 3	Endrin aldehyde	

<b># samples:</b>	1	<b>min:</b>	< 0.020 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.020 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Endrin ketone(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.020 ug/L	Boys Rd - Well 3	Endrin ketone	

<b># samples:</b>	1	<b>min:</b>	< 0.020 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.020 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Endrin(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.000020 mg/L	Boys Rd - Well 3	Endrin	<=0.002 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Ethylbenzene(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.0010 mg/L	Boys Rd - Well 3	Ethylbenzene	<=0.7 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Ethylene dibromide / EDB(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.0003 mg/L	Boys Rd - Well 3	Ethylene dibromide / EDB	<=0.00002 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0003 mg/L
-------------------	---	-------------	---------------

<b># detects:</b>	0	<b>max:</b>	< 0.0003 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Fenclorphos(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Fenclorphos	

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Fluoranthene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.030 ug/L	Boys Rd - Well 3	Fluoranthene	

<b># samples:</b>	1	<b>min:</b>	< 0.030 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.030 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Fluorene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Fluorene	

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Fluoride(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.1 mg/L	Boys Rd - Well 3	Fluoride	<=4.0 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.1 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.1 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Glyphosate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.05 mg/L	Boys Rd - Well 3	Glyphosate	<=0.7 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.05 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.05 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)

# of Exceedences: 0

Hardness (total, as CaCO3)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 25.1 mg/L	Boys Rd - Well 3	Hardness (total, as CaCO3)	

# samples:	1	min:	25.1 mg/L
# detects:	1	max:	25.1 mg/L
# non-detects:	0	avg:	25.1 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Heptachlor epoxide(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000010 mg/L	Boys Rd - Well 3	Heptachlor epoxide	<=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000010 mg/L	Boys Rd - Well 3	Heptachlor	<=0.0004 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Indeno(1,2,3-c,d)pyrene	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.01 mg/L	Boys Rd - Well 3	Iron (total)	<=0.3 Secondary Standard

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

**# of Exceedences:** 0

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 0.00066 mg/L	Boys Rd - Well 3	Lead (total)	<=0.015 MCL

<b># samples:</b> 1	<b>min:</b> 0.00066 mg/L
<b># detects:</b> 1	<b>max:</b> 0.00066 mg/L
<b># non-detects:</b> 0	<b>avg:</b> 0.00066 mg/L (based on 1 numerical results)
<b># of Exceedences:</b> 0	

Lindane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000050 mg/L	Boys Rd - Well 3	Lindane	<=0.0002 MCL

<b># samples:</b> 1	<b>min:</b> < 0.000050 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.000050 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Linuron(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.050 ug/L	Boys Rd - Well 3	Linuron	

<b># samples:</b> 1	<b>min:</b> < 0.050 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.050 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Lithium (dissolved)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.10 ug/L	Boys Rd - Well 3	Lithium (dissolved)	

<b># samples:</b> 1	<b>min:</b> < 0.10 ug/L
<b># detects:</b> 0	<b>max:</b> < 0.10 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Magnesium (dissolved)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 960 ug/L	Boys Rd - Well 3	Magnesium (dissolved)	

<b># samples:</b> 1	<b>min:</b> 960 ug/L
<b># detects:</b> 1	<b>max:</b> 960 ug/L
<b># non-detects:</b> 0	<b>avg:</b> 960 ug/L (based on 1 numerical results)
<b># of Exceedences:</b> 0	



<b>Malathion(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Malathion	<=0.19	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Manganese (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.00020 mg/L	Boys Rd - Well 3	Manganese (total)	<=0.05	Secondary Standard

<b># samples:</b>	1	<b>min:</b>	< 0.00020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Mercury (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000010 mg/L	Boys Rd - Well 3	Mercury (total)	<=0.002	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Methoxychlor(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000050 mg/L	Boys Rd - Well 3	Methoxychlor	<=0.04	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Methyl parathion(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Methyl parathion		

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		



<b>Methyl tert-butyl ether / MTBE(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 1.0 ug/L	Boys Rd - Well 3	Methyl tert-butyl ether / MTBE	
<b># samples:</b>	1	<b>min:</b>	< 1.0 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 1.0 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Metolachlor(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Metolachlor	<=0.05 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Metribuzin(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Metribuzin	<=0.08 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000200 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000200 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Molybdenum (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.10 ug/L	Boys Rd - Well 3	Molybdenum (total)	
<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Naphthalene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.200 ug/L	Boys Rd - Well 3	Naphthalene	
<b># samples:</b>	1	<b>min:</b>	< 0.200 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.200 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			



<b>Nickel (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.00040 mg/L	Boys Rd - Well 3	Nickel (total)	<=0.1	MCL
<b># samples:</b>	1	<b>min:</b>	< 0.00040 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.00040 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Nitrate (as N)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	0.08 mg/L	Boys Rd - Well 3	Nitrate (as N)	<=10	MCL
<b># samples:</b>	1	<b>min:</b>	0.08 mg/L		
<b># detects:</b>	1	<b>max:</b>	0.08 mg/L		
<b># non-detects:</b>	0	<b>avg:</b>	0.08 mg/L (based on 1 numerical results)		
<b># of Exceedences:</b>	0				

<b>Nitritotriacetic acid / NTA(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.2 mg/L	Boys Rd - Well 3	Nitritotriacetic acid / NTA	<=0.4	MAC
<b># samples:</b>	1	<b>min:</b>	< 0.2 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.2 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Paraquat(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.0050 mg/L	Boys Rd - Well 3	Paraquat	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride
<b># samples:</b>	1	<b>min:</b>	< 0.0050 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.0050 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

<b>Parathion(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Parathion		
<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L		
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		

# of Exceedences: 0

**Pentachloronitrobenzene / PCNB(Lab Data Transfer)**

Sampling Point Name	Measurement Name	Criteria
Boys Rd - Well 3	Pentachloronitrobenzene / PCNB	

08/04/2020 13:30	< 0.100 ug/L	
<b># samples:</b>	1	<b>min:</b> < 0.100 ug/L
<b># detects:</b>	0	<b>max:</b> < 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**Pentachlorophenol / PCP(Lab Data Transfer)**

Sampling Point Name	Measurement Name	Criteria
Boys Rd - Well 3	Pentachlorophenol / PCP	<=0.001 MCL

08/04/2020 13:30	< 0.00050 mg/L	
<b># samples:</b>	1	<b>min:</b> < 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b> < 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**Permethrin(Lab Data Transfer)**

Sampling Point Name	Measurement Name	Criteria
Boys Rd - Well 3	Permethrin	

08/04/2020 13:30	< 0.010 ug/L	
<b># samples:</b>	1	<b>min:</b> < 0.010 ug/L
<b># detects:</b>	0	<b>max:</b> < 0.010 ug/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**pH(Inline Instrument)**

Sampling Point Name	Measurement Name	Criteria
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
01/21/2020	6.72	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
02/24/2020	6.78	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
03/17/2020	6.84	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
05/21/2020	6.95	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
06/16/2020	7.07	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
07/21/2020	7.01	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
08/17/2020	7.03	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
09/17/2020	7.07	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
10/19/2020	7.32	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
11/16/2020	7.38	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
12/15/2020	7.49	
Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard



<b># samples:</b>	11	<b>min:</b>	6.72
<b># detects:</b>	11	<b>max:</b>	7.49
<b># non-detects:</b>	0	<b>avg:</b>	7.06 (based on 11 numerical results)
<b># of Exceedences:</b>	0		

<b>pH(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	7.22	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard

<b># samples:</b>	1	<b>min:</b>	7.22
<b># detects:</b>	1	<b>max:</b>	7.22
<b># non-detects:</b>	0	<b>avg:</b>	7.22 (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Phenanthrene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Phenanthrene		

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Phorate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Phorate	<=0.002	MAC

<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Picloram(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Picloram	<=0.5	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.050 ug/L	Boys Rd - Well 3	Polychlorinated Biphenyls / PCBs (as arochlor total)		



<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Potassium (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30      200 ug/L	Boys Rd - Well 3	Potassium (total)	

<b># samples:</b>	1	<b>min:</b>	200 ug/L
<b># detects:</b>	1	<b>max:</b>	200 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	200 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Prometon(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30      < 0.300 ug/L	Boys Rd - Well 3	Prometon	

<b># samples:</b>	1	<b>min:</b>	< 0.300 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.300 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Prometryn(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30      < 0.100 ug/L	Boys Rd - Well 3	Prometryn	

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Pyrene(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30      < 0.020 ug/L	Boys Rd - Well 3	Pyrene	

<b># samples:</b>	1	<b>min:</b>	< 0.020 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.020 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Quinoline(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30      < 0.050 ug/L	Boys Rd - Well 3	Quinoline	

<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L

<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Selenium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.00050 mg/L	Boys Rd - Well 3	Selenium (total)	<=0.05	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Silicon (total, as Si)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	3,100 ug/L	Boys Rd - Well 3	Silicon (total, as Si)		

<b># samples:</b>	1	<b>min:</b>	3,100 ug/L
<b># detects:</b>	1	<b>max:</b>	3,100 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	3,100 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Silver (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000050 mg/L	Boys Rd - Well 3	Silver (total)	<=0.1	Secondary Standard

<b># samples:</b>	1	<b>min:</b>	< 0.000050 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000050 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Simazine(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Simazine	<=0.004	MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000200 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000200 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Sodium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>	
08/04/2020 13:30	1.77 mg/L	Boys Rd - Well 3	Sodium (total)	<=160	MCL

<b># samples:</b>	1	<b>min:</b>	1.77 mg/L
<b># detects:</b>	1	<b>max:</b>	1.77 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	1.77 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Strontium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	29.3 ug/L	Boys Rd - Well 3	Strontium (total)	

<b># samples:</b>	1	<b>min:</b>	29.3 ug/L
<b># detects:</b>	1	<b>max:</b>	29.3 ug/L
<b># non-detects:</b>	0	<b>avg:</b>	29.3 ug/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Styrene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Styrene	<=0.1 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Sulfotep(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Sulfotep	

<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Sulfur (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 3,000 ug/L	Boys Rd - Well 3	Sulfur (total)	

<b># samples:</b>	1	<b>min:</b>	< 3,000 ug/L
<b># detects:</b>	0	<b>max:</b>	< 3,000 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Sulphate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	1.7 mg/L	Boys Rd - Well 3	Sulphate	<=250 Secondary Standard

<b># samples:</b>	1	<b>min:</b>	1.7 mg/L
<b># detects:</b>	1	<b>max:</b>	1.7 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	1.7 mg/L (based on 1 numerical results)
<b># of Exceedences:</b>	0		

<b>Sulphide (total, as S)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 20 ug/L	Boys Rd - Well 3	Sulphide (total, as S)	

<b># samples:</b>	1	<b>min:</b>	< 20 ug/L
<b># detects:</b>	0	<b>max:</b>	< 20 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Tebuthiuron(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.200 ug/L	Boys Rd - Well 3	Tebuthiuron	

<b># samples:</b>	1	<b>min:</b>	< 0.200 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.200 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Temephos(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.500 ug/L	Boys Rd - Well 3	Temephos	

<b># samples:</b>	1	<b>min:</b>	< 0.500 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.500 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Temperature(Inline Instrument)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/21/2020 14.9 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
02/24/2020 14.4 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
03/17/2020 11.9 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
05/21/2020 14.9 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
06/16/2020 12.5 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
* 07/21/2020 15.2 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
* 08/17/2020 17.9 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
* 09/17/2020 16.9 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
* 10/19/2020 17.4 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
* 11/16/2020 16.4 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
12/15/2020 14.3 degrees C	Boys Rd - Well 3	Temperature	<=15 AO

<b># samples:</b>	11	<b>min:</b>	11.9 degrees C
<b># detects:</b>	11	<b>max:</b>	17.9 degrees C
<b># non-detects:</b>	0	<b>avg:</b>	15.2 degrees C (based on 11 numerical results)
<b># of Exceedences:</b>	5		

<b>Terbufos(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.000100 mg/L	Boys Rd - Well 3	Terbufos	<=0.001 MAC



<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Tetrachloroethylene / PCE(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.0010 mg/L	Boys Rd - Well 3	Tetrachloroethylene / PCE	<=0.003 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Thallium (total)(Lab Data Transfer)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30 < 0.000020 mg/L	Boys Rd - Well 3	Thallium (total)	<=0.002 MCL

<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Time(Inline Instrument)</b>	<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
01/21/2020 900	Boys Rd - Well 3	Time	
02/24/2020 930	Boys Rd - Well 3	Time	
03/17/2020 1,000	Boys Rd - Well 3	Time	
05/21/2020 1,105	Boys Rd - Well 3	Time	
06/16/2020 1,205	Boys Rd - Well 3	Time	
07/21/2020 1,000	Boys Rd - Well 3	Time	
08/17/2020 1,130	Boys Rd - Well 3	Time	
09/17/2020 1,335	Boys Rd - Well 3	Time	
10/19/2020 1,145	Boys Rd - Well 3	Time	
11/16/2020 1,005	Boys Rd - Well 3	Time	
12/15/2020 1,110	Boys Rd - Well 3	Time	

<b># samples:</b>	11	<b>min:</b>	900
<b># detects:</b>	11	<b>max:</b>	1,335
<b># non-detects:</b>	0	<b>avg:</b>	1,079 (based on 11 numerical results)
<b># of Exceedences:</b>	0		

<b>Tin (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.20 ug/L	Boys Rd - Well 3	Tin (total)	
<b># samples:</b>	1	<b>min:</b>	< 0.20 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.20 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Titanium (total)(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 5.0 ug/L	Boys Rd - Well 3	Titanium (total)	
<b># samples:</b>	1	<b>min:</b>	< 5.0 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 5.0 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Toluene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Toluene	<=1 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>trans-1,2-Dichloroethylene(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	trans-1,2-Dichloroethylene	<=0.1 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

<b>Triallate(Lab Data Transfer)</b>		<b>Sampling Point Name</b>	<b>Measurement Name</b>	<b>Criteria</b>
08/04/2020 13:30	< 0.100 ug/L	Boys Rd - Well 3	Triallate	
<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			



Trichloroethylene / TCE(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/04/2020 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Trichloroethylene / TCE	<=0.003	MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

Trichlorofluoromethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/04/2020 13:30	< 1.0 ug/L	Boys Rd - Well 3	Trichlorofluoromethane		
<b># samples:</b>	1	<b>min:</b>	< 1.0 ug/L		
<b># detects:</b>	0	<b>max:</b>	< 1.0 ug/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

Trifluralin(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/04/2020 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Trifluralin	<=0.045	MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000200 mg/L		
<b># detects:</b>	0	<b>max:</b>	< 0.000200 mg/L		
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)		
<b># of Exceedences:</b>	0				

Turbidity(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
01/21/2020	0.098 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
02/24/2020	0.09 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
03/17/2020	0.12 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
05/21/2020	0.03 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
06/16/2020	0.05 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
07/21/2020	0.03 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
08/17/2020	0.07 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
09/17/2020	0.08 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
10/19/2020	0.09 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
11/16/2020	0.08 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
12/15/2020	0.01 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
<b># samples:</b>	11	<b>min:</b>	0.01 NTU		
<b># detects:</b>	11	<b>max:</b>	0.12 NTU		
<b># non-detects:</b>	0	<b>avg:</b>	0.068 NTU (based on 11 numerical results)		



**# of Exceedences:** 0      **95th percentile:** 0.120 NTU

Uranium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.000020 mg/L	Boys Rd - Well 3	Uranium (total)	<=0.02      MAC

<b># samples:</b> 1	<b>min:</b> < 0.000020 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.000020 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Vanadium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 1.0 ug/L	Boys Rd - Well 3	Vanadium (total)	

<b># samples:</b> 1	<b>min:</b> < 1.0 ug/L
<b># detects:</b> 0	<b>max:</b> < 1.0 ug/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Vinyl chloride(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0010 mg/L	Boys Rd - Well 3	Vinyl chloride	<=0.001      MCL

<b># samples:</b> 1	<b>min:</b> < 0.0010 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.0010 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Xylenes (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.0020 mg/L	Boys Rd - Well 3	Xylenes (total)	<=10      MCL

<b># samples:</b> 1	<b>min:</b> < 0.0020 mg/L
<b># detects:</b> 0	<b>max:</b> < 0.0020 mg/L
<b># non-detects:</b> 1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b> 0	

Zinc (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 0.0151 mg/L	Boys Rd - Well 3	Zinc (total)	<=5      Secondary Standard

<b># samples:</b> 1	<b>min:</b> 0.0151 mg/L
<b># detects:</b> 1	<b>max:</b> 0.0151 mg/L
<b># non-detects:</b> 0	<b>avg:</b> 0.0151 mg/L (based on 1 numerical results)
<b># of Exceedences:</b> 0	

Zirconium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/04/2020 13:30 < 0.10 ug/L	Boys Rd - Well 3	Zirconium (total)	

<b># samples:</b>	1	<b>min:</b>	< 0.10 ug/L
<b># detects:</b>	0	<b>max:</b>	< 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0		

<b>Facility:</b>	Water - Raw; Water - Raw
<b>Sampling Point:</b>	Boys Rd - Well 5 (3-6-SR, 3B16D)

pH(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
01/29/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
02/19/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
03/25/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
04/28/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
05/26/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
06/25/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
07/27/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
08/26/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
09/23/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
10/26/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
11/23/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard
12/08/2020	Boys Rd - Well 5	pH	>=6.5, <=8.5 Secondary Standard

<b># samples:</b>	12	<b>min:</b>	6.97
<b># detects:</b>	12	<b>max:</b>	7.34
<b># non-detects:</b>	0	<b>avg:</b>	7.11 (based on 12 numerical results)
<b># of Exceedences:</b>	0		

Temperature(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
01/29/2020	Boys Rd - Well 5	Temperature	<=15 AO
02/19/2020	Boys Rd - Well 5	Temperature	<=15 AO
03/25/2020	Boys Rd - Well 5	Temperature	<=15 AO
04/28/2020	Boys Rd - Well 5	Temperature	<=15 AO
05/26/2020	Boys Rd - Well 5	Temperature	<=15 AO
06/25/2020	Boys Rd - Well 5	Temperature	<=15 AO
* 07/27/2020	Boys Rd - Well 5	Temperature	<=15 AO
* 08/26/2020	Boys Rd - Well 5	Temperature	<=15 AO
* 09/23/2020	Boys Rd - Well 5	Temperature	<=15 AO
* 10/26/2020	Boys Rd - Well 5	Temperature	<=15 AO



Temperature(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
* 11/23/2020 16.0 degrees C	Boys Rd - Well 5	Temperature	<=15 AO
* 12/08/2020 16.1 degrees C	Boys Rd - Well 5	Temperature	<=15 AO
<b># samples:</b> 12	<b>min:</b> 11.4 degrees C		
<b># detects:</b> 12	<b>max:</b> 17.6 degrees C		
<b># non-detects:</b> 0	<b>avg:</b> 14.8 degrees C (based on 12 numerical results)		
<b># of Exceedences:</b> 6			

Time(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
01/29/2020 1,230	Boys Rd - Well 5	Time	
02/19/2020 1,020	Boys Rd - Well 5	Time	
03/25/2020 1,305	Boys Rd - Well 5	Time	
04/28/2020 800	Boys Rd - Well 5	Time	
05/26/2020 1,135	Boys Rd - Well 5	Time	
07/27/2020 1,300	Boys Rd - Well 5	Time	
08/26/2020 920	Boys Rd - Well 5	Time	
09/23/2020 830	Boys Rd - Well 5	Time	
10/26/2020 1,200	Boys Rd - Well 5	Time	
11/23/2020 1,215	Boys Rd - Well 5	Time	
12/08/2020 1,250	Boys Rd - Well 5	Time	
<b># samples:</b> 11	<b>min:</b> 800		
<b># detects:</b> 11	<b>max:</b> 1,305		
<b># non-detects:</b> 0	<b>avg:</b> 1,110 (based on 11 numerical results)		
<b># of Exceedences:</b> 0			

Turbidity(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
01/29/2020 0.11 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
02/19/2020 0.09 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
03/25/2020 0.06 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
04/28/2020 0.01 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
05/26/2020 0.07 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
06/25/2020 0.04 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
07/27/2020 0.02 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
08/26/2020 0.08 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
09/23/2020 0.08 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
10/26/2020 0.08 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
11/23/2020 0.26 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined
12/08/2020 0.13 NTU	Boys Rd - Well 5	Turbidity	<=0.5 User-Defined



<b># samples:</b>	12	<b>min:</b>	0.01 NTU
<b># detects:</b>	12	<b>max:</b>	0.26 NTU
<b># non-detects:</b>	0	<b>avg:</b>	0.09 NTU (based on 12 numerical results)
<b># of Exceedences:</b>	0	<b>95th percentile:</b>	0.26 NTU

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,  
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

\* Indicates Criteria is exceeded