

August 15, 2025

File: 5630-55

Island Health
Unit 202 – 6425 Norcross Road
Duncan, B.C.
V9L 6C5

Dear Environmental Health Officer,

**Re: South End Water System Water Quality Report
Premises Number 1310818
Report for the Period Jan 1/24 to Dec 31/24**

Please find the Municipality of North Cowichan's Water quality report for the South-end Water System attached.

Sincerely,



Kyle Simpson
Manager, Utilities
kyle.simpson@northcowichan.ca

cc: Clay Reitsma Director, Engineering



1 Operator Information

Contact Name	Neil Gailey Foreperson, Utilities
Phone	250-746-3152
Email	neil.gailey@northcowichan.ca

2 System Description

This is a groundwater supply. Water is pumped from the Boys Road wells and treated with U.V disinfection. In 2018, Vancouver Island Health Authority amended the operating certificate for the South End Water System and the Municipality is now required to chlorinate continuously to reduce bacterial growth in the distribution system. In December of 2019 a new sodium hypochlorite injection system was installed to replace the existing calcium hypochlorite system.

3 Boil Advisories

None.

4 Future Improvements

No future improvements are contemplated at this time.

5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

6 Results

See below for the results of various water quality parameters.

Report Name: South-end Water Quality Report

Report Subtitle: Water Quality Report

	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
January 2024	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					5,092.84	0.08
2	0.53	0.24	0.64	0.36	4,713.37	0.07
3					5,441.76	0.06
4					4,932.13	0.07
5					4,674.42	0.07
6					4,756.88	0.07
7					5,438.82	0.07
8					4,847.01	0.08
9	0.58		0.63	0.32	4,710.89	0.07
10		0.48			5,116.79	0.07
11					5,486.75	0.08
12					4,738.13	0.08
13					5,039.60	0.08
14					5,873.42	0.07
15				0.34	5,645.67	0.07
16		0.42			6,038.51	0.07
17					5,882.63	0.07
18					5,514.99	0.07
19					5,246.19	0.07
20					5,538.04	0.08
21					5,837.86	0.07
22		0.52	0.82	0.36	5,657.06	0.08
23	0.64				5,526.44	0.07
24					5,477.35	0.08
25					5,413.26	0.07
26					5,128.33	0.07
27					5,160.72	0.08
28					5,611.69	0.07
29			0.71		5,199.29	0.08
30	0.61				6,002.97	0.07
31		0.55			5,913.40	0.08
Average	0.59	0.44	0.70	0.35	5,343.78	0.07
Minimum	0.53	0.24	0.63	0.32	4,674.42	0.06
Maximum	0.64	0.55	0.82	0.36	6,038.51	0.08
Count	4	5	4	4	31	31
Total					165,657.21	
95 Percentile						0.08
Exceedences	0	0	0	0	0	0
Median	0.60	0.48	0.68	0.35	5,438.82	0.07

February 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1				0.47	5,459.51	0.07
2					4,915.76	0.07
3					4,985.17	0.08
4					5,537.06	0.07
5		0.43		0.33	5,039.79	0.08
6	0.60				5,216.50	0.07
7			0.51		5,273.77	0.08
8					5,220.36	0.08
9					5,071.67	0.07
10					4,664.54	0.08
11					4,827.66	0.08
12	0.66				5,358.82	0.08
13			0.58	0.36	4,711.17	0.08
14		0.52			6,042.64	0.08
15					5,149.40	0.08
16					4,589.97	0.07
17					4,524.43	0.08
18					4,776.16	0.08
19					4,876.96	0.07
20			0.55	0.34	4,795.10	0.07
21	0.54	0.52			4,695.41	0.08
22					4,726.69	0.08
23					4,582.09	0.08
24					4,957.88	0.07
25					5,066.16	0.08
26			0.58	0.26	5,111.33	0.08
27	0.54				4,729.42	0.08
28		0.57			4,572.65	0.07
29					4,742.86	0.08

Average	0.59	0.51	0.56	0.35	4,973.14	0.08
Minimum	0.54	0.43	0.51	0.26	4,524.43	0.07
Maximum	0.66	0.57	0.58	0.47	6,042.64	0.08
Count	4	4	4	5	29	29
Total					144,220.93	
95 Percentile						0.08
Exceedences	0	0	0	0	0	0
Median	0.57	0.52	0.57	0.34	4,915.76	0.08

March 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					4,938.66	0.08
2					4,824.99	0.08
3					5,327.70	0.08
4		0.49			5,001.54	0.08
5	0.67				4,660.64	0.08
6					4,846.95	0.08
7			0.56	0.41	5,086.65	0.07
8					4,706.99	0.08
9					5,160.35	0.08
10					5,100.70	0.07
11					4,844.92	0.08
12					4,761.44	0.08
13	0.50	0.50	0.56	0.27	5,030.76	0.08
14					5,317.20	0.08
15					5,116.14	0.07
16					4,868.78	0.07
17					5,835.90	0.08
18			0.71	0.31	5,485.18	0.07
19					5,170.61	0.07
20					4,921.92	0.07
21					4,922.60	0.07
22	0.50	0.63			4,925.22	0.08
23					4,587.73	0.08
24					5,250.31	0.07
25			0.54	0.36	4,917.36	0.08
26					4,921.31	0.08
27		0.49			5,054.03	0.08
28					5,058.87	0.08
29					5,197.97	0.08
30					5,233.08	0.08
31					5,534.77	0.07

Average	0.56	0.53	0.59	0.34	5,051.98	0.08
Minimum	0.50	0.49	0.54	0.27	4,587.73	0.07
Maximum	0.67	0.63	0.71	0.41	5,835.90	0.08
Count	3	4	4	4	31	31
Total					156,611.27	
95 Percentile						0.08
Exceedences	0	0	0	0	0	0
Median	0.50	0.50	0.56	0.34	5,030.76	0.08

April 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					5,053.76	0.07
2	0.48	0.53	0.82	0.41	5,108.68	0.08
3					5,602.59	0.08
4					5,587.07	0.07
5					5,474.58	0.08
6					5,606.76	0.07
7					5,325.36	0.08
8					5,440.19	0.08
9					5,528.48	0.08
10					5,499.89	0.08
11					5,413.91	0.07
12					5,126.16	0.08
13					5,676.45	0.07
14					5,615.58	0.08
15					5,851.86	0.08
16					6,082.55	0.08
17	0.57	0.54	0.59	0.33	6,308.33	0.08
18					6,299.21	0.08
19					6,186.81	0.08
20					5,823.35	0.08
21					6,088.12	0.08
22			0.64		6,492.01	0.08
23					6,659.81	0.08
24				0.27	6,247.38	0.08
25	0.53	0.63			5,658.26	0.08
26					5,689.35	0.08
27					5,258.41	0.08
28					5,714.01	0.09
29					5,899.13	0.09
30					6,122.46	0.08
Average	0.53	0.57	0.68	0.34	5,748.02	0.08
Minimum	0.48	0.53	0.59	0.27	5,053.76	0.07
Maximum	0.57	0.63	0.82	0.41	6,659.81	0.09
Count	3	3	3	3	30	30
Total					172,440.51	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.53	0.54	0.64	0.33	5,667.36	0.08

May 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					6,416.50	0.08
2	0.46		0.56	0.21	6,658.07	0.07
3					6,433.33	0.08
4					6,477.12	0.08
5					6,586.74	0.08
6					6,767.83	0.08
7					6,906.38	0.08
8					7,203.59	0.08
9					8,720.51	0.08
10	0.50	0.63	0.62	0.53	8,609.85	0.07
11					9,181.89	0.07
12					9,529.10	0.08
13		0.64			9,041.52	0.07
14					8,899.30	0.07
15	0.51		0.66	0.55	9,195.02	0.07
16					9,471.55	0.08
17					8,932.06	0.08
18					8,122.70	0.08
19					8,305.60	0.08
20					8,959.03	0.07
21					7,452.94	0.08
22					7,166.65	0.08
23					7,763.59	0.08
24	0.62		0.71	0.57	7,125.40	0.08
25					7,397.81	0.08
26					7,297.21	0.08
27					7,034.89	0.07
28		0.61	0.63	0.60	6,769.52	0.08
29	0.71				7,035.42	0.08
30					7,416.79	0.07
31					7,651.26	0.07

Average	0.56	0.63	0.64	0.49	7,759.01	0.08
Minimum	0.46	0.61	0.56	0.21	6,416.50	0.07
Maximum	0.71	0.64	0.71	0.60	9,529.10	0.08
Count	5	3	5	5	31	31
Total					240,529.17	
95 Percentile						0.08
Exceedences	0	0	0	0	0	0
Median	0.51	0.63	0.63	0.55	7,416.79	0.08

June 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					7,237.20	0.08
2					6,731.05	0.07
3		0.58		0.67	6,893.83	0.08
4					6,750.97	0.08
5	0.53		0.60		7,442.22	0.07
6					8,267.68	0.07
7					8,499.68	0.07
8					9,561.34	0.07
9					9,923.70	0.07
10				0.57	9,829.74	0.07
11		0.73	0.72		8,394.32	0.08
12					8,611.95	0.07
13					9,204.19	0.07
14					9,018.03	0.07
15					8,087.60	0.07
16					8,390.46	0.07
17					8,370.40	0.07
18		0.77	0.67	0.62	9,119.96	0.07
19					10,278.49	0.07
20					11,381.92	0.07
21					11,461.57	0.07
22					10,183.21	0.07
23					10,909.77	0.07
24			0.66	0.56	10,746.41	0.07
25					10,915.91	0.07
26	0.55				10,088.89	0.07
27					9,267.40	0.07
28					10,547.51	0.07
29					10,514.28	0.07
30					10,693.15	0.07
Average	0.54	0.69	0.66	0.61	9,244.09	0.07
Minimum	0.53	0.58	0.60	0.56	6,731.05	0.07
Maximum	0.55	0.77	0.72	0.67	11,461.57	0.08
Count	2	3	4	4	30	30
Total					277,322.83	
95 Percentile						0.08
Exceedences	0	0	0	0	0	0
Median	0.54	0.73	0.67	0.60	9,235.80	0.07

July 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					11,832.05	0.07
2		0.56		0.55	11,663.91	0.07
3			0.63		12,216.93	0.07
4					12,968.08	0.07
5					13,313.92	0.07
6					13,877.45	0.07
7					14,718.08	0.07
8					14,864.29	0.07
9		0.60	0.53	0.32	14,604.76	0.07
10	0.53				14,424.66	0.07
11					13,952.64	0.07
12					13,518.96	0.07
13					13,013.34	0.07
14					13,213.88	0.07
15		0.61	0.56	0.41	13,068.54	0.07
16	0.54				12,788.99	0.07
17					13,315.55	0.06
18					13,962.07	0.07
19					14,034.86	0.06
20					14,072.17	0.06
21					14,047.11	0.07
22				0.51	12,682.86	0.06
23					12,021.20	0.07
24			0.55		12,156.21	0.07
25	0.41	0.51			12,120.10	0.06
26					11,102.55	0.07
27					11,072.60	0.07
28					11,331.62	0.06
29		0.49			9,202.94	0.07
30	0.25		0.41	0.34	8,638.74	0.07
31					9,798.77	0.06

Average	0.43	0.55	0.54	0.43	12,696.77	0.07
Minimum	0.25	0.49	0.41	0.32	8,638.74	0.06
Maximum	0.54	0.61	0.63	0.55	14,864.29	0.07
Count	4	5	5	5	31	31
Total					393,599.83	
95 Percentile						0.07
Exceedences	0	0	0	0	0	0
Median	0.47	0.56	0.55	0.41	13,013.34	0.07

August 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					11,044.64	0.06
2					10,740.03	0.06
3					11,199.58	0.05
4					10,940.98	0.06
5					11,938.27	0.06
6	0.30	0.40			12,492.06	0.06
7			0.47	0.38	12,162.36	0.06
8					12,176.42	0.06
9					11,664.45	0.06
10					11,623.39	0.06
11					11,312.23	0.06
12					10,445.44	0.06
13					9,477.61	0.06
14	0.35	0.59	0.51		9,322.71	0.06
15					9,372.69	0.06
16				0.31	9,517.13	0.06
17					9,336.54	0.06
18					8,709.41	0.06
19				0.13	7,912.74	0.07
20					7,150.43	0.05
21					7,357.19	0.06
22		0.44	0.42		7,682.89	0.06
23					7,201.05	0.06
24					7,165.29	0.06
25					7,289.78	0.06
26	0.34		0.58	0.32	7,137.19	0.05
27		0.33			6,933.90	0.06
28					7,124.48	0.06
29					7,375.05	0.05
30					7,667.12	0.05
31					8,095.86	0.05

Average	0.33	0.44	0.50	0.29	9,340.93	0.06
Minimum	0.30	0.33	0.42	0.13	6,933.90	0.05
Maximum	0.35	0.59	0.58	0.38	12,492.06	0.07
Count	3	4	4	4	31	31
Total					289,568.91	
95 Percentile						0.06
Exceedences	0	0	0	0	0	0
Median	0.34	0.42	0.49	0.32	9,336.54	0.06

September 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					8,658.82	0.05
2					8,967.64	0.05
3	0.36	0.38	0.67	0.35	8,520.52	0.05
4					8,610.51	0.05
5					8,817.95	0.05
6					8,709.08	0.05
7					9,066.93	0.05
8					9,224.09	0.05
9					8,925.95	0.05
10					8,274.82	0.05
11	0.41	0.33	0.49	0.40	7,709.85	0.05
12					8,212.43	0.05
13					7,510.11	0.05
14					7,263.08	0.05
15					7,514.18	0.05
16	0.56			0.27	7,392.30	0.05
17		0.36	0.51		7,186.70	0.05
18					7,153.82	0.05
19					7,160.15	0.05
20					7,215.87	0.05
21					7,618.20	0.05
22					7,509.82	0.05
23	0.42		0.71	0.70	7,261.32	0.05
24		0.40			6,946.05	0.05
25					7,162.71	0.05
26					6,942.52	0.05
27					6,610.47	0.05
28					6,461.78	0.05
29					6,501.05	0.06
30					6,721.69	0.05
Average	0.44	0.37	0.60	0.43	7,727.68	0.05
Minimum	0.36	0.33	0.49	0.27	6,461.78	0.05
Maximum	0.56	0.40	0.71	0.70	9,224.09	0.06
Count	4	4	4	4	30	30
Total					231,830.41	
95 Percentile						0.05
Exceedences	0	0	0	0	0	0
Median	0.42	0.37	0.59	0.38	7,509.97	0.05

October 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1		0.61	0.62	0.53	6,505.15	0.06
2	0.42				6,528.04	0.06
3					6,563.51	0.05
4					6,099.38	0.05
5					6,228.00	0.05
6					6,478.14	0.05
7					6,132.62	0.06
8	0.46		0.60	0.55	6,136.31	0.06
9		0.60			6,074.74	0.06
10					5,863.38	0.06
11					5,645.92	0.06
12					5,962.51	0.06
13					6,006.59	0.06
14					5,750.08	0.05
15	0.50	0.55	0.54	0.52	5,762.38	0.06
16					5,664.42	0.06
17					5,515.01	0.05
18					5,293.92	0.05
19					5,204.94	0.06
20					6,255.81	0.06
21		0.61	0.55	0.57	6,319.78	0.05
22					5,135.83	0.06
23	0.49				5,404.08	0.06
24					5,298.37	0.06
25					4,950.78	0.06
26					5,355.33	0.06
27					5,547.56	0.06
28				0.15	5,470.36	0.06
29					5,312.23	0.06
30	0.32	0.34	0.58		5,082.76	0.06
31					4,898.45	0.06

Average	0.44	0.54	0.58	0.46	5,756.33	0.06
Minimum	0.32	0.34	0.54	0.15	4,898.45	0.05
Maximum	0.50	0.61	0.62	0.57	6,563.51	0.06
Count	5	5	5	5	31	31
Total					178,446.38	
95 Percentile						0.06
Exceedences	0	0	0	0	0	0
Median	0.46	0.60	0.58	0.53	5,750.08	0.06

November 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					5,194.59	0.06
2					5,385.84	0.06
3					5,479.02	0.06
4		0.57			5,638.64	0.06
5					5,599.33	0.06
6	0.53				5,258.56	0.06
7			0.25		5,111.01	0.06
8				0.32	5,062.58	0.06
9					5,307.23	0.06
10					5,534.60	0.07
11					5,504.41	0.06
12					5,408.21	0.07
13	0.47				5,278.95	0.06
14					5,126.45	0.07
15				0.35	4,896.58	0.06
16					5,301.59	0.07
17					5,151.81	0.06
18	0.83	0.57	0.62	0.45	5,064.70	0.06
19					5,197.11	0.06
20					5,233.12	0.08
21					5,259.59	0.06
22					5,502.04	0.07
23					5,174.90	0.07
24					5,274.40	0.06
25			1.00	0.44	5,213.53	0.07
26					5,633.61	0.07
27					5,297.81	0.07
28					5,276.05	0.07
29	0.58	0.57			5,382.35	0.10
30					5,326.96	0.08
Average	0.60	0.57	0.62	0.39	5,302.52	0.07
Minimum	0.47	0.57	0.25	0.32	4,896.58	0.06
Maximum	0.83	0.57	1.00	0.45	5,638.64	0.10
Count	4	3	3	4	30	30
Total					159,075.57	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.56	0.57	0.62	0.40	5,277.50	0.06

December 2024	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m ³ /d)	Avg Turbidity (Daily) (NTU)
1					5,955.88	0.07
2					5,754.92	0.08
3	0.24		0.82	0.21	5,945.20	0.08
4					6,173.26	0.07
5					5,992.58	0.08
6		0.45			5,705.10	0.07
7					5,429.69	0.07
8					5,909.58	0.09
9		0.48	0.64		5,947.87	0.08
10	0.43			0.40	5,492.95	0.07
11					5,683.89	0.07
12					5,339.22	0.08
13					4,897.22	0.07
14					5,419.05	0.08
15					5,364.69	0.07
16					5,284.61	0.07
17					5,248.53	0.08
18	0.67	0.67	0.86	0.46	5,564.78	0.09
19					5,632.19	0.09
20					5,556.39	0.07
21					5,060.28	0.08
22					5,363.46	0.07
23	0.75	0.63	0.82	0.41	5,456.14	0.08
24					5,490.40	0.07
25					5,579.45	0.07
26					5,115.63	0.08
27					5,358.56	0.07
28					5,155.39	0.08
29					5,212.00	0.07
30					5,369.73	0.08
31	0.61				5,335.21	0.07

Average	0.54	0.56	0.79	0.37	5,509.48	0.08
Minimum	0.24	0.45	0.64	0.21	4,897.22	0.07
Maximum	0.75	0.67	0.86	0.46	6,173.26	0.09
Count	5	4	4	4	31	31
Total					170,793.85	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.61	0.56	0.82	0.41	5,456.14	0.07

* indicates Geometric Mean
** indicates Intraday Average

DISINFECTANTS

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2024	0.36 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/09/2024	0.32 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/15/2024	0.34 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/22/2024	0.36 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/01/2024	0.47 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/05/2024	0.33 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/13/2024	0.36 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/20/2024	0.34 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/26/2024	0.26 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/07/2024	0.41 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/13/2024	0.27 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/18/2024	0.31 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/25/2024	0.36 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/02/2024	0.41 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/17/2024	0.33 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/24/2024	0.27 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/02/2024	0.21 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/10/2024	0.53 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/15/2024	0.55 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/24/2024	0.57 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/28/2024	0.60 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/03/2024	0.67 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/10/2024	0.57 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/18/2024	0.62 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/24/2024	0.56 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/02/2024	0.55 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/09/2024	0.32 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/15/2024	0.41 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/22/2024	0.51 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/30/2024	0.34 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/07/2024	0.38 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/16/2024	0.31 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/19/2024	0.13 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/26/2024	0.32 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/03/2024	0.35 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/11/2024	0.40 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/16/2024	0.27 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
09/23/2024	0.70 mg/L	Free Cl2	Maple Mtn Reservoir
10/01/2024	0.53 mg/L	Free Cl2	Maple Mtn Reservoir
10/08/2024	0.55 mg/L	Free Cl2	Maple Mtn Reservoir
10/15/2024	0.52 mg/L	Free Cl2	Maple Mtn Reservoir
10/21/2024	0.57 mg/L	Free Cl2	Maple Mtn Reservoir
10/28/2024	0.15 mg/L	Free Cl2	Maple Mtn Reservoir
11/08/2024	0.32 mg/L	Free Cl2	Maple Mtn Reservoir
11/15/2024	0.35 mg/L	Free Cl2	Maple Mtn Reservoir
11/18/2024	0.45 mg/L	Free Cl2	Maple Mtn Reservoir
11/25/2024	0.44 mg/L	Free Cl2	Maple Mtn Reservoir
12/03/2024	0.21 mg/L	Free Cl2	Maple Mtn Reservoir
12/10/2024	0.40 mg/L	Free Cl2	Maple Mtn Reservoir
12/18/2024	0.46 mg/L	Free Cl2	Maple Mtn Reservoir
12/23/2024	0.41 mg/L	Free Cl2	Maple Mtn Reservoir

# samples:	51	min:	0.13 mg/L
# detects:	51	max:	0.70 mg/L
# non-detects:	0	avg:	0.41 mg/L (based on 51 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2024	0.24 mg/L	Free Cl2	Bell McKinnon Reservoir
01/10/2024	0.48 mg/L	Free Cl2	Bell McKinnon Reservoir
01/16/2024	0.42 mg/L	Free Cl2	Bell McKinnon Reservoir
01/22/2024	0.52 mg/L	Free Cl2	Bell McKinnon Reservoir
01/31/2024	0.55 mg/L	Free Cl2	Bell McKinnon Reservoir
02/05/2024	0.43 mg/L	Free Cl2	Bell McKinnon Reservoir
02/14/2024	0.52 mg/L	Free Cl2	Bell McKinnon Reservoir
02/21/2024	0.52 mg/L	Free Cl2	Bell McKinnon Reservoir
02/28/2024	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir
03/04/2024	0.49 mg/L	Free Cl2	Bell McKinnon Reservoir
03/13/2024	0.50 mg/L	Free Cl2	Bell McKinnon Reservoir
03/22/2024	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir
03/27/2024	0.49 mg/L	Free Cl2	Bell McKinnon Reservoir
04/02/2024	0.53 mg/L	Free Cl2	Bell McKinnon Reservoir
04/17/2024	0.54 mg/L	Free Cl2	Bell McKinnon Reservoir
04/25/2024	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir
05/10/2024	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir
05/13/2024	0.64 mg/L	Free Cl2	Bell McKinnon Reservoir
05/28/2024	0.61 mg/L	Free Cl2	Bell McKinnon Reservoir



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
06/03/2024	0.58 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
06/11/2024	0.73 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
06/18/2024	0.77 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/02/2024	0.56 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/09/2024	0.60 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/15/2024	0.61 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/25/2024	0.51 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/29/2024	0.49 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/06/2024	0.40 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/14/2024	0.59 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/22/2024	0.44 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/27/2024	0.33 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/03/2024	0.38 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/11/2024	0.33 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/17/2024	0.36 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/24/2024	0.40 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/01/2024	0.61 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/09/2024	0.60 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/15/2024	0.55 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/21/2024	0.61 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/30/2024	0.34 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
11/04/2024	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
11/18/2024	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
11/29/2024	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/06/2024	0.45 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/09/2024	0.48 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/18/2024	0.67 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/23/2024	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined

# samples:	47	min:	0.24 mg/L
# detects:	47	max:	0.77 mg/L
# non-detects:	0	avg:	0.52 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2024	0.64 mg/L	Free Cl2	Maple Bay Marina >=0.05, <=4 User-Defined
01/09/2024	0.63 mg/L	Free Cl2	Maple Bay Marina >=0.05, <=4 User-Defined
01/22/2024	0.82 mg/L	Free Cl2	Maple Bay Marina >=0.05, <=4 User-Defined
01/29/2024	0.71 mg/L	Free Cl2	Maple Bay Marina >=0.05, <=4 User-Defined
02/07/2024	0.51 mg/L	Free Cl2	Maple Bay Marina >=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
02/13/2024	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/20/2024	0.55 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/26/2024	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/07/2024	0.56 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/13/2024	0.56 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/18/2024	0.71 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/25/2024	0.54 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/02/2024	0.82 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/17/2024	0.59 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/22/2024	0.64 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/02/2024	0.56 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/10/2024	0.62 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/15/2024	0.66 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/24/2024	0.71 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/28/2024	0.63 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/05/2024	0.60 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/11/2024	0.72 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/18/2024	0.67 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/24/2024	0.66 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/03/2024	0.63 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/09/2024	0.53 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/15/2024	0.56 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/24/2024	0.55 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/30/2024	0.41 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/07/2024	0.47 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/14/2024	0.51 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/22/2024	0.42 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/26/2024	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/03/2024	0.67 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/11/2024	0.49 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/17/2024	0.51 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/23/2024	0.71 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/01/2024	0.62 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/08/2024	0.60 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/15/2024	0.54 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/21/2024	0.55 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/30/2024	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/07/2024	0.25 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/18/2024	0.62 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
11/25/2024	1.00 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/03/2024	0.82 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/09/2024	0.64 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/18/2024	0.86 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/23/2024	0.82 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined

# samples:	49	min:	0.25 mg/L
# detects:	49	max:	1.00 mg/L
# non-detects:	0	avg:	0.62 mg/L (based on 49 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/02/2024	0.69 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
01/08/2024	0.64 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
01/23/2024	0.70 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
01/30/2024	0.51 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/06/2024	0.80 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/12/2024	0.77 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/21/2024	0.60 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/27/2024	0.51 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
03/05/2024	0.62 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
03/12/2024	0.50 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
04/02/2024	0.64 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
04/08/2024	0.55 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
* 04/17/2024	361 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/02/2024	0.52 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/10/2024	0.51 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/14/2024	0.73 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/29/2024	0.79 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/03/2024	0.74 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/10/2024	0.72 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/18/2024	0.79 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/24/2024	0.68 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/03/2024	0.68 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/08/2024	0.39 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/15/2024	0.64 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/23/2024	0.56 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/30/2024	0.54 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
08/07/2024	0.54 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
08/14/2024	0.54 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
08/20/2024	0.57 mg/L	Free Cl2	North Rd Reservoir #2
08/26/2024	0.48 mg/L	Free Cl2	North Rd Reservoir #2
09/04/2024	0.54 mg/L	Free Cl2	North Rd Reservoir #2
09/16/2024	0.69 mg/L	Free Cl2	North Rd Reservoir #2
09/24/2024	0.52 mg/L	Free Cl2	North Rd Reservoir #2
10/02/2024	0.49 mg/L	Free Cl2	North Rd Reservoir #2
10/08/2024	0.77 mg/L	Free Cl2	North Rd Reservoir #2
10/15/2024	0.66 mg/L	Free Cl2	North Rd Reservoir #2
10/23/2024	0.68 mg/L	Free Cl2	North Rd Reservoir #2
10/28/2024	0.61 mg/L	Free Cl2	North Rd Reservoir #2
11/06/2024	0.68 mg/L	Free Cl2	North Rd Reservoir #2
11/12/2024	0.62 mg/L	Free Cl2	North Rd Reservoir #2
11/18/2024	0.76 mg/L	Free Cl2	North Rd Reservoir #2
11/29/2024	0.58 mg/L	Free Cl2	North Rd Reservoir #2
12/03/2024	0.59 mg/L	Free Cl2	North Rd Reservoir #2
12/09/2024	0.51 mg/L	Free Cl2	North Rd Reservoir #2
12/20/2024	0.68 mg/L	Free Cl2	North Rd Reservoir #2
12/27/2024	0.76 mg/L	Free Cl2	North Rd Reservoir #2

# samples:	46	min:	0.39 mg/L
# detects:	46	max:	361 mg/L
# non-detects:	0	avg:	8.46 mg/L (based on 46 numerical results)
# of Exceedences:	1		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2024	0.53 mg/L	Free Cl2	3908 Cowichan Lake Rd
01/09/2024	0.58 mg/L	Free Cl2	3908 Cowichan Lake Rd
01/23/2024	0.64 mg/L	Free Cl2	3908 Cowichan Lake Rd
01/30/2024	0.61 mg/L	Free Cl2	3908 Cowichan Lake Rd
02/06/2024	0.60 mg/L	Free Cl2	3908 Cowichan Lake Rd
02/12/2024	0.66 mg/L	Free Cl2	3908 Cowichan Lake Rd
02/21/2024	0.54 mg/L	Free Cl2	3908 Cowichan Lake Rd
02/27/2024	0.54 mg/L	Free Cl2	3908 Cowichan Lake Rd
03/05/2024	0.67 mg/L	Free Cl2	3908 Cowichan Lake Rd
03/13/2024	0.50 mg/L	Free Cl2	3908 Cowichan Lake Rd
03/22/2024	0.50 mg/L	Free Cl2	3908 Cowichan Lake Rd
04/02/2024	0.48 mg/L	Free Cl2	3908 Cowichan Lake Rd
04/17/2024	0.57 mg/L	Free Cl2	3908 Cowichan Lake Rd
04/25/2024	0.53 mg/L	Free Cl2	3908 Cowichan Lake Rd
05/02/2024	0.46 mg/L	Free Cl2	3908 Cowichan Lake Rd



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
05/10/2024	0.50 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/15/2024	0.51 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/24/2024	0.62 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/29/2024	0.71 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
06/05/2024	0.53 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
06/26/2024	0.55 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/10/2024	0.53 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/16/2024	0.54 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/25/2024	0.41 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/30/2024	0.25 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
08/06/2024	0.30 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
08/14/2024	0.35 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
08/26/2024	0.34 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/03/2024	0.36 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/11/2024	0.41 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/16/2024	0.56 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/23/2024	0.42 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/02/2024	0.42 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/08/2024	0.46 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/15/2024	0.50 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/23/2024	0.49 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/30/2024	0.32 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/06/2024	0.53 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/13/2024	0.47 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/18/2024	0.83 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/29/2024	0.58 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/03/2024	0.24 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/10/2024	0.43 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/18/2024	0.67 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/23/2024	0.75 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/31/2024	0.61 mg/L	Free Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined

# samples:	46	min:	0.24 mg/L
# detects:	46	max:	0.83 mg/L
# non-detects:	0	avg:	0.51 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/03/2024	0.88 mg/L	Free Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
01/08/2024	0.76 mg/L	Free Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/15/2024	0.67 mg/L	Free Cl2	Source at Lakes Rd
01/24/2024	0.78 mg/L	Free Cl2	Source at Lakes Rd
01/30/2024	0.76 mg/L	Free Cl2	Source at Lakes Rd
02/06/2024	0.61 mg/L	Free Cl2	Source at Lakes Rd
02/13/2024	0.70 mg/L	Free Cl2	Source at Lakes Rd
02/20/2024	0.84 mg/L	Free Cl2	Source at Lakes Rd
02/29/2024	0.79 mg/L	Free Cl2	Source at Lakes Rd
03/05/2024	0.55 mg/L	Free Cl2	Source at Lakes Rd
03/13/2024	0.70 mg/L	Free Cl2	Source at Lakes Rd
03/20/2024	0.54 mg/L	Free Cl2	Source at Lakes Rd
03/26/2024	0.91 mg/L	Free Cl2	Source at Lakes Rd
04/17/2024	0.69 mg/L	Free Cl2	Source at Lakes Rd
04/24/2024	0.47 mg/L	Free Cl2	Source at Lakes Rd
05/02/2024	0.84 mg/L	Free Cl2	Source at Lakes Rd
05/10/2024	0.95 mg/L	Free Cl2	Source at Lakes Rd
05/15/2024	0.88 mg/L	Free Cl2	Source at Lakes Rd
05/24/2024	0.73 mg/L	Free Cl2	Source at Lakes Rd
05/29/2024	0.56 mg/L	Free Cl2	Source at Lakes Rd
06/05/2024	0.80 mg/L	Free Cl2	Source at Lakes Rd
06/10/2024	0.73 mg/L	Free Cl2	Source at Lakes Rd
06/18/2024	0.66 mg/L	Free Cl2	Source at Lakes Rd
06/26/2024	0.64 mg/L	Free Cl2	Source at Lakes Rd
07/03/2024	0.63 mg/L	Free Cl2	Source at Lakes Rd
07/09/2024	0.80 mg/L	Free Cl2	Source at Lakes Rd
07/16/2024	0.63 mg/L	Free Cl2	Source at Lakes Rd
07/24/2024	0.76 mg/L	Free Cl2	Source at Lakes Rd
07/29/2024	0.5 mg/L	Free Cl2	Source at Lakes Rd
08/07/2024	0.48 mg/L	Free Cl2	Source at Lakes Rd
08/14/2024	0.60 mg/L	Free Cl2	Source at Lakes Rd
08/26/2024	0.81 mg/L	Free Cl2	Source at Lakes Rd
09/10/2024	0.67 mg/L	Free Cl2	Source at Lakes Rd
09/17/2024	0.65 mg/L	Free Cl2	Source at Lakes Rd
09/24/2024	0.67 mg/L	Free Cl2	Source at Lakes Rd
10/02/2024	0.66 mg/L	Free Cl2	Source at Lakes Rd
10/09/2024	0.67 mg/L	Free Cl2	Source at Lakes Rd
10/15/2024	0.52 mg/L	Free Cl2	Source at Lakes Rd
10/23/2024	0.55 mg/L	Free Cl2	Source at Lakes Rd
10/30/2024	0.68 mg/L	Free Cl2	Source at Lakes Rd
11/08/2024	0.71 mg/L	Free Cl2	Source at Lakes Rd



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/18/2024 1.15 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/03/2024 0.92 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/11/2024 0.60 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/18/2024 1.13 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/24/2024 0.93 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined

# samples:	46	min:	0.47 mg/L
# detects:	46	max:	1.15 mg/L
# non-detects:	0	avg:	0.72 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/03/2024 1.06 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/08/2024 0.76 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/15/2024 0.72 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/24/2024 0.89 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/30/2024 0.77 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/06/2024 0.88 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/13/2024 0.84 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/20/2024 0.81 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/29/2024 1.00 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/05/2024 0.58 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/13/2024 0.74 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/20/2024 0.80 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/26/2024 1.04 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/17/2024 0.58 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/24/2024 0.55 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/02/2024 0.77 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/10/2024 0.90 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/15/2024 0.92 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/24/2024 0.73 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/29/2024 0.50 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/05/2024 0.72 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/10/2024 0.74 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/18/2024 0.57 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/26/2024 0.73 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/03/2024 0.69 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/09/2024 0.72 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/16/2024 0.61 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/24/2024 0.75 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
07/29/2024	0.64 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
08/07/2024	0.63 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
08/14/2024	0.67 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
08/26/2024	0.89 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
09/10/2024	0.63 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
09/17/2024	0.66 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
09/24/2024	0.63 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
10/02/2024	0.62 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
10/09/2024	0.63 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
10/15/2024	0.55 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
10/23/2024	0.58 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
10/30/2024	0.72 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
11/08/2024	0.77 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
11/18/2024	1.01 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
12/03/2024	0.79 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
12/11/2024	0.65 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
12/18/2024	1.22 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined
12/24/2024	1.03 mg/L	Total Cl2	Source at Lakes Rd >=0.05, <=4 User-Defined

# samples:	46	min:	0.50 mg/L
# detects:	46	max:	1.22 mg/L
# non-detects:	0	avg:	0.75 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2024	0.48 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
01/09/2024	0.50 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
01/23/2024	0.52 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
01/30/2024	0.56 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
02/06/2024	0.61 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
02/12/2024	0.38 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
02/21/2024	0.63 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
02/27/2024	0.58 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
03/05/2024	0.65 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
03/13/2024	0.56 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
03/22/2024	0.59 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
04/02/2024	0.59 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
04/17/2024	0.49 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
04/25/2024	0.59 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/02/2024	0.48 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
05/10/2024	0.52 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/15/2024	0.55 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/24/2024	0.65 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
05/29/2024	0.68 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
06/05/2024	0.54 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
06/26/2024	0.58 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/10/2024	0.53 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/16/2024	0.61 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/25/2024	0.40 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
07/30/2024	0.27 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
08/06/2024	0.45 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
08/14/2024	0.39 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
08/26/2024	0.35 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/03/2024	0.32 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/11/2024	0.47 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/16/2024	0.40 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
09/23/2024	0.44 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/02/2024	0.44 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/08/2024	0.44 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/15/2024	0.44 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/23/2024	0.52 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
10/30/2024	0.91 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/06/2024	0.60 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/13/2024	0.57 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/18/2024	0.81 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
11/29/2024	0.59 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/03/2024	0.50 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/10/2024	0.69 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/18/2024	0.72 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/23/2024	0.81 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined
12/31/2024	0.74 mg/L	Total Cl2	3908 Cowichan Lake Rd >=0.05, <=4 User-Defined

# samples:	46	min:	0.27 mg/L
# detects:	46	max:	0.91 mg/L
# non-detects:	0	avg:	0.55 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2024	0.68 mg/L	Total Cl2	North Rd Reservoir #2 >=0.05, <=4 User-Defined
01/08/2024	0.63 mg/L	Total Cl2	North Rd Reservoir #2 >=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/23/2024	0.45 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
01/30/2024	0.77 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/06/2024	0.85 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/12/2024	0.67 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/21/2024	0.57 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
02/27/2024	0.50 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
03/05/2024	0.67 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
03/12/2024	0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
04/02/2024	0.64 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
04/08/2024	0.40 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
04/17/2024	0.67 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/02/2024	0.59 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/10/2024	0.60 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/14/2024	0.87 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
05/29/2024	0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/03/2024	0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/10/2024	0.69 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/18/2024	0.74 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
06/24/2024	0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/03/2024	0.61 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/08/2024	0.52 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/15/2024	0.68 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/23/2024	0.59 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
07/30/2024	0.57 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
08/07/2024	0.64 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
08/14/2024	0.56 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
08/20/2024	0.59 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
08/26/2024	0.50 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
09/04/2024	0.56 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
09/16/2024	0.68 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
09/24/2024	0.55 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
10/02/2024	0.60 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
10/08/2024	0.72 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
10/15/2024	0.68 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
10/23/2024	0.72 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
10/28/2024	0.58 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
11/06/2024	0.68 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
11/12/2024	0.63 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined
11/18/2024	0.79 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/29/2024 0.60 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/03/2024 0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/09/2024 0.46 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/20/2024 1.07 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/27/2024 0.86 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined

# samples:	46	min:	0.40 mg/L
# detects:	46	max:	1.07 mg/L
# non-detects:	0	avg:	0.65 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2024 0.69 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/09/2024 0.58 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/22/2024 0.81 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/29/2024 0.46 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/07/2024 0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/13/2024 0.50 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/20/2024 0.64 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/26/2024 0.53 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/07/2024 0.60 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/13/2024 0.58 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/18/2024 0.91 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/25/2024 0.56 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/02/2024 0.71 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/17/2024 0.52 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/22/2024 0.56 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/02/2024 0.54 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/10/2024 0.66 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/15/2024 0.67 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/24/2024 0.70 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/28/2024 0.62 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/05/2024 0.64 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/11/2024 0.70 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/18/2024 0.69 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/24/2024 0.68 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/03/2024 0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/09/2024 0.56 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/15/2024 0.60 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/24/2024 0.59 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
07/30/2024	0.45 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
08/07/2024	0.55 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
08/14/2024	0.54 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
08/22/2024	0.47 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
08/26/2024	0.65 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
09/03/2024	0.54 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
09/11/2024	0.62 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
09/17/2024	0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
09/23/2024	0.69 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
10/01/2024	0.66 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
10/08/2024	0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
10/15/2024	0.49 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
10/21/2024	0.58 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
10/30/2024	0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
11/07/2024	0.39 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
11/18/2024	0.60 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
11/25/2024	0.62 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/03/2024	0.83 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/09/2024	0.69 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/18/2024	0.91 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined
12/23/2024	0.84 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4	User-Defined

# samples:	49	min:	0.39 mg/L
# detects:	49	max:	0.91 mg/L
# non-detects:	0	avg:	0.62 mg/L (based on 49 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/02/2024	0.43 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
01/10/2024	0.58 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
01/16/2024	0.45 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
01/22/2024	0.65 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
01/31/2024	0.54 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
02/05/2024	0.38 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
02/14/2024	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
02/21/2024	0.62 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
02/28/2024	0.34 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
03/04/2024	0.48 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
03/13/2024	0.52 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined
03/22/2024	0.68 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
03/27/2024	0.49 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
04/02/2024	0.48 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
04/17/2024	0.45 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
04/25/2024	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
05/10/2024	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
05/13/2024	0.60 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
05/28/2024	0.66 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
06/03/2024	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
06/11/2024	0.57 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
06/18/2024	0.73 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/02/2024	0.38 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/09/2024	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/15/2024	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/25/2024	0.55 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
07/29/2024	0.35 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/06/2024	0.52 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/14/2024	0.40 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/22/2024	0.53 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
08/27/2024	0.32 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/03/2024	0.47 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/11/2024	0.46 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/17/2024	0.47 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
09/24/2024	0.42 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/01/2024	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/09/2024	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/15/2024	0.58 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/21/2024	0.66 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
10/30/2024	0.55 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
11/04/2024	0.58 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
11/18/2024	0.67 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
11/29/2024	0.61 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/06/2024	0.60 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/09/2024	0.58 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/18/2024	0.68 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined
12/23/2024	0.70 mg/L	Total Cl2	Bell McKinnon Reservoir >=0.05, <=4 User-Defined

# samples:	47	min:	0.32 mg/L
# detects:	47	max:	0.73 mg/L
# non-detects:	0	avg:	0.55 mg/L (based on 47 numerical results)
# of Exceedences:	0		



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2024	0.38 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/09/2024	0.35 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/15/2024	0.25 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/22/2024	0.42 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/01/2024	0.44 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/05/2024	0.33 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/13/2024	0.32 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/20/2024	0.33 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/26/2024	0.20 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/07/2024	0.36 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/13/2024	0.30 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/18/2024	0.33 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/25/2024	0.23 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/02/2024	0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/17/2024	0.35 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/24/2024	0.23 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/02/2024	0.50 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/10/2024	0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/15/2024	0.57 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/24/2024	0.60 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/28/2024	0.55 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/03/2024	0.64 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/10/2024	0.51 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/18/2024	0.53 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/24/2024	0.56 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/02/2024	0.38 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/09/2024	0.35 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/15/2024	0.54 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/22/2024	0.59 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/30/2024	0.45 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/07/2024	0.39 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/16/2024	0.36 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/19/2024	0.14 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/26/2024	0.41 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/03/2024	0.41 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/11/2024	0.37 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/16/2024	0.19 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/23/2024	0.68 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/01/2024	0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
10/08/2024	0.56 mg/L	Total Cl2	Maple Mtn Reservoir
10/15/2024	0.49 mg/L	Total Cl2	Maple Mtn Reservoir
10/21/2024	0.61 mg/L	Total Cl2	Maple Mtn Reservoir
10/28/2024	0.31 mg/L	Total Cl2	Maple Mtn Reservoir
11/08/2024	0.20 mg/L	Total Cl2	Maple Mtn Reservoir
11/15/2024	0.53 mg/L	Total Cl2	Maple Mtn Reservoir
11/18/2024	0.58 mg/L	Total Cl2	Maple Mtn Reservoir
11/25/2024	0.39 mg/L	Total Cl2	Maple Mtn Reservoir
12/03/2024	0.31 mg/L	Total Cl2	Maple Mtn Reservoir
12/10/2024	0.48 mg/L	Total Cl2	Maple Mtn Reservoir
12/18/2024	0.49 mg/L	Total Cl2	Maple Mtn Reservoir
12/23/2024	0.45 mg/L	Total Cl2	Maple Mtn Reservoir

# samples:	51	min:	0.14 mg/L
# detects:	51	max:	0.68 mg/L
# non-detects:	0	avg:	0.42 mg/L (based on 51 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



MICROORGANISMS

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
02/12/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
03/12/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
04/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
05/13/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
06/10/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
07/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
08/12/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
09/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
10/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
11/12/2024 00:00 SC CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined
12/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P User-Defined

# samples:	11	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/22/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
02/26/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
03/25/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
04/22/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
05/27/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
07/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
12/18/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined

# samples:	12	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
02/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
03/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
04/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
05/13/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
06/10/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
10/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
11/12/2024 00:00 SC CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
12/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined

# samples:	11	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/15/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
02/20/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
03/18/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
04/15/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
05/22/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
06/17/2024 00:00 SC CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
07/15/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
08/19/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
09/16/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
10/15/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
11/18/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined
12/16/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	1820 Herd Road	<=0, OG, P User-Defined

# samples:	11	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)



of Exceedences: 0

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
02/26/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
03/25/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
04/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
07/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
12/18/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P	User-Defined

# samples:	12	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
02/05/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
03/04/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
04/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
05/27/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
06/03/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
07/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
08/06/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
09/03/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
10/01/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
11/04/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
12/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined

# samples:	12	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
02/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
03/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
04/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
05/14/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
06/10/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
10/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
11/13/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
12/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
# samples: 12	min: < 1 CFU/100ml		
# detects: 0	max: < 1 CFU/100ml		
# non-detects: 12	Geometric Mean: n/a (based on 0 numerical results)		
# of Exceedences: 0			

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
02/12/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
03/12/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
05/13/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
06/10/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
07/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
08/12/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
09/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
10/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
10/15/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
11/12/2024 00:00 SC CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
12/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P User-Defined
# samples: 11	min: < 1 CFU/100ml		
# detects: 0	max: < 1 CFU/100ml		
# non-detects: 11	Geometric Mean: n/a (based on 0 numerical results)		



of Exceedences: 0

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
02/27/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
03/25/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
04/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
07/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
12/18/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined

# samples:	12	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
02/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
03/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
05/13/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
06/10/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
10/08/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
11/12/2024 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
12/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
# samples:	10	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
02/05/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
03/04/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
04/03/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
06/03/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
07/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
08/06/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
09/03/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
10/01/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
11/04/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
12/02/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
# samples:	12	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/15/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
02/20/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
03/18/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
04/15/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
05/22/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
06/17/2024 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
06/25/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
07/15/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
08/19/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
09/16/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
10/15/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
11/18/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
12/16/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
# samples:	12	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)		



of Exceedences: 0

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/22/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
02/26/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
03/25/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
04/24/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
05/27/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
06/24/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
07/22/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
08/26/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
09/23/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
10/22/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
11/25/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined
12/18/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P User-Defined

# samples:	12	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/08/2024 00:00 < 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P User-Defined
02/12/2024 00:00 < 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P User-Defined
03/12/2024 00:00 < 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P User-Defined
05/13/2024 00:00 < 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
06/10/2024 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
10/08/2024 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
11/12/2024 00:00	SC	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
12/09/2024 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/22/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
02/27/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
03/25/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
04/22/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
07/22/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
12/18/2024 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
# samples:	12	min:	< 1		
# detects:	0	max:	< 1		
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
02/12/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
03/12/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
05/13/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
06/10/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
10/08/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
10/15/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
11/12/2024 00:00	SC	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
12/09/2024 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
# samples:	11	min:	< 1		
# detects:	0	max:	< 1		
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/26/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
03/25/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
04/24/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
07/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
12/18/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined

# samples:	12	min:	< 1
# detects:	0	max:	< 1
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/02/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
02/05/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
03/04/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
04/02/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
06/03/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
07/02/2024 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined



Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/06/2024 00:00 < 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
09/03/2024 00:00 < 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
10/01/2024 00:00 < 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
11/04/2024 00:00 < 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
12/02/2024 00:00 < 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined

# samples:	12	min:	< 1
# detects:	0	max:	< 1
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/08/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
02/12/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
03/12/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
04/08/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
05/13/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
06/10/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
07/08/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
08/12/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
09/09/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
10/08/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
11/12/2024 00:00 SC	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined
12/09/2024 00:00 < 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P User-Defined

# samples:	11	min:	< 1
-------------------	----	-------------	-----



# detects:	0	max:	< 1
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/15/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
02/20/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
03/18/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
04/15/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
05/22/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
06/17/2024 00:00 SC	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
07/15/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
08/19/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
09/16/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
10/15/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
11/18/2024 00:00 < 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined
* 12/16/2024 00:00 1	Total Coliforms (counts)	1820 Herd Road	<=0, OG, P User-Defined

# samples:	11	min:	< 1
# detects:	1	max:	1
# non-detects:	10	Geometric Mean:	1 (based on 1 numerical results)
# of Exceedences:	1		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
01/22/2024 00:00 < 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
02/26/2024 00:00 < 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined
03/25/2024 00:00 < 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
04/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
07/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
12/18/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined

# samples:	12	min:	< 1
# detects:	0	max:	< 1
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
02/12/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
03/12/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
04/08/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
05/14/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
06/10/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
10/08/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
11/13/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
12/09/2024 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined

# samples:	12	min:	< 1
# detects:	0	max:	< 1
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
02/12/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
03/12/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
04/08/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
05/13/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
06/10/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
07/08/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
08/12/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
10/08/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
11/12/2024 00:00	SC	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined
12/09/2024 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P	User-Defined

# samples:	11	min:	< 1
# detects:	0	max:	< 1
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/02/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
02/05/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
03/04/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
04/03/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
06/03/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
07/02/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
08/06/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
09/03/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
10/01/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
11/04/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
12/02/2024 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined

# samples:	12	min:	< 1
# detects:	0	max:	< 1
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
02/26/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
03/25/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
04/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
05/27/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
06/24/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
08/26/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
09/23/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
10/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
11/25/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
12/18/2024 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined

# samples:	12	min:	< 1
# detects:	0	max:	< 1
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/15/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
02/20/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
03/18/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
04/15/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
05/22/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
06/17/2024 00:00	SC	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
06/25/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
07/15/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
08/19/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
09/16/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
10/15/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
11/18/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
12/16/2024 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
# samples:	12	min:	< 1	
# detects:	0	max:	< 1	
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 1 (3-2-SR, 3B169)

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/02/2024	6.60	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
* 02/05/2024	6.28	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
* 03/04/2024	6.37	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
04/02/2024	6.72	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
05/06/2024	6.89	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
06/03/2024	6.62	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
07/02/2024	6.63	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
* 08/06/2024	0.77	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
09/03/2024	6.6	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
10/01/2024	6.63	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
11/04/2024	6.70	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
12/02/2024	6.57	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard

# samples:	12	min:	0.77
# detects:	12	max:	6.89
# non-detects:	0	avg:	6.12 (based on 12 numerical results)
# of Exceedences:	3		

Temperature(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
* 01/02/2024	15.2 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
02/05/2024	13.5 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
03/04/2024	15.0 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
04/02/2024	12.2 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
05/06/2024	13.3 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
06/03/2024	12.7 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
07/02/2024	15 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 08/06/2024	18.1 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 09/03/2024	17.5 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 10/01/2024	17.8 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 11/04/2024	17.8 degrees C	Temperature	Boys Rd - Well 1	<=15	AO
* 12/02/2024	16.8 degrees C	Temperature	Boys Rd - Well 1	<=15	AO

# samples:	12	min:	12.2 degrees C
# detects:	12	max:	18.1 degrees C

# non-detects:	0	avg:	15.4 degrees C (based on 12 numerical results)
# of Exceedences:	6		

Turbidity(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/02/2024	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
02/05/2024	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
03/04/2024	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
04/02/2024	0.084 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
05/06/2024	0.082 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
06/03/2024	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
07/02/2024	0.07 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
* 08/06/2024	0.56 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
* 09/03/2024	0.59 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
10/01/2024	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
11/04/2024	0.05 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
12/02/2024	0.07 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined

# samples:	12	min:	0.05 NTU
# detects:	12	max:	0.59 NTU
# non-detects:	0	avg:	0.160 NTU (based on 12 numerical results)
# of Exceedences:	2	95th percentile:	0.590 NTU

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 2 (3-3-SR, 3B16A)

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria		
02/12/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
04/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
05/13/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
06/10/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
07/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
* 08/13/2024 00:00	1.0 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
09/09/2024 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined



Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
10/08/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P User-Defined
11/12/2024 00:00 SC CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P User-Defined
12/09/2024 00:00 < 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P User-Defined

# samples:	9	min:	< 1 CFU/100ml
# detects:	1	max:	1.0 CFU/100ml
# non-detects:	8	Geometric Mean:	1.0 CFU/100ml (based on 1 numerical results)
# of Exceedences:	1		

pH(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/08/2024 6.59	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
* 02/12/2024 6.36	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
04/09/2024 6.73	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
05/13/2024 6.8	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
06/10/2024 6.74	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
07/09/2024 6.67	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
08/13/2024 6.53	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
09/09/2024 6.71	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
10/09/2024 6.74	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
11/12/2024 6.72	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard
12/09/2024 6.7	pH	Boys Rd - Well 2	>=6.5, <=8.5 Secondary Standard

# samples:	11	min:	6.36
# detects:	11	max:	6.8
# non-detects:	0	avg:	6.66 (based on 11 numerical results)
# of Exceedences:	1		

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/08/2024 15.5 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
* 02/12/2024 15.1 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
04/09/2024 12.2 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
05/13/2024 13.9 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
* 06/10/2024 15.2 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
* 07/09/2024 16.3 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
* 08/13/2024 17.3 degrees C	Temperature	Boys Rd - Well 2	<=15 AO
* 09/09/2024 20.3 degrees C	Temperature	Boys Rd - Well 2	<=15 AO



Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 10/09/2024	18.9 degrees C	Boys Rd - Well 2	<=15 AO
* 11/12/2024	17.2 degrees C	Boys Rd - Well 2	<=15 AO
12/09/2024	14.3 degrees C	Boys Rd - Well 2	<=15 AO
# samples:	11	min:	12.2 degrees C
# detects:	11	max:	20.3 degrees C
# non-detects:	0	avg:	16.0 degrees C (based on 11 numerical results)
# of Exceedences:	8		

Time(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/08/2024	1,155	Boys Rd - Well 2	
02/12/2024	1,130	Boys Rd - Well 2	
04/09/2024	1,042	Boys Rd - Well 2	
05/13/2024	1,100	Boys Rd - Well 2	
06/10/2024	845	Boys Rd - Well 2	
07/09/2024	830	Boys Rd - Well 2	
08/13/2024	1,155	Boys Rd - Well 2	
09/09/2024	1,004	Boys Rd - Well 2	
10/09/2024	1,200	Boys Rd - Well 2	
11/12/2024	1,200	Boys Rd - Well 2	
12/09/2024	1,215	Boys Rd - Well 2	
# samples:	11	min:	830
# detects:	11	max:	1,215
# non-detects:	0	avg:	1,080 (based on 11 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/12/2024 00:00	< 1	Boys Rd - Well 2	<=0, OG, P User-Defined
04/09/2024 00:00	< 1	Boys Rd - Well 2	<=0, OG, P User-Defined
05/13/2024 00:00	< 1	Boys Rd - Well 2	<=0, OG, P User-Defined
06/10/2024 00:00	< 1	Boys Rd - Well 2	<=0, OG, P User-Defined
* 07/09/2024 00:00	1	Boys Rd - Well 2	<=0, OG, P User-Defined
* 08/13/2024 00:00	6.3	Boys Rd - Well 2	<=0, OG, P User-Defined



Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
09/09/2024 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
10/08/2024 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
11/12/2024 00:00	SC	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
12/09/2024 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined

# samples:	9	min:	< 1
# detects:	2	max:	6.3
# non-detects:	7	Geometric Mean:	2.5 (based on 2 numerical results)
# of Exceedences:	2		

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/08/2024	0.09 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
02/12/2024	0.08 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
04/09/2024	0.084 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
05/13/2024	0.07 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
06/10/2024	0.08 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
07/09/2024	0.07 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
08/13/2024	0.06 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
09/09/2024	0.061 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
10/09/2024	0.14 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
11/12/2024	0.06 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
12/09/2024	0.08 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined

# samples:	11	min:	0.06 NTU
# detects:	11	max:	0.14 NTU
# non-detects:	0	avg:	0.080 NTU (based on 11 numerical results)
# of Exceedences:	0	95th percentile:	0.140 NTU

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 3 (3-4-SR, 3B16B)

1,1,1-Trichloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	1,1,1-Trichloroethane	Boys Rd - Well 3	<=0.2	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L



# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2,2-Tetrachloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.5 ug/L	1,1,2,2-Tetrachloroethane	Boys Rd - Well 3	

# samples:	1	min:	< 0.5 ug/L
# detects:	0	max:	< 0.5 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0010 mg/L	1,1,2-Trichloroethane	Boys Rd - Well 3	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1-Dichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 1.0 ug/L	1,1-Dichloroethane	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1-Dichloroethylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0010 mg/L	1,1-Dichloroethylene	Boys Rd - Well 3	<=0.007 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0005 mg/L	1,2-Dichlorobenzene	Boys Rd - Well 3	<=0.6 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0010 mg/L	1,2-Dichloroethane	Boys Rd - Well 3	<=0.003 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichloropropane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0010 mg/L	1,2-Dichloropropane	Boys Rd - Well 3	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 1.0 ug/L	1,3-Dichlorobenzene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichloropropene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 1.0 ug/L	1,3-Dichloropropene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,4-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0010 mg/L	1,4-Dichlorobenzene	Boys Rd - Well 3	<=0.075 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



1-Methylnaphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.100 ug/L	1-Methylnaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.50 ug/L	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.00050 mg/L	2,3,4,6-Tetrachlorop henol	Boys Rd - Well 3	<=0.001 AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.50 ug/L	2,3,4-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,5-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.50 ug/L	2,3,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)



of Exceedences: 0

Measurement Name	Sampling Point Name	Criteria
2,3,6-Trichlorophenol(Lab Data Transfer)		
07/29/2024 13:48	< 0.50 ug/L	2,3,6-Trichlorophenol Boys Rd - Well 3

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
2,3-Dichlorophenol(Lab Data Transfer)		
07/29/2024 13:48	< 0.20 ug/L	2,3-Dichlorophenol Boys Rd - Well 3

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
2,4 + 2,5-Dichlorophenol(Lab Data Transfer)		
07/29/2024 13:48	< 0.20 ug/L	2,4 + 2,5-Dichlorophenol Boys Rd - Well 3

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
2,4,5-Trichlorophenol(Lab Data Transfer)		
07/29/2024 13:48	< 0.50 ug/L	2,4,5-Trichlorophenol Boys Rd - Well 3

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)		
07/29/2024 13:48	< 0.10 ug/L	2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T Boys Rd - Well 3

# samples:	1	min:	< 0.10 ug/L
------------	---	------	-------------



# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.00050 mg/L	2,4,6-Trichlorophenol	Boys Rd - Well 3	<=0.002 AO (MAC is 0.005 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.00010 mg/L	2,4-Dichlorophenoxy acetic acid / 2,4-D	Boys Rd - Well 3	<=0.07 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,6-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.20 ug/L	2,6-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chloronaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.100 ug/L	2-Chloronaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.10 ug/L	2-Chlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	2-methyl-4-chlorophenoxyacetic acid / MCPA	Boys Rd - Well 3	

# samples:	1	min:	< 0.02 ug/L
# detects:	0	max:	< 0.02 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	2-Methylnaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	3 and 4-Chlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	3,4,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.20 ug/L	3,4-Dichlorophenol	Boys Rd - Well 3	
# samples:	1	min:	< 0.20 ug/L	
# detects:	0	max:	< 0.20 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

3,5-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.50 ug/L	3,5-Dichlorophenol	Boys Rd - Well 3	
# samples:	1	min:	< 0.50 ug/L	
# detects:	0	max:	< 0.50 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.50 ug/L	4-Chloro-3-methylphenol (Parachlorometacresol)	Boys Rd - Well 3	
# samples:	1	min:	< 0.50 ug/L	
# detects:	0	max:	< 0.50 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Acenaphthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Acenaphthene	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Acenaphthylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.200 ug/L	Acenaphthylene	Boys Rd - Well 3	
# samples:	1	min:	< 0.200 ug/L	
# detects:	0	max:	< 0.200 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Acridine(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Acridine	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alachlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.000100 mg/L	Alachlor	Boys Rd - Well 3	<=0.002 MCL

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aldrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.006 ug/L	Aldrin	Boys Rd - Well 3	

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.010 ug/L	alpha-BHC	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aluminum (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0050 mg/L	Aluminum (total)	Boys Rd - Well 3	<=0.2 Secondary Standard

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.010 ug/L	Anthracene	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.00020 mg/L	Antimony (total)	Boys Rd - Well 3	<=0.006 MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1016(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Aroclor 1016	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Aroclor 1221	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Aroclor 1232	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Aroclor 1242	Boys Rd - Well 3	



# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Aroclor 1248	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Aroclor 1254	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Aroclor 1260	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1262(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Aroclor 1262	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1268(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Aroclor 1268	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.00050 mg/L	Arsenic (total)	Boys Rd - Well 3	<=0.010	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Atrazine + N-dealkylated metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000100 mg/L	Atrazine + N-dealkylated metabolites	Boys Rd - Well 3	<=0.005	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Azinphos-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Azinphos-methyl	Boys Rd - Well 3	<=0.02	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0050 mg/L	Barium (total)	Boys Rd - Well 3	<=2	MCL

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0005 mg/L	Benzene	Boys Rd - Well 3	<=0.001	MCL

# samples:	1	min:	< 0.0005 mg/L
------------	---	------	---------------

# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)anthracene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.010 ug/L	Benzo(a)anthracene	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)pyrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.000010 mg/L	Benzo(a)pyrene	Boys Rd - Well 3	<=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Benzo(b,j)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(g,h,i)perylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Benzo(g,h,i)perylene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(k)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Benzo(k)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
------------	---	------	--------------

# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.00010 mg/L	Beryllium (total)	Boys Rd - Well 3	<=0.004 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

beta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	beta-BHC	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.10 ug/L	Bismuth (total)	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.0500 mg/L	Boron (total)	Boys Rd - Well 3	<=5 MAC

# samples:	1	min:	< 0.0500 mg/L
# detects:	0	max:	< 0.0500 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromacil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.100 ug/L	Bromacil	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.005 mg/L	Bromate	Boys Rd - Well 3	<=0.01	MAC

# samples:	1	min:	< 0.005 mg/L
# detects:	0	max:	< 0.005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	Bromodichloromethane (dichlorobromomethane)	Boys Rd - Well 3	<=0.016	MAC

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 1.0 ug/L	Bromoform	Boys Rd - Well 3		

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoxynil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Bromoxynil	Boys Rd - Well 3	<=0.005	MAC
07/29/2024 13:48	< 0.00010 mg/L	Bromoxynil	Boys Rd - Well 3	<=0.005	MAC

# samples:	2	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.020 ug/L	Butachlor	Boys Rd - Well 3		

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000010 mg/L	Cadmium (total)	Boys Rd - Well 3	<=0.005	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	9,390 ug/L	Calcium (total)	Boys Rd - Well 3		

# samples:	1	min:	9,390 ug/L
# detects:	1	max:	9,390 ug/L
# non-detects:	0	avg:	9,390 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.100 ug/L	Captan	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Carbon tetrachloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0005 mg/L	Carbon tetrachloride	Boys Rd - Well 3	<=0.003	MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlordane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000050 mg/L	Chlordane	Boys Rd - Well 3	<=0.002	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	2.02 mg/L	Chloride	Boys Rd - Well 3	<=250	Secondary Standard

# samples:	1	min:	2.02 mg/L
# detects:	1	max:	2.02 mg/L
# non-detects:	0	avg:	2.02 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chlorobenzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	Chlorobenzene	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 2.0 ug/L	Chloroethane	Boys Rd - Well 3		

# samples:	1	min:	< 2.0 ug/L
# detects:	0	max:	< 2.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloroform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 1.0 ug/L	Chloroform	Boys Rd - Well 3		

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorothalonil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.050 ug/L	Chlorothalonil	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Chlorpyrifos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000010 mg/L	Chlorpyrifos	Boys Rd - Well 3	<=0.09	MAC

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.00050 mg/L	Chromium (total)	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chrysene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.050 ug/L	Chrysene	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

cis-1,2-Dichloroethylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	cis-1,2-Dichloroethylene	Boys Rd - Well 3	<=0.07	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.10 ug/L	Cobalt (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Copper (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	0.00518 mg/L	Copper (total)	Boys Rd - Well 3	<=1	Secondary Standard

# samples:	1	min:	0.00518 mg/L
# detects:	1	max:	0.00518 mg/L
# non-detects:	0	avg:	0.00518 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.100 ug/L	Cyanazine	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0020 mg/L	Cyanide (total)	Boys Rd - Well 3	<=0.2	MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.010 ug/L	DDT + metabolites	Boys Rd - Well 3		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

delta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.050 ug/L	delta-BHC	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Deltamethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.100 ug/L	Deltamethrin	Boys Rd - Well 3	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Diazinon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.000020 mg/L	Diazinon	Boys Rd - Well 3	<=0.02 MAC
# samples:	1	min:	< 0.000020 mg/L	
# detects:	0	max:	< 0.000020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibenzo(a,h)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.010 ug/L	Dibenzo(a,h)anthracene	Boys Rd - Well 3	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 1.0 ug/L	Dibromochloromethane (Chlorodibromomethane)	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromomethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 1.0 ug/L	Dibromomethane	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Dicamba(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.00010 mg/L	Dicamba	Boys Rd - Well 3	<=0.12 MAC

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichloromethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0030 mg/L	Dichloromethane	Boys Rd - Well 3	<=0.005 MCL

# samples:	1	min:	< 0.0030 mg/L
# detects:	0	max:	< 0.0030 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichlorvos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.100 ug/L	Dichlorvos	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diclofop-methyl(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.000100 mg/L	Diclofop-methyl	Boys Rd - Well 3	<=0.009 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.010 ug/L	Dieldrin	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Dimethoate	Boys Rd - Well 3	<=0.02	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dinoseb(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.00010 mg/L	Dinoseb	Boys Rd - Well 3	<=0.007	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0100 mg/L	Diquat	Boys Rd - Well 3	<=0.02	MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Disulfoton(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.100 ug/L	Disulfoton	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Diuron	Boys Rd - Well 3	<=0.15	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.010 ug/L	Endosulfan (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan sulfate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.050 ug/L	Endosulfan sulfate	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin aldehyde(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.020 ug/L	Endrin aldehyde	Boys Rd - Well 3	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin ketone(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.020 ug/L	Endrin ketone	Boys Rd - Well 3	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.000020 mg/L	Endrin	Boys Rd - Well 3	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Ethylbenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.0010 mg/L	Ethylbenzene	Boys Rd - Well 3	<=0.7 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fenchlorphos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.100 ug/L	Fenchlorphos	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.030 ug/L	Fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.030 ug/L
# detects:	0	max:	< 0.030 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluorene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Fluorene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.10 mg/L	Fluoride	Boys Rd - Well 3	<=4.0 MCL

# samples:	1	min:	< 0.10 mg/L
# detects:	0	max:	< 0.10 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 mg/L	Glyphosate	Boys Rd - Well 3	<=0.7 MCL

# samples:	1	min:	< 0.050 mg/L
# detects:	0	max:	< 0.050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Hardness (total, as CaCO3)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	27.3 mg/L	Hardness (total, as CaCO3)	Boys Rd - Well 3	

# samples:	1	min:	27.3 mg/L
# detects:	1	max:	27.3 mg/L
# non-detects:	0	avg:	27.3 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Heptachlor epoxide(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.000010 mg/L	Heptachlor epoxide	Boys Rd - Well 3	<=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.000010 mg/L	Heptachlor	Boys Rd - Well 3	<=0.0004 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.050 ug/L	Indeno(1,2,3-c,d)pyrene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.01 mg/L	Iron (total)	Boys Rd - Well 3	<=0.3 Secondary Standard

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Lead (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	0.00040 mg/L	Lead (total)	Boys Rd - Well 3	<=0.015	MCL

# samples:	1	min:	0.00040 mg/L
# detects:	1	max:	0.00040 mg/L
# non-detects:	0	avg:	0.00040 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000050 mg/L	Lindane	Boys Rd - Well 3	<=0.0002	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Linuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.050 ug/L	Linuron	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lithium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.10 ug/L	Lithium (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	937 ug/L	Magnesium (total)	Boys Rd - Well 3		

# samples:	1	min:	937 ug/L
# detects:	1	max:	937 ug/L
# non-detects:	0	avg:	937 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000100 mg/L	Malathion	Boys Rd - Well 3	<=0.19	MAC



# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Manganese (total)	Boys Rd - Well 3	<=0.05

07/29/2024 13:48 < 0.00020 mg/L

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Mercury (total)	Boys Rd - Well 3	<=0.002

07/29/2024 13:48 < 0.000010 mg/L

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methoxychlor	Boys Rd - Well 3	<=0.04

07/29/2024 13:48 < 0.000050 mg/L

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methyl parathion	Boys Rd - Well 3	

07/29/2024 13:48 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methyl tert-butyl ether / MTBE	Boys Rd - Well 3	

07/29/2024 13:48 < 1.0 ug/L

# samples:	1	min:	< 1.0 ug/L
------------	---	------	------------

# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000100 mg/L	Metolachlor	Boys Rd - Well 3	<=0.05	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Metribuzin	Boys Rd - Well 3	<=0.08	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.10 ug/L	Molybdenum (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.200 ug/L	Naphthalene	Boys Rd - Well 3		

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.00040 mg/L	Nickel (total)	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	0.084 mg/L	Nitrate (as N)	Boys Rd - Well 3	<=10	MCL

# samples:	1	min:	0.084 mg/L
# detects:	1	max:	0.084 mg/L
# non-detects:	0	avg:	0.084 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	0.29 mg/L	Nitrilotriacetic acid / NTA	Boys Rd - Well 3	<=0.4	MAC

# samples:	1	min:	0.29 mg/L
# detects:	1	max:	0.29 mg/L
# non-detects:	0	avg:	0.29 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0050 mg/L	Paraquat	Boys Rd - Well 3	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.100 ug/L	Parathion	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Pentachloronitrobenzene / PCNB	Boys Rd - Well 3	
07/29/2024 13:48	< 0.100 ug/L	
# samples:	1	min: < 0.100 ug/L
# detects:	0	max: < 0.100 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Pentachlorophenol / PCP(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Pentachlorophenol / PCP	Boys Rd - Well 3	<=0.001 MCL
07/29/2024 13:48	< 0.00050 mg/L	
# samples:	1	min: < 0.00050 mg/L
# detects:	0	max: < 0.00050 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Permethrin(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Permethrin	Boys Rd - Well 3	
07/29/2024 13:48	< 0.010 ug/L	
# samples:	1	min: < 0.010 ug/L
# detects:	0	max: < 0.010 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

pH(Inline Instrument)

Measurement Name	Sampling Point Name	Criteria
pH	Boys Rd - Well 3	>=6.5, <=8.5 Secondary Standard
01/15/2024	6.62	
* 02/20/2024	6.28	>=6.5, <=8.5 Secondary Standard
03/18/2024	6.63	>=6.5, <=8.5 Secondary Standard
* 04/15/2024	6.44	>=6.5, <=8.5 Secondary Standard
05/21/2024	6.51	>=6.5, <=8.5 Secondary Standard
* 06/17/2024	6.4	>=6.5, <=8.5 Secondary Standard
* 07/17/2024	6.42	>=6.5, <=8.5 Secondary Standard
* 08/19/2024	6.36	>=6.5, <=8.5 Secondary Standard
09/16/2024	6.55	>=6.5, <=8.5 Secondary Standard
10/15/2024	6.65	>=6.5, <=8.5 Secondary Standard



pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
11/18/2024	6.50	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
* 12/16/2024	6.30	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard

# samples:	12	min:	6.28
# detects:	12	max:	6.65
# non-detects:	0	avg:	6.47 (based on 12 numerical results)
# of Exceedences:	6		

pH(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	6.65	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard

# samples:	1	min:	6.65
# detects:	1	max:	6.65
# non-detects:	0	avg:	6.65 (based on 1 numerical results)
# of Exceedences:	0		

Phenanthrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.100 ug/L	Phenanthrene	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phorate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000100 mg/L	Phorate	Boys Rd - Well 3	<=0.002	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Picloram(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.00010 mg/L	Picloram	Boys Rd - Well 3	<=0.5	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer) **Measurement Name** **Sampling Point Name** **Criteria**

07/29/2024 13:48	< 0.150 ug/L	Polychlorinated Biphenyls / PCBs (as arochlor total)	Boys Rd - Well 3	
# samples:	1	min:	< 0.150 ug/L	
# detects:	0	max:	< 0.150 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Potassium (total)(Lab Data Transfer) **Measurement Name** **Sampling Point Name** **Criteria**

07/29/2024 13:48	220 ug/L	Potassium (total)	Boys Rd - Well 3	
# samples:	1	min:	220 ug/L	
# detects:	1	max:	220 ug/L	
# non-detects:	0	avg:	220 ug/L (based on 1 numerical results)	
# of Exceedences:	0			

Prometon(Lab Data Transfer) **Measurement Name** **Sampling Point Name** **Criteria**

07/29/2024 13:48	< 0.300 ug/L	Prometon	Boys Rd - Well 3	
# samples:	1	min:	< 0.300 ug/L	
# detects:	0	max:	< 0.300 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Prometryn(Lab Data Transfer) **Measurement Name** **Sampling Point Name** **Criteria**

07/29/2024 13:48	< 0.100 ug/L	Prometryn	Boys Rd - Well 3	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Pyrene(Lab Data Transfer) **Measurement Name** **Sampling Point Name** **Criteria**

07/29/2024 13:48	< 0.020 ug/L	Pyrene	Boys Rd - Well 3	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			



Quinoline(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.050 ug/L	Quinoline	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L		
# detects:	0	max:	< 0.050 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Selenium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.00050 mg/L	Selenium (total)	Boys Rd - Well 3	<=0.05	MCL

# samples:	1	min:	< 0.00050 mg/L		
# detects:	0	max:	< 0.00050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Silicon (total, as Si)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	2,800 ug/L	Silicon (total, as Si)	Boys Rd - Well 3		

# samples:	1	min:	2,800 ug/L		
# detects:	1	max:	2,800 ug/L		
# non-detects:	0	avg:	2,800 ug/L (based on 1 numerical results)		
# of Exceedences:	0				

Silver (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000050 mg/L	Silver (total)	Boys Rd - Well 3	<=0.1	Secondary Standard

# samples:	1	min:	< 0.000050 mg/L		
# detects:	0	max:	< 0.000050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Simazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Simazine	Boys Rd - Well 3	<=0.004	MCL

# samples:	1	min:	< 0.000200 mg/L		
# detects:	0	max:	< 0.000200 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Sodium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	1.9 mg/L	Sodium (total)	Boys Rd - Well 3	<=160	MCL

# samples:	1	min:	1.9 mg/L
# detects:	1	max:	1.9 mg/L
# non-detects:	0	avg:	1.9 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	27.9 ug/L	Strontium (total)	Boys Rd - Well 3	

# samples:	1	min:	27.9 ug/L
# detects:	1	max:	27.9 ug/L
# non-detects:	0	avg:	27.9 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Styrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.0010 mg/L	Styrene	Boys Rd - Well 3	<=0.1 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.100 ug/L	Sulfotep	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 3,000 ug/L	Sulfur (total)	Boys Rd - Well 3	

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	1.6 mg/L	Sulphate	Boys Rd - Well 3	<=250 Secondary Standard

# samples:	1	min:	1.6 mg/L
# detects:	1	max:	1.6 mg/L



# non-detects:	0	avg:	1.6 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.020 mg/L	Sulphide (total, as S)	Boys Rd - Well 3	

# samples:	1	min:	< 0.020 mg/L
# detects:	0	max:	< 0.020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tebuthiuron(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.200 ug/L	Tebuthiuron	Boys Rd - Well 3	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temephos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.500 ug/L	Temephos	Boys Rd - Well 3	

# samples:	1	min:	< 0.500 ug/L
# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/15/2024 15.8 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
02/20/2024 14.9 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 03/18/2024 15.2 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
04/15/2024 12.9 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
05/21/2024 14.0 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
06/17/2024 14.8 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 07/17/2024 15.8 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 08/19/2024 16.8 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 09/16/2024 19.7 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 10/15/2024 15.4 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 11/18/2024 16.7 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 12/16/2024 16.4 degrees C	Temperature	Boys Rd - Well 3	<=15 AO



# samples:	12	min:	12.9 degrees C
# detects:	12	max:	19.7 degrees C
# non-detects:	0	avg:	15.7 degrees C (based on 12 numerical results)
# of Exceedences:	8		

Terbufos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000100 mg/L	Terbufos	Boys Rd - Well 3	<=0.001	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tetrachloroethylene / PCE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	Tetrachloroethylene / PCE	Boys Rd - Well 3	<=0.003	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Thallium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000020 mg/L	Thallium (total)	Boys Rd - Well 3	<=0.002	MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Time(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria
01/15/2024	950	Time	Boys Rd - Well 3	
02/20/2024	1,200	Time	Boys Rd - Well 3	
03/18/2024	1,140	Time	Boys Rd - Well 3	
04/15/2024	1,055	Time	Boys Rd - Well 3	
05/21/2024	1,040	Time	Boys Rd - Well 3	
06/17/2024	900	Time	Boys Rd - Well 3	
07/17/2024	815	Time	Boys Rd - Well 3	
08/19/2024	1,100	Time	Boys Rd - Well 3	
09/16/2024	1,300	Time	Boys Rd - Well 3	
10/15/2024	1,000	Time	Boys Rd - Well 3	

Time(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/18/2024	930	Time	Boys Rd - Well 3
12/16/2024	1,200	Time	Boys Rd - Well 3

# samples:	12	min:	815
# detects:	12	max:	1,300
# non-detects:	0	avg:	1,053 (based on 12 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.20 ug/L	Tin (total)	Boys Rd - Well 3

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 5.0 ug/L	Titanium (total)	Boys Rd - Well 3

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Toluene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.0010 mg/L	Toluene	Boys Rd - Well 3

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

trans-1,2-Dichloroethylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48	< 0.0010 mg/L	trans-1,2-Dichloroethylene	Boys Rd - Well 3

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.100 ug/L	Triallate	Boys Rd - Well 3		
# samples:	1	min:	< 0.100 ug/L		
# detects:	0	max:	< 0.100 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Trichloroethylene / TCE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	Trichloroethylene / TCE	Boys Rd - Well 3	<=0.003	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Trichlorofluoromethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 1.0 ug/L	Trichlorofluoromethane	Boys Rd - Well 3		
# samples:	1	min:	< 1.0 ug/L		
# detects:	0	max:	< 1.0 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Trifluralin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000200 mg/L	Trifluralin	Boys Rd - Well 3	<=0.045	MAC
# samples:	1	min:	< 0.000200 mg/L		
# detects:	0	max:	< 0.000200 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/15/2024	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
02/20/2024	0.08 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
03/18/2024	0.074 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
04/15/2024	0.084 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
05/21/2024	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
06/17/2024	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
07/17/2024	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined



Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
08/19/2024	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
09/16/2024	0.053 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
10/15/2024	0.05 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
11/18/2024	0.06 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
12/16/2024	0.07 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined

# samples:	12	min:	0.05 NTU
# detects:	12	max:	0.084 NTU
# non-detects:	0	avg:	0.068 NTU (based on 12 numerical results)
# of Exceedences:	0	95th percentile:	0.084 NTU

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.000020 mg/L	Uranium (total)	Boys Rd - Well 3	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 5.0 ug/L	Vanadium (total)	Boys Rd - Well 3		

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vinyl chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0010 mg/L	Vinyl chloride	Boys Rd - Well 3	<=0.001	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Xylenes (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/29/2024 13:48	< 0.0020 mg/L	Xylenes (total)	Boys Rd - Well 3	<=10	MCL

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Zinc (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 0.0060 mg/L	Zinc (total)	Boys Rd - Well 3	<=5 Secondary Standard

# samples:	1	min:	0.0060 mg/L
# detects:	1	max:	0.0060 mg/L
# non-detects:	0	avg:	0.0060 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/29/2024 13:48 < 0.10 ug/L	Zirconium (total)	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 5 (3-6-SR, 3B16D)

pH(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/22/2024 6.36	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
* 02/26/2024 6.37	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
* 03/26/2024 6.41	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
* 04/22/2024 6.45	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
05/27/2024 6.75	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
06/24/2024 6.68	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
* 07/23/2024 6.43	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
08/26/2024 6.58	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
09/23/2024 6.62	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
10/22/2024 6.65	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard
11/25/2024 6.93	pH	Boys Rd - Well 5	>=6.5, <=8.5 Secondary Standard

# samples:	11	min:	6.36
# detects:	11	max:	6.93
# non-detects:	0	avg:	6.57 (based on 11 numerical results)



of Exceedences: 5

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/22/2024	15.9 degrees C	Boys Rd - Well 5	<=15 AO
* 02/26/2024	15.1 degrees C	Boys Rd - Well 5	<=15 AO
03/26/2024	14.2 degrees C	Boys Rd - Well 5	<=15 AO
04/22/2024	14.3 degrees C	Boys Rd - Well 5	<=15 AO
05/27/2024	12.6 degrees C	Boys Rd - Well 5	<=15 AO
06/24/2024	14.6 degrees C	Boys Rd - Well 5	<=15 AO
* 07/23/2024	15.7 degrees C	Boys Rd - Well 5	<=15 AO
* 08/26/2024	17.1 degrees C	Boys Rd - Well 5	<=15 AO
* 09/23/2024	19.06 degrees C	Boys Rd - Well 5	<=15 AO
* 10/22/2024	18.1 degrees C	Boys Rd - Well 5	<=15 AO
11/25/2024	14.8 degrees C	Boys Rd - Well 5	<=15 AO

samples: 11 min: 12.6 degrees C
 # detects: 11 max: 19.06 degrees C
 # non-detects: 0 avg: 15.59 degrees C (based on 11 numerical results)
 # of Exceedences: 6

Time(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/22/2024	845	Boys Rd - Well 5	
02/26/2024	1,015	Boys Rd - Well 5	
03/26/2024	830	Boys Rd - Well 5	
04/22/2024	1,115	Boys Rd - Well 5	
05/27/2024	845	Boys Rd - Well 5	
06/24/2024	1,335	Boys Rd - Well 5	
07/23/2024	845	Boys Rd - Well 5	
08/26/2024	1,200	Boys Rd - Well 5	
09/23/2024	1,000	Boys Rd - Well 5	
10/22/2024	1,000	Boys Rd - Well 5	
11/25/2024	1,255	Boys Rd - Well 5	

samples: 11 min: 830
 # detects: 11 max: 1,335
 # non-detects: 0 avg: 1,026 (based on 11 numerical results)
 # of Exceedences: 0

Turbidity(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/22/2024	0.09 NTU	Boys Rd - Well 5	<=0.5 User-Defined
02/26/2024	0.08 NTU	Boys Rd - Well 5	<=0.5 User-Defined



Turbidity(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
03/26/2024	0.077 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
04/22/2024	0.088 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
05/27/2024	0.08 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
06/24/2024	0.08 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
07/23/2024	0.07 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
08/26/2024	0.06 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
09/23/2024	0.06 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
* 10/22/2024	2.07 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined
11/25/2024	0.08 NTU	Turbidity	Boys Rd - Well 5	<=0.5 User-Defined

# samples:	11	min:	0.06 NTU
# detects:	11	max:	2.07 NTU
# non-detects:	0	avg:	0.258 NTU (based on 11 numerical results)
# of Exceedences:	1	95th percentile:	2.070 NTU

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 < means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown
 * Indicates Criteria is exceeded

