

June 30, 2026

File: 5620-55

Island Health
Unit 202 – 6425 Norcross Road
Duncan, B.C.
V9L 6C5

Dear Environmental Health Officer,

**Re: Chemainus Water System Water Quality Report
Premises Number 1310823
Report for the Period Jan 1/25 to Dec 31/25**

Please find the Municipality of North Cowichan's Water quality report for the Chemainus Water System attached.

Sincerely,

Clay Reitsma
Director of Engineering
Clay.Reitsma@northcowichan.ca

cc Mike Brown, Manager of Utilities

1 Operator Information

Name	Neil Gailey, Utilities Foreperson
Phone	250-746-3152
Email	neil.gailey@northcowichan.ca

2 System Description

The Chemainus water system is supplied from the wells along the Chemainus River. The water is chlorinated at the well site prior to distribution. Water is then pumped from the well site into the Chemainus distribution system. Pumped well water in excess of the town's demand is delivered to two concrete reservoirs located on Copper Canyon Road.

3 Boil Advisories

None

4 Future Improvements

None proposed at this time

5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

6 Results

See below for the results of various water quality parameters.

Report Name: Chemainus, Water Quality Report

	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
January 2025	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,576	0.85	0.75	0.05
2	2,425	0.84	0.75	0.05
3	2,346	0.85	0.75	0.04
4	2,386	0.83	0.75	0.04
5	2,650	0.85	0.74	0.05
6	2,647	0.85	0.75	0.05
7	2,519	0.84	0.75	0.04
8	2,433	0.86	0.72	0.05
9	2,439	0.85	0.73	0.04
10	2,560	0.85	0.72	0.03
11	2,644	0.89	0.73	0.04
12	2,539	0.85	0.7	0.04
13	2,451	0.88	0.73	0.04
14	2,351	0.88	0.71	0.04
15	2,517	0.87	0.71	0.04
16	2,683	0.86	0.7	0.04
17	2,684	0.87	0.72	0.04
18	2,380	0.87	0.69	0.04
19	2,243	0.88	0.71	0.04
20	2,456	1.17	0.46	0.04
21	2,739	0.84	0.68	0.04
22	2,703	0.85	0.72	0.06
23	2,372	0.91	0.66	0.08
24	2,353	0.89	0.7	0.05
25	2,421	0.89	0.68	0.04
26	2,559	0.91	0.66	0.04
27	2,637	0.87	0.71	0.04
28	2,276	0.87	0.7	0.03
29	2,278	0.86	0.74	0.04
30	2,505	0.88	0.68	0.03
31	2,591	0.85	0.73	0.02
Average	2,496	0.87	0.71	0.04
Minimum	2,243	0.83	0.46	0.02
Maximum	2,739	1.17	0.75	0.08
Count	31	31	31	31
Total	77,363			
95 Percentile				0.07
Exceedences	0	0	0	0
Median	2,505	0.86	0.72	0.04

February 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,625	0.84	0.75	0.02
2	2,603	0.88	0.68	0.02
3	2,683	0.88	0.69	0.02
4	2,588	0.87	0.7	0.03
5	2,588	0.88	0.7	0.03
6	2,621	0.89	0.66	0.02
7	2,554	0.9	0.6	0.02
8	2,321	0.89	0.62	0.02
9	2,308	0.89	0.65	0.02
10	2,517	0.86	0.72	0.02
11	2,661	0.92	0.69	0.27
12	2,889	0.88	0.67	0.04
13	2,688	0.89	0.66	0.04
14	2,577	0.85	0.72	0.04
15	2,542	0.92	0.71	0.03
16	2,482	0.87	0.72	0.03
17	2,694	0.84	0.75	0.03
18	3,023	0.85	0.73	0.03
19	3,055	0.84	0.74	0.03
20	2,991	0.86	0.72	0.03
21	2,762	0.85	0.72	0.03
22	2,454	0.85	0.71	0.05
23	2,538	0.85	0.71	0.1
24	2,646	0.85	0.73	0.07
25	2,686	0.87	0.72	0.08
26	2,859	1.13	0.6	0.07
27	2,564	0.99	0.68	0.06
28	2,654	1.02	0.64	0.05

Average	2,649	0.89	0.69	0.05
Minimum	2,308	0.84	0.6	0.02
Maximum	3,055	1.13	0.75	0.27
Count	28	28	28	28
Total	74,173			
95 Percentile				0.19
Exceedences	0	0	0	0
Median	2,623	0.88	0.71	0.03

March 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,647	0.98	0.67	0.05
2	2,540	1.01	0.66	0.05
3	2,482	0.97	0.69	0.05
4	2,496	0.86	0.71	0.03
5	2,446	0.94	0.67	0.04
6	2,530	0.87	0.66	0.03
7	2,633	0.84	0.74	0.04
8	2,668	0.84	0.75	0.03
9	2,615	0.83	0.74	0.07
10	2,652	0.85	0.68	0.07
11	2,620	0.99	0.7	0.04
12	2,580	0.86	0.72	0.04
13	2,532	0.84	0.73	0.04
14	2,549	0.84	0.73	0.04
15	2,579	0.83	0.73	0.04
16	2,657	0.84	0.72	0.04
17	2,659	0.87	0.7	0.04
18	2,694	0.87	0.65	0.03
19	2,694	0.89	0.65	0.03
20	2,717	0.89	0.57	0.03
21	2,684	0.93	0.53	0.03
22	2,630	0.9	0.54	0.03
23	2,577	0.91	0.59	0.03
24	2,626	0.9	0.57	0.03
25	2,685	0.93	0.49	0.04
26	2,631	0.94	0.47	0.04
27	2,586	0.94	0.5	0.04
28	2,580	0.94	0.52	0.04
29	2,549	0.9	0.52	0.04
30	2,483	0.92	0.54	0.03
31	2,523	1.01	0.31	0.03

Average	2,598	0.90	0.63	0.04
Minimum	2,446	0.83	0.31	0.03
Maximum	2,717	1.01	0.75	0.07
Count	31	31	31	31
Total	80,544			
95 Percentile				0.07
Exceedences	0	0	0	0
Median	2,615	0.90	0.66	0.04

April 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,535	1.05	0.44	0.03
2	2,556	0.85	0.73	0.03
3	2,673	0.87	0.73	0.03
4	2,696	0.85	0.75	0.03
5	2,636	0.85	0.72	0.03
6	2,619	0.83	0.73	0.03
7	2,689	0.84	0.73	0.03
8	2,658	0.82	0.73	0.03
9	2,623	0.84	0.73	0.03
10	2,502	0.85	0.69	0.03
11	2,605	0.88	0.69	0.07
12	2,568	0.86	0.71	0.05
13	2,747	0.86	0.69	0.05
14	2,907	0.87	0.68	0.04
15	3,194	0.85	0.72	0.05
16	3,177	0.85	0.71	0.04
17	3,225	0.85	0.71	0.05
18	2,957	0.86	0.69	0.04
19	2,881	0.85	0.72	0.05
20	2,796	0.86	0.73	0.04
21	2,656	0.85	0.67	0.05
22	2,563	1.83	0	0.04
23	2,922	1.69	0	0.04
24	3,298	0.84	0.71	0.04
25	3,358	0.86	0.74	0.04
26	3,397	0.85	0.72	0.04
27	2,927	0.86	0.71	0.04
28	2,994	0.84	0.71	0.04
29	4,087	0.84	0.72	0.04
30	3,893	0.86	0.65	0.04

Average	2,911	0.92	0.66	0.04
Minimum	2,502	0.82	0	0.03
Maximum	4,087	1.83	0.75	0.07
Count	30	30	30	30
Total	87,339			
95 Percentile				0.06
Exceedences	0	0	0	0
Median	2,772	0.85	0.71	0.04

May 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,419	1.82	0	0.04
2	3,737	1.72	0	0.04
3	3,847	1.18	0.47	0.04
4	3,197	0.85	0.71	0.04
5	2,442	0.84	0.73	0.04
6	3,315	0.85	0.72	0.04
7	3,468	0.87	0.73	0.04
8	3,120	0.85	0.73	0.04
9	3,527	0.85	0.73	0.04
10	3,467	0.85	0.72	0.04
11	3,117	0.85	0.71	0.04
12	3,073	0.85	0.73	0.04
13	3,096	0.85	0.7	0.04
14	5,653	0.87	0.7	0.04
15	4,195	0.85	0.73	0.03
16	3,078	1.26	0.25	0.04
17	3,324	1.42	0.05	0.05
18	3,170	0.89	0.72	0.04
19	2,973	0.84	0.71	0.04
20	2,808	0.86	0.71	0.04
21	2,907	0.88	0.43	0.04
22	3,122	0.83	0.72	0.03
23	3,400	0.86	0.74	0.04
24	3,610	0.84	0.73	0.04
25	3,500	0.84	0.7	0.04
26	3,305	0.85	0.73	0.04
27	3,250	0.85	0.7	0.04
28	3,953	1.08	0.71	0.04
29	3,924	0.84	0.71	0.04
30	3,604	0.83	0.73	0.04
31	3,604	0.84	0.72	0.04

Average	3,426	0.96	0.62	0.04
Minimum	2,442	0.83	0	0.03
Maximum	5,653	1.82	0.74	0.05
Count	31	31	31	31
Total	106,205			
95 Percentile				0.04
Exceedences	0	0	0	0
Median	3,324	0.85	0.71	0.04

June 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,386	0.84	0.73	0.04
2	3,573	0.85	0.73	0.04
3	3,689	0.84	0.72	0.04
4	3,664	0.83	0.71	0.04
5	3,737	0.84	0.75	0.04
6	4,190	0.83	0.74	0.04
7	4,348	0.84	0.72	0.04
8	3,943	0.84	0.73	0.04
9	4,278	0.83	0.72	0.03
10	4,345	0.83	0.71	0.03
11	4,230	0.84	0.73	0.04
12	4,236	0.86	0.7	0.03
13	3,742	1.16	0.56	0.03
14	3,801	0.84	0.71	0.03
15	4,196	0.86	0.64	0.04
16	3,984	0.87	0.64	0.04
17	4,190	1.06	0.31	0.04
18	4,138	0.89	0.62	0.04
19	3,828	1.01	0.36	0.03
20	3,971	0.92	0.61	0.04
21	3,603	0.86	0.71	0.03
22	3,617	0.85	0.73	0.04
23	3,620	0.86	0.61	0.03
24	3,603	0.91	0.62	0.04
25	3,925	0.85	0.73	0.04
26	3,840	1.09	0.35	0.03
27	3,554	0.85	0.73	0.04
28	3,579	0.84	0.73	0.03
29	3,918	0.86	0.74	0.03
30	4,238	0.87	0.73	0.04

Average	3,899	0.88	0.66	0.04
Minimum	3,386	0.83	0.31	0.03
Maximum	4,348	1.16	0.75	0.04
Count	30	30	30	30
Total	116,966			
95 Percentile				0.04
Exceedences	0	0	0	0
Median	3,879	0.85	0.72	0.04

July 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,949	0.85	0.73	0.03
2	4,123	0.9	0.73	0.04
3	4,185	0.86	0.7	0.04
4	3,808	0.86	0.72	0.03
5	4,129	1.57	0	0.03
6	3,990	1.01	0.59	0.04
7	4,058	0.88	0.72	0.03
8	4,136	0.89	0.72	0.04
9	3,611	0.84	0.72	0.04
10	3,895	0.86	0.69	0.03
11	4,153	0.92	0.54	0.04
12	3,942	0.85	0.71	0.03
13	4,267	0.87	0.68	0.03
14	4,455	0.86	0.71	0.03
15	4,335	0.88	0.62	0.03
16	4,388	1.19	0.27	0.03
17	4,441	1.35	0.1	0.04
18	4,473	0.86	0.71	0.03
19	4,104	0.9	0.67	0.03
20	4,012	0.86	0.72	0.03
21	4,255	0.85	0.72	0.03
22	4,290	0.88	0.71	0.03
23	4,270	0.86	0.73	0.04
24	4,313	0.85	0.72	0.03
25	4,324	0.86	0.71	0.03
26	4,186	0.92	0.71	0.03
27	4,146	0.86	0.72	0.03
28	4,017	0.86	0.72	0.03
29	4,210	0.85	0.73	0.03
30	4,290	0.87	0.73	0.03
31	4,287	0.86	0.71	0.03

Average	4,163	0.92	0.64	0.03
Minimum	3,611	0.84	0	0.03
Maximum	4,473	1.57	0.73	0.04
Count	31	31	31	31
Total	129,042			
95 Percentile				0.04
Exceedences	0	0	0	0
Median	4,185	0.86	0.71	0.03

August 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	4,314	0.86	0.7	0.03
2	4,269	0.86	0.71	0.03
3	4,270	0.87	0.71	0.03
4	3,789	0.87	0.71	0.03
5	4,096	0.86	0.71	0.03
6	4,161	0.87	0.71	0.03
7	3,496	0.85	0.72	0.03
8	3,880	0.91	0.71	0.03
9	3,711	0.88	0.71	0.03
10	4,013	0.87	0.7	0.03
11	4,248	0.87	0.68	0.03
12	4,179	0.86	0.68	0.03
13	4,269	0.89	0.67	0.03
14	4,228	0.87	0.66	0.03
15	3,524	0.89	0.62	0.03
16	3,095	0.86	0.67	0.03
17	3,346	0.86	0.69	0.04
18	3,512	0.9	0.69	0.03
19	3,347	0.87	0.67	0.04
20	3,269	0.88	0.66	0.03
21	3,368	0.86	0.67	0.03
22	3,858	0.87	0.67	0.03
23	3,718	0.86	0.68	0.03
24	3,741	0.86	0.67	0.03
25	4,077	0.88	0.68	0.03
26	4,212	0.84	0.68	0.03
27	4,153	0.88	0.63	0.04
28	3,648	0.88	0.69	0.03
29	3,747	0.87	0.69	0.03
30	3,622	0.88	0.67	0.03
31	3,422	0.87	0.68	0.03

Average	3,825	0.87	0.68	0.03
Minimum	3,095	0.84	0.62	0.03
Maximum	4,314	0.91	0.72	0.04
Count	31	31	31	31
Total	118,582			
95 Percentile				0.04
Exceedences	0	0	0	0
Median	3,789	0.87	0.68	0.03

September 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,926	0.87	0.67	0.03
2	3,657	0.87	0.66	0.03
3	3,427	0.9	0.62	0.03
4	3,880	0.88	0.62	0.03
5	3,490	0.87	0.66	0.03
6	3,309	0.87	0.66	0.03
7	3,326	0.88	0.67	0.03
8	3,776	0.88	0.68	0.03
9	3,384	0.88	0.67	0.03
10	3,190	0.93	0.69	0.03
11	3,695	0.88	0.68	0.03
12	3,492	0.91	0.68	0.03
13	3,140	0.87	0.68	0.03
14	3,275	0.89	0.68	0.03
15	3,188	0.87	0.68	0.03
16	3,274	0.88	0.68	0.03
17	3,168	0.89	0.65	0.04
18	3,139	0.88	0.68	0.03
19	3,452	0.87	0.68	0.03
20	3,420	0.86	0.67	0.03
21	3,162	0.91	0.68	0.03
22	3,051	0.89	0.68	0.03
23	3,020	0.91	0.68	0.03
24	3,134	0.9	0.7	0.03
25	3,303	0.9	0.68	0.03
26	3,293	0.88	0.67	0.03
27	3,220	0.87	0.67	0.03
28	3,021	0.9	0.67	0.03
29	2,902	0.89	0.67	0.03
30	2,803	0.89	0.67	0.03

Average	3,317	0.89	0.67	0.03
Minimum	2,803	0.86	0.62	0.03
Maximum	3,926	0.93	0.7	0.04
Count	30	30	30	30
Total	99,517			
95 Percentile				0.03
Exceedences	0	0	0	0
Median	3,284	0.88	0.68	0.03

October 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,798	0.9	0.66	0.03
2	2,788	0.87	0.66	0.03
3	2,844	0.9	0.67	0.03
4	2,880	0.88	0.67	0.03
5	2,829	0.86	0.65	0.03
6	3,005	0.87	0.67	0.03
7	2,808	0.87	0.66	0.03
8	2,680	1.05	0.69	0.03
9	2,671	0.9	0.65	0.03
10	2,661	0.93	0.64	0.03
11	2,682	0.94	0.65	0.03
12	2,887	0.92	0.66	0.03
13	3,171	0.9	0.67	0.03
14	3,206	0.91	0.65	0.03
15	3,131	0.94	0.66	0.03
16	3,111	0.91	0.66	0.03
17	3,020	0.94	0.66	0.03
18	2,890	0.89	0.66	0.03
19	2,779	0.9	0.65	0.03
20	2,899	0.97	0.65	0.03
21	2,810	0.94	0.65	0.03
22	2,815	0.98	0.64	0.03
23	2,813	0.96	0.61	0.03
24	2,986	1.01	0.62	0.03
25	2,943	0.99	0.61	0.03
26	2,904	0.96	0.6	0.03
27	2,973	1.02	0.6	0.03
28	2,932	1.08	0.6	0.03
29	2,871	1.02	0.6	0.03
30	2,736	1	0.58	0.03
31	2,681	1.05	0.57	0.03

Average	2,878	0.94	0.64	0.03
Minimum	2,661	0.86	0.57	0.03
Maximum	3,206	1.08	0.69	0.03
Count	31	31	31	31
Total	89,204			
95 Percentile				0.03
Exceedences	0	0	0	0
Median	2,871	0.94	0.65	0.03

November 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,609	1.02	0.57	0.03
2	2,643	1.04	0.57	0.03
3	2,894	1.09	0.58	0.03
4	2,956	1.1	0.55	0.03
5	2,868	1.09	0.56	0.03
6	2,915	1.07	0.54	0.03
7	2,851	1.01	0.57	0.04
8	2,812	0.99	0.54	0.03
9	2,744	1.01	0.55	0.03
10	2,822	1.01	0.54	0.03
11	2,885	1.08	0.5	0.03
12	2,740	1.03	0.52	0.03
13	2,688	1.02	0.55	0.03
14	2,603	1.02	0.53	0.03
15	2,571	1.1	0.53	0.03
16	2,898	1	0.54	0.03
17	2,860	0.99	0.52	0.03
18	2,538	0.99	0.52	0.03
19	2,430	1.04	0.51	0.03
20	2,475	0.97	0.55	0.03
21	2,671	0.92	0.52	0.03
22	2,762	0.93	0.53	0.03
23	2,664	0.94	0.54	0.03
24	2,736	1.17	0.45	0.03
25	2,647	1.22	0.5	0.03
26	2,564	1.38	0	0.03
27	2,562	1.05	0.55	0.03
28	2,694	1.41	0	0.03
29	2,803	1.07	0.52	0.03
30	2,801	1.09	0.59	0.03

Average	2,724	1.06	0.50	0.03
Minimum	2,430	0.92	0	0.03
Maximum	2,956	1.41	0.59	0.04
Count	30	30	30	30
Total	81,706			
95 Percentile				0.03
Exceedences	0	0	0	0
Median	2,738	1.04	0.54	0.03

December 2025	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,868	1.04	0.56	0.03
2	2,927	1	0.54	0.03
3	2,894	0.98	0.56	0.03
4	2,764	1.03	0.57	0.03
5	2,703	0.97	0.56	0.03
6	2,686	0.99	0.27	0.03
7	2,684	0.95	0.56	0.03
8	2,769	1.01	0.58	0.03
9	2,774	0.93	0.25	0.03
10	2,791	0.96	0.53	0.03
11	2,895	0.95	0.57	0.03
12	2,930	0.96	0.55	0.04
13	2,913	0.98	0.57	0.03
14	2,892	0.98	0.57	0.03
15	2,910	1.03	0.6	0.03
16	2,908	1.01	0.56	0.04
17	2,902	1.01	0.57	0.05
18	2,899	1.13	0	0.04
19	2,874	0.98	0.58	0.04
20	2,877	0.99	0.56	0.03
21	2,547	0.94	0.56	0.03
22	2,604	0.94	0.47	0.03
23	2,764	1.04	0.58	0.03
24	2,729	1.03	0.58	0.03
25	2,586	1.07	0.5	0.03
26	2,896	1.05	0.57	0.03
27	2,560	1	0.61	0.03
28	2,633	1.06	0.6	0.03
29	2,828	1.03	0.59	0.03
30	2,576	1.01	0.57	0.03
31	2,711	1.02	0.6	0.03

Average	2,784	1.00	0.53	0.03
Minimum	2,547	0.93	0	0.03
Maximum	2,930	1.13	0.61	0.05
Count	31	31	31	31
Total	86,294			
95 Percentile				0.04
Exceedences	0	0	0	0
Median	2,791	1.00	0.57	0.03

* indicates Geometric Mean

** indicates Intraday Average

DISINFECTANTS

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/07/2025	0.69 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/15/2025	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/20/2025	0.71 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/29/2025	0.78 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/12/2025	0.78 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/18/2025	0.75 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/25/2025	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/05/2025	0.52 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/11/2025	0.77 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/17/2025	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/24/2025	0.70 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
04/08/2025	0.79 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
04/16/2025	0.70 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
04/22/2025	0.60 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
04/30/2025	0.62 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
05/05/2025	0.70 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
05/12/2025	0.74 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
05/27/2025	0.66 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
06/03/2025	0.76 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
06/10/2025	0.78 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
06/18/2025	0.86 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
06/25/2025	0.62 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/11/2025	0.73 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/15/2025	0.55 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/21/2025	0.60 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/29/2025	0.58 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/06/2025	0.71 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/11/2025	0.71 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/19/2025	0.58 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/30/2025	0.58 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/02/2025	0.76 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/09/2025	0.76 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/15/2025	0.61 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/23/2025	0.79 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/01/2025	0.88 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/08/2025	0.83 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
10/16/2025	0.88 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/20/2025	0.83 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/27/2025	0.74 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
11/04/2025	0.76 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
11/13/2025	0.76 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
11/19/2025	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/03/2025	0.74 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/08/2025	0.71 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/16/2025	0.75 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/22/2025	0.75 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined

# samples:	47	min:	0.52 mg/L
# detects:	47	max:	0.88 mg/L
# non-detects:	0	avg:	0.72 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.79 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/07/2025	0.83 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/15/2025	0.88 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/20/2025	0.68 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/29/2025	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/06/2025	0.77 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/14/2025	0.74 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/20/2025	0.68 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/24/2025	0.67 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/05/2025	0.35 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/11/2025	0.83 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/18/2025	0.81 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/24/2025	0.73 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/31/2025	0.76 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/08/2025	0.80 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/16/2025	0.82 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/23/2025	0.90 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/28/2025	0.68 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
05/05/2025	0.79 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
05/13/2025	0.76 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
05/26/2025	0.74 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/03/2025	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/10/2025	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
06/18/2025	0.85 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/25/2025	0.75 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
07/07/2025	0.70 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
07/16/2025	0.70 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
07/28/2025	0.60 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/06/2025	0.69 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/11/2025	0.70 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/19/2025	0.60 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/26/2025	0.62 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/03/2025	0.75 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/09/2025	0.80 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/15/2025	0.64 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/22/2025	0.74 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/01/2025	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/08/2025	0.73 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/16/2025	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/21/2025	0.81 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/28/2025	0.68 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/04/2025	0.74 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/13/2025	0.79 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/19/2025	0.70 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/25/2025	0.65 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
12/02/2025	0.70 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
12/17/2025	0.38 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined

# samples:	47	min:	0.35 mg/L
# detects:	47	max:	0.90 mg/L
# non-detects:	0	avg:	0.73 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/08/2025	0.72 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
01/17/2025	0.77 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
01/21/2025	0.71 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
01/29/2025	0.76 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
02/06/2025	0.58 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
02/18/2025	0.72 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
02/25/2025	0.54 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/03/2025	0.81 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/10/2025	0.81 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
03/18/2025	0.63 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/25/2025	0.62 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/07/2025	0.82 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/15/2025	0.76 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/24/2025	0.82 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/29/2025	0.79 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
05/16/2025	0.82 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
05/26/2025	0.73 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/02/2025	0.82 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/10/2025	0.78 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/19/2025	0.75 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/24/2025	0.79 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/11/2025	0.69 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/16/2025	0.81 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/22/2025	0.50 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/29/2025	0.77 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/05/2025	0.69 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/11/2025	0.77 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/19/2025	0.66 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/26/2025	0.66 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/03/2025	0.78 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/09/2025	0.81 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/15/2025	0.62 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/25/2025	0.75 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
10/01/2025	0.76 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
10/07/2025	0.69 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
10/28/2025	0.80 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/03/2025	0.76 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/13/2025	0.75 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/18/2025	0.62 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/25/2025	0.65 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
12/08/2025	0.74 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
12/16/2025	0.64 mg/L	Free Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined

# samples:	42	min:	0.50 mg/L
# detects:	42	max:	0.82 mg/L
# non-detects:	0	avg:	0.73 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/07/2025	0.82 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
01/15/2025	0.83 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
01/21/2025	0.68 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
01/29/2025	0.63 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/05/2025	0.71 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/14/2025	0.68 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/18/2025	0.78 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/24/2025	0.66 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/05/2025	0.89 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/10/2025	0.68 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/17/2025	0.70 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/24/2025	0.62 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/08/2025	0.73 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/14/2025	0.62 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/24/2025	0.71 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/28/2025	0.70 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
05/06/2025	0.75 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
05/13/2025	0.73 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
05/26/2025	0.59 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/03/2025	0.72 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/10/2025	0.75 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/18/2025	0.72 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/23/2025	0.61 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/09/2025	0.67 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/16/2025	0.47 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/22/2025	0.50 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/28/2025	0.70 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/05/2025	0.62 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/11/2025	0.65 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/19/2025	0.62 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/26/2025	0.49 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/03/2025	0.60 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/08/2025	0.72 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/15/2025	0.56 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/23/2025	0.70 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/01/2025	0.68 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/09/2025	0.67 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/21/2025	0.80 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/28/2025	0.75 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
11/04/2025	0.76 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
11/13/2025	0.72 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
11/18/2025	0.61 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
11/25/2025	0.67 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
12/01/2025	0.60 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
12/08/2025	0.64 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
12/16/2025	0.67 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined

# samples:	46	min:	0.47 mg/L
# detects:	46	max:	0.89 mg/L
# non-detects:	0	avg:	0.68 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/07/2025	0.73 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
01/15/2025	0.82 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
01/20/2025	0.54 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
01/29/2025	0.62 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
02/03/2025	0.71 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
02/14/2025	0.66 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
02/18/2025	0.69 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
02/25/2025	0.68 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
03/05/2025	0.52 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
03/10/2025	0.62 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
03/17/2025	0.56 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
04/09/2025	0.76 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
04/22/2025	0.63 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
04/30/2025	0.79 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
05/06/2025	0.64 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
05/27/2025	0.59 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/03/2025	0.69 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/10/2025	0.72 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/18/2025	0.65 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/25/2025	0.65 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
07/16/2025	0.58 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
07/21/2025	0.38 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
07/31/2025	0.41 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
08/06/2025	0.58 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
08/19/2025	0.40 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/02/2025	0.74 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
09/09/2025	0.39 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/15/2025	0.47 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/23/2025	0.63 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/01/2025	0.66 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/07/2025	0.62 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/21/2025	0.53 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/29/2025	0.59 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/04/2025	0.63 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/13/2025	0.63 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/19/2025	0.60 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/25/2025	0.60 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
12/03/2025	0.59 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
12/08/2025	0.54 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
12/17/2025	0.58 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4 User-Defined

# samples:	40	min:	0.38 mg/L
# detects:	40	max:	0.82 mg/L
# non-detects:	0	avg:	0.61 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/08/2025	0.82 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/15/2025	0.81 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/20/2025	0.84 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/29/2025	0.74 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/05/2025	0.60 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/14/2025	0.74 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/18/2025	0.68 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/25/2025	0.69 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/05/2025	0.80 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/10/2025	0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/17/2025	0.64 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/25/2025	0.71 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/08/2025	0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/16/2025	0.83 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/22/2025	0.71 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/29/2025	0.78 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/06/2025	0.76 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/26/2025	0.71 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/03/2025	0.71 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
06/11/2025	0.74 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/18/2025	0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/24/2025	0.78 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/11/2025	0.80 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/16/2025	0.71 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/21/2025	0.61 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/05/2025	0.72 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/11/2025	0.70 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/19/2025	0.57 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/30/2025	0.55 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
09/03/2025	0.76 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
09/09/2025	0.77 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
09/15/2025	0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
09/25/2025	0.70 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
10/01/2025	0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
10/09/2025	0.76 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
10/21/2025	0.64 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
10/28/2025	0.78 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
11/04/2025	0.76 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
11/13/2025	0.72 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
11/17/2025	0.64 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
11/25/2025	0.70 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
12/04/2025	0.73 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
12/08/2025	0.74 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
12/16/2025	0.62 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined

# samples:	44	min:	0.55 mg/L
# detects:	44	max:	0.84 mg/L
# non-detects:	0	avg:	0.71 mg/L (based on 44 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.40 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/06/2025	0.39 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/15/2025	0.36 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/21/2025	0.30 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/29/2025	0.46 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/05/2025	0.43 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/14/2025	0.33 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/19/2025	0.31 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
02/25/2025	0.30 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/03/2025	0.08 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/10/2025	0.42 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/18/2025	0.38 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/25/2025	0.36 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/07/2025	0.40 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/15/2025	0.37 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/22/2025	0.28 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/29/2025	0.28 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/05/2025	0.24 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/15/2025	0.31 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/26/2025	0.28 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/02/2025	0.27 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/10/2025	0.23 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/18/2025	0.33 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/24/2025	0.36 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/08/2025	0.08 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/16/2025	0.17 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/23/2025	0.07 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/01/2025	0.19 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/06/2025	0.08 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/11/2025	0.15 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 08/19/2025	0.03 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 08/26/2025	0.03 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
09/02/2025	0.20 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
09/09/2025	0.05 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
09/15/2025	0.12 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
09/25/2025	0.09 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/01/2025	0.18 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/07/2025	0.22 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/14/2025	0.37 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/20/2025	0.25 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/21/2025	0.27 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/28/2025	0.3 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/03/2025	0.28 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/13/2025	0.31 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/18/2025	0.25 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/25/2025	0.31 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/01/2025	0.52 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
12/16/2025	0.16 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/23/2025	0.16 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
# samples:	49	min:	0.03 mg/L	
# detects:	49	max:	0.52 mg/L	
# non-detects:	0	avg:	0.26 mg/L (based on 49 numerical results)	
# of Exceedences:	2			

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.42 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
01/07/2025	0.44 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
01/15/2025	0.52 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
01/21/2025	0.48 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
01/28/2025	0.91 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/06/2025	0.66 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/11/2025	0.55 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/19/2025	0.58 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/26/2025	0.54 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/05/2025	0.60 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/10/2025	0.59 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/18/2025	0.44 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/25/2025	0.34 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
04/09/2025	0.66 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
04/14/2025	0.62 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
04/24/2025	0.63 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
04/29/2025	0.53 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
05/06/2025	0.69 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/12/2025	0.66 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/26/2025	0.73 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/03/2025	0.69 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/10/2025	0.70 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/18/2025	0.73 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/25/2025	0.72 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/07/2025	0.57 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/15/2025	0.65 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/31/2025	0.7 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/02/2025	0.72 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/11/2025	0.65 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/19/2025	0.60 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/26/2025	0.54 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/03/2025	0.64 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/08/2025	0.69 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/15/2025	0.53 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/25/2025	0.71 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/09/2025	0.68 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/14/2025	0.64 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/23/2025	0.72 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined

Free Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
10/28/2025	0.63 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/04/2025	0.62 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/10/2025	0.60 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/17/2025	0.39 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/22/2025	0.57 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/08/2025	0.45 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/17/2025	0.39 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined

# samples:	45	min:	0.34 mg/L
# detects:	45	max:	0.91 mg/L
# non-detects:	0	avg:	0.60 mg/L (based on 45 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.73 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
01/07/2025	0.72 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
01/15/2025	0.74 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
01/20/2025	0.73 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
01/29/2025	0.76 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
02/12/2025	0.69 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
02/18/2025	0.77 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
02/25/2025	0.75 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
03/05/2025	0.49 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
03/11/2025	0.71 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
03/17/2025	0.66 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
03/24/2025	0.74 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
04/08/2025	0.70 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
04/16/2025	0.72 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
04/22/2025	0.81 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
04/30/2025	0.61 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
05/05/2025	0.81 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
05/12/2025	0.74 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
05/27/2025	0.72 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined
06/03/2025	0.81 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4	User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
06/10/2025	0.82 mg/L	Total Cl2	3483 Henry Rd
06/18/2025	0.76 mg/L	Total Cl2	3483 Henry Rd
06/25/2025	0.76 mg/L	Total Cl2	3483 Henry Rd
07/11/2025	0.76 mg/L	Total Cl2	3483 Henry Rd
07/15/2025	0.71 mg/L	Total Cl2	3483 Henry Rd
07/21/2025	0.63 mg/L	Total Cl2	3483 Henry Rd
07/29/2025	0.71 mg/L	Total Cl2	3483 Henry Rd
08/06/2025	0.73 mg/L	Total Cl2	3483 Henry Rd
08/11/2025	0.71 mg/L	Total Cl2	3483 Henry Rd
08/19/2025	0.67 mg/L	Total Cl2	3483 Henry Rd
08/30/2025	0.67 mg/L	Total Cl2	3483 Henry Rd
09/02/2025	0.77 mg/L	Total Cl2	3483 Henry Rd
09/09/2025	0.80 mg/L	Total Cl2	3483 Henry Rd
09/15/2025	0.67 mg/L	Total Cl2	3483 Henry Rd
09/23/2025	0.78 mg/L	Total Cl2	3483 Henry Rd
10/01/2025	0.83 mg/L	Total Cl2	3483 Henry Rd
10/08/2025	0.82 mg/L	Total Cl2	3483 Henry Rd
10/16/2025	1.01 mg/L	Total Cl2	3483 Henry Rd
10/20/2025	0.86 mg/L	Total Cl2	3483 Henry Rd
10/27/2025	0.78 mg/L	Total Cl2	3483 Henry Rd
11/04/2025	0.79 mg/L	Total Cl2	3483 Henry Rd
11/13/2025	0.77 mg/L	Total Cl2	3483 Henry Rd
11/19/2025	0.72 mg/L	Total Cl2	3483 Henry Rd
12/03/2025	0.72 mg/L	Total Cl2	3483 Henry Rd
12/08/2025	0.75 mg/L	Total Cl2	3483 Henry Rd
12/16/2025	0.68 mg/L	Total Cl2	3483 Henry Rd
12/22/2025	0.66 mg/L	Total Cl2	3483 Henry Rd

# samples:	47	min:	0.49 mg/L
# detects:	47	max:	1.01 mg/L
# non-detects:	0	avg:	0.74 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/02/2025	0.51 mg/L	Total Cl2	Chemainus Rd South EOL
01/07/2025	0.47 mg/L	Total Cl2	Chemainus Rd South EOL
01/15/2025	0.55 mg/L	Total Cl2	Chemainus Rd South EOL

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/21/2025	0.52 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/28/2025	0.76 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/06/2025	0.65 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/11/2025	0.56 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/19/2025	0.59 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/26/2025	0.56 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/05/2025	0.60 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/10/2025	0.65 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/18/2025	0.44 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/25/2025	0.36 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/09/2025	0.64 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/14/2025	0.63 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/24/2025	0.61 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/29/2025	0.55 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/06/2025	0.67 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/12/2025	0.72 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/26/2025	0.70 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/03/2025	0.75 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/10/2025	0.65 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/18/2025	0.67 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/25/2025	0.70 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
07/07/2025	0.59 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/15/2025	0.69 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/02/2025	0.46 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/11/2025	0.69 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/19/2025	0.61 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/26/2025	0.28 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/03/2025	0.67 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/08/2025	0.69 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/15/2025	0.57 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/25/2025	0.71 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/09/2025	0.74 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/14/2025	0.64 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/23/2025	0.75 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/28/2025	0.63 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/04/2025	0.65 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/10/2025	0.61 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/17/2025	0.44 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/22/2025	0.47 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/08/2025	0.57 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/17/2025	0.36 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
# samples:	44	min:	0.28 mg/L		
# detects:	44	max:	0.76 mg/L		

# non-detects:	0	avg:	0.60 mg/L (based on 44 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.43 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/06/2025	0.41 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/15/2025	0.33 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/21/2025	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/29/2025	0.46 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/05/2025	0.49 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/14/2025	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/19/2025	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/25/2025	0.35 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/03/2025	0.25 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/10/2025	0.43 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/18/2025	0.35 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/25/2025	0.42 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/07/2025	0.41 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/15/2025	0.41 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/22/2025	0.35 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/29/2025	0.35 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/05/2025	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/15/2025	0.44 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/26/2025	0.37 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/02/2025	0.26 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/10/2025	0.24 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/18/2025	0.25 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/24/2025	0.37 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/08/2025	0.26 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/16/2025	0.25 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/23/2025	0.16 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/01/2025	0.19 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/06/2025	0.15 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/11/2025	0.18 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/19/2025	0.05 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/26/2025	0.13 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/02/2025	0.17 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/09/2025	0.07 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/15/2025	0.18 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/25/2025	0.14 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
10/01/2025	0.20 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/07/2025	0.23 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/14/2025	0.39 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/20/2025	0.28 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/21/2025	0.27 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/28/2025	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/03/2025	0.32 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/13/2025	0.32 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/18/2025	0.30 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/25/2025	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/01/2025	0.46 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/16/2025	0.16 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/23/2025	0.12 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined

# samples:	49	min:	0.05 mg/L
# detects:	49	max:	0.49 mg/L
# non-detects:	0	avg:	0.29 mg/L (based on 49 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/08/2025	0.75 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/15/2025	0.82 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/20/2025	0.86 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/29/2025	0.53 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/05/2025	0.69 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/14/2025	0.78 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/18/2025	0.77 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/25/2025	0.79 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/05/2025	0.76 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/10/2025	0.71 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/17/2025	0.71 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/25/2025	0.76 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/08/2025	0.63 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/16/2025	0.75 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/22/2025	0.57 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/29/2025	0.66 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/06/2025	0.76 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/26/2025	0.75 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/03/2025	0.72 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/11/2025	0.70 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
06/18/2025	0.87 mg/L	Total Cl2	Mckay Rd PRV Vault
06/24/2025	0.80 mg/L	Total Cl2	Mckay Rd PRV Vault
07/11/2025	0.71 mg/L	Total Cl2	Mckay Rd PRV Vault
07/16/2025	0.72 mg/L	Total Cl2	Mckay Rd PRV Vault
07/21/2025	0.70 mg/L	Total Cl2	Mckay Rd PRV Vault
08/05/2025	0.84 mg/L	Total Cl2	Mckay Rd PRV Vault
08/11/2025	0.73 mg/L	Total Cl2	Mckay Rd PRV Vault
08/19/2025	0.60 mg/L	Total Cl2	Mckay Rd PRV Vault
08/30/2025	0.58 mg/L	Total Cl2	Mckay Rd PRV Vault
09/03/2025	0.77 mg/L	Total Cl2	Mckay Rd PRV Vault
09/09/2025	0.75 mg/L	Total Cl2	Mckay Rd PRV Vault
09/15/2025	0.69 mg/L	Total Cl2	Mckay Rd PRV Vault
09/25/2025	0.76 mg/L	Total Cl2	Mckay Rd PRV Vault
10/01/2025	0.79 mg/L	Total Cl2	Mckay Rd PRV Vault
10/09/2025	0.77 mg/L	Total Cl2	Mckay Rd PRV Vault
10/21/2025	0.77 mg/L	Total Cl2	Mckay Rd PRV Vault
10/28/2025	0.78 mg/L	Total Cl2	Mckay Rd PRV Vault
11/04/2025	0.79 mg/L	Total Cl2	Mckay Rd PRV Vault
11/13/2025	0.71 mg/L	Total Cl2	Mckay Rd PRV Vault
11/17/2025	0.61 mg/L	Total Cl2	Mckay Rd PRV Vault
11/25/2025	0.75 mg/L	Total Cl2	Mckay Rd PRV Vault
12/04/2025	0.64 mg/L	Total Cl2	Mckay Rd PRV Vault
12/08/2025	0.61 mg/L	Total Cl2	Mckay Rd PRV Vault
12/16/2025	0.64 mg/L	Total Cl2	Mckay Rd PRV Vault

# samples:	44	min:	0.53 mg/L
# detects:	44	max:	0.87 mg/L
# non-detects:	0	avg:	0.72 mg/L (based on 44 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/07/2025	0.76 mg/L	Total Cl2	10139 Island View Close
01/15/2025	0.81 mg/L	Total Cl2	10139 Island View Close
01/20/2025	0.57 mg/L	Total Cl2	10139 Island View Close
01/29/2025	0.71 mg/L	Total Cl2	10139 Island View Close
02/03/2025	0.60 mg/L	Total Cl2	10139 Island View Close
02/14/2025	0.68 mg/L	Total Cl2	10139 Island View Close
02/18/2025	0.70 mg/L	Total Cl2	10139 Island View Close
02/25/2025	0.54 mg/L	Total Cl2	10139 Island View Close
03/05/2025	0.65 mg/L	Total Cl2	10139 Island View Close

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
03/10/2025	0.62 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
03/17/2025	0.56 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
04/09/2025	0.62 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
04/22/2025	0.68 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
04/30/2025	0.75 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
05/06/2025	0.73 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
05/27/2025	0.66 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/03/2025	0.67 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/10/2025	0.72 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/18/2025	0.68 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
06/25/2025	0.62 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
07/16/2025	0.63 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
07/21/2025	0.40 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
07/31/2025	0.52 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
08/06/2025	0.61 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
08/19/2025	0.44 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/02/2025	0.78 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/09/2025	0.47 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/15/2025	0.43 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
09/23/2025	0.62 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/01/2025	0.63 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/07/2025	0.64 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/21/2025	0.60 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
10/29/2025	0.61 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/04/2025	0.64 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/13/2025	0.65 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/19/2025	0.60 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
11/25/2025	0.57 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
12/03/2025	0.58 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
12/08/2025	0.50 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined
12/17/2025	0.61 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4 User-Defined

# samples:	40	min:	0.40 mg/L
# detects:	40	max:	0.81 mg/L
# non-detects:	0	avg:	0.62 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/07/2025	0.80 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
01/15/2025	0.86 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/21/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
01/29/2025	0.73 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/05/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/14/2025	0.70 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/18/2025	0.74 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
02/24/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/05/2025	0.72 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/10/2025	0.69 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/17/2025	0.65 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
03/24/2025	0.73 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/08/2025	0.78 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/14/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/24/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
04/28/2025	0.76 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
05/06/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
05/13/2025	0.79 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
05/26/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/03/2025	0.73 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/10/2025	0.68 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/18/2025	0.71 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
06/23/2025	0.6 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/09/2025	0.55 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/16/2025	0.41 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/22/2025	0.59 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
07/28/2025	0.64 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/05/2025	0.70 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/11/2025	0.62 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/19/2025	0.64 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
08/26/2025	0.55 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/03/2025	0.61 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/08/2025	0.73 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/15/2025	0.59 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
09/23/2025	0.65 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/01/2025	0.72 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/09/2025	0.67 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/21/2025	0.78 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
10/28/2025	0.72 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
11/04/2025	0.74 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
11/13/2025	0.70 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
11/18/2025	0.65 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
11/25/2025	0.58 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
12/01/2025	0.61 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
12/08/2025	0.68 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
12/16/2025	0.57 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4 User-Defined
# samples:	46	min:	0.41 mg/L	
# detects:	46	max:	0.86 mg/L	
# non-detects:	0	avg:	0.68 mg/L (based on 46 numerical results)	
# of Exceedences:	0			

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/08/2025	0.75 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
01/17/2025	0.80 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
01/21/2025	0.74 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
01/29/2025	0.79 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
02/06/2025	0.67 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
02/18/2025	0.82 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
02/25/2025	0.65 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/03/2025	0.81 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/10/2025	0.78 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/18/2025	0.51 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
03/25/2025	0.69 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/07/2025	0.55 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/15/2025	0.78 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/24/2025	0.75 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
04/29/2025	0.75 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
05/16/2025	0.79 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
05/26/2025	0.81 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/02/2025	0.93 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/10/2025	0.81 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/19/2025	0.58 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
06/24/2025	0.78 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/11/2025	0.60 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/16/2025	0.76 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/22/2025	0.49 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
07/29/2025	0.71 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/05/2025	0.77 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/11/2025	0.78 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
08/19/2025	0.68 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
08/26/2025	0.69 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/03/2025	0.83 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/09/2025	0.75 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/15/2025	0.72 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
09/25/2025	0.76 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
10/01/2025	0.78 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
10/07/2025	0.75 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
10/28/2025	0.82 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/03/2025	0.80 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/13/2025	0.81 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/18/2025	0.71 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
11/25/2025	0.50 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
12/08/2025	0.70 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined
12/16/2025	0.68 mg/L	Total Cl2	3218 Channel Blvd	>=0.05, <=4 User-Defined

# samples:	42	min:	0.49 mg/L
# detects:	42	max:	0.93 mg/L
# non-detects:	0	avg:	0.73 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.78 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/07/2025	0.88 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/15/2025	0.90 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/20/2025	0.69 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
01/29/2025	0.82 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/06/2025	0.82 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/14/2025	0.77 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/20/2025	0.72 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
02/24/2025	0.74 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/05/2025	0.64 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/11/2025	0.78 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/18/2025	0.73 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/24/2025	0.69 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
03/31/2025	0.66 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/08/2025	0.78 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/16/2025	0.80 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/23/2025	0.96 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
04/28/2025	0.74 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
05/05/2025	0.79 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
05/13/2025	0.79 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
05/26/2025	0.70 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/03/2025	0.60 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/10/2025	0.76 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/18/2025	0.95 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
06/25/2025	0.75 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
07/07/2025	0.59 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
07/16/2025	0.72 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
07/28/2025	0.72 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/06/2025	0.73 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/11/2025	0.74 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/19/2025	0.62 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
08/26/2025	0.73 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/03/2025	0.80 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/09/2025	0.76 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/15/2025	0.69 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
09/22/2025	0.78 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/01/2025	0.84 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/08/2025	0.74 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/16/2025	0.86 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/21/2025	0.76 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
10/28/2025	0.73 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/04/2025	0.77 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/13/2025	0.81 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/19/2025	0.80 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
11/25/2025	0.68 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
12/02/2025	0.63 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined
12/17/2025	0.65 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4 User-Defined

# samples:	47	min:	0.59 mg/L
# detects:	47	max:	0.96 mg/L
# non-detects:	0	avg:	0.75 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
< means less than lower detection limit shown
> means greater than upper detection limit shown
« means detected & less than number shown
» means detected & greater than number shown

* Indicates Criteria is exceeded

DISINFECTANTS

Total Chloramines (as combined chlorine)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.0400 mg/L	Total Chloramines (as combined chlorine)	River Rd Reducer	<=3.0	MAC
# samples:	1	min:	< 0.0400 mg/L		
# detects:	0	max:	< 0.0400 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

INORGANIC

Aluminum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.0050 mg/L	Aluminum (total)	River Rd Reducer	<=0.2	Secondary Standard
# samples:	1	min:	< 0.0050 mg/L		
# detects:	0	max:	< 0.0050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Antimony (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00020 mg/L	Antimony (total)	River Rd Reducer	<=0.006	MCL
# samples:	1	min:	< 0.00020 mg/L		
# detects:	0	max:	< 0.00020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Arsenic (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00050 mg/L	Arsenic (total)	River Rd Reducer	<=0.010	MCL
# samples:	1	min:	< 0.00050 mg/L		
# detects:	0	max:	< 0.00050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Barium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	0.0089 mg/L	Barium (total)	River Rd Reducer	<=2	MCL
# samples:	1	min:	0.0089 mg/L		

# detects:	1	max:	0.0089 mg/L
# non-detects:	0	avg:	0.0089 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00010 mg/L	Beryllium (total)	River Rd Reducer	<=0.004	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00010 mg/L	Bismuth (total)	River Rd Reducer		

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.0500 mg/L	Boron (total)	River Rd Reducer	<=5	MAC

# samples:	1	min:	< 0.0500 mg/L
# detects:	0	max:	< 0.0500 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.005 mg/L	Bromate	River Rd Reducer	<=0.01	MAC

# samples:	1	min:	< 0.005 mg/L
# detects:	0	max:	< 0.005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000010 mg/L	Cadmium (total)	River Rd Reducer	<=0.005	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Calcium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	9.06 mg/L	Calcium (total)	River Rd Reducer	

# samples:	1	min:	9.06 mg/L
# detects:	1	max:	9.06 mg/L
# non-detects:	0	avg:	9.06 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	6.16 mg/L	Chloride	River Rd Reducer	<=250 Secondary Standard

# samples:	1	min:	6.16 mg/L
# detects:	1	max:	6.16 mg/L
# non-detects:	0	avg:	6.16 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.00050 mg/L	Chromium (total)	River Rd Reducer	<=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.00010 mg/L	Cobalt (total)	River Rd Reducer	

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	0.0136 mg/L	Copper (total)	River Rd Reducer	<=1 Secondary Standard

# samples:	1	min:	0.0136 mg/L
# detects:	1	max:	0.0136 mg/L
# non-detects:	0	avg:	0.0136 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.0020 mg/L	Cyanide (total)	River Rd Reducer	<=0.2	MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.10 mg/L	Fluoride	River Rd Reducer	<=4.0	MCL

# samples:	1	min:	< 0.10 mg/L
# detects:	0	max:	< 0.10 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.010 mg/L	Iron (total)	River Rd Reducer	<=0.3	Secondary Standard

# samples:	1	min:	< 0.010 mg/L
# detects:	0	max:	< 0.010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	0.00032 mg/L	Lead (total)	River Rd Reducer	<=0.015	MCL

# samples:	1	min:	0.00032 mg/L
# detects:	1	max:	0.00032 mg/L
# non-detects:	0	avg:	0.00032 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lithium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00010 mg/L	Lithium (total)	River Rd Reducer		

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	1.01 mg/L	Magnesium (total)	River Rd Reducer	

# samples:	1	min:	1.01 mg/L
# detects:	1	max:	1.01 mg/L
# non-detects:	0	avg:	1.01 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.00020 mg/L	Manganese (total)	River Rd Reducer	<=0.05 Secondary Standard

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.000010 mg/L	Mercury (total)	River Rd Reducer	<=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	0.00010 mg/L	Molybdenum (total)	River Rd Reducer	

# samples:	1	min:	0.00010 mg/L
# detects:	1	max:	0.00010 mg/L
# non-detects:	0	avg:	0.00010 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.00040 mg/L	Nickel (total)	River Rd Reducer	<=0.1 MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	0.046 mg/L	Nitrate (as N)	River Rd Reducer	<=10 MCL

# samples:	1	min:	0.046 mg/L
# detects:	1	max:	0.046 mg/L
# non-detects:	0	avg:	0.046 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 0.22 mg/L	Potassium (total)	River Rd Reducer	

# samples:	1	min:	0.22 mg/L
# detects:	1	max:	0.22 mg/L
# non-detects:	0	avg:	0.22 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.00050 mg/L	Selenium (total)	River Rd Reducer	<=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 3.1 mg/L	Silicon (total, as Si)	River Rd Reducer	

# samples:	1	min:	3.1 mg/L
# detects:	1	max:	3.1 mg/L
# non-detects:	0	avg:	3.1 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000050 mg/L	Silver (total)	River Rd Reducer	<=0.1 Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 3.17 mg/L	Sodium (total)	River Rd Reducer	<=160 MCL

# samples:	1	min:	3.17 mg/L
# detects:	1	max:	3.17 mg/L

# non-detects:	0	avg:	3.17 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	0.0326 mg/L	Strontium (total)	River Rd Reducer	

# samples:	1	min:	0.0326 mg/L
# detects:	1	max:	0.0326 mg/L
# non-detects:	0	avg:	0.0326 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 3.0 mg/L	Sulfur (total)	River Rd Reducer	

# samples:	1	min:	< 3.0 mg/L
# detects:	0	max:	< 3.0 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	2.7 mg/L	Sulphate	River Rd Reducer	<=250 Secondary Standard

# samples:	1	min:	2.7 mg/L
# detects:	1	max:	2.7 mg/L
# non-detects:	0	avg:	2.7 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.020 mg/L	Sulphide (total, as S)	River Rd Reducer	

# samples:	1	min:	< 0.020 mg/L
# detects:	0	max:	< 0.020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Thallium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.000020 mg/L	Thallium (total)	River Rd Reducer	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.00020 mg/L	Tin (total)	River Rd Reducer	
# samples:	1	min:	< 0.00020 mg/L	
# detects:	0	max:	< 0.00020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Titanium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.0050 mg/L	Titanium (total)	River Rd Reducer	
# samples:	1	min:	< 0.0050 mg/L	
# detects:	0	max:	< 0.0050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.0050 mg/L	Vanadium (total)	River Rd Reducer	
# samples:	1	min:	< 0.0050 mg/L	
# detects:	0	max:	< 0.0050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Zinc (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	0.0072 mg/L	Zinc (total)	River Rd Reducer	<=5 Secondary Standard
# samples:	1	min:	0.0072 mg/L	
# detects:	1	max:	0.0072 mg/L	
# non-detects:	0	avg:	0.0072 mg/L (based on 1 numerical results)	
# of Exceedences:	0			

Zirconium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.00010 mg/L	Zirconium (total)	River Rd Reducer	
# samples:	1	min:	< 0.00010 mg/L	
# detects:	0	max:	< 0.00010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

MICROORGANISMS

Heterotrophic Plate Count / HPC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 1 CFU/100ml	Heterotrophic Plate Count / HPC	River Rd Reducer	<=500	User-Defined
# samples:	1	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	1	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Iron Bacteria (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 1 CFU/ml	Iron Bacteria (counts)	River Rd Reducer	
# samples:	1	min:	< 1 CFU/ml	
# detects:	0	max:	< 1 CFU/ml	
# non-detects:	1	Geometric Mean:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

ORGANIC

1-Methylnaphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	1-Methylnaphthalene	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.50 ug/L	2,3,4,6 + 2,3,5,6-Tetrachlorophenol	River Rd Reducer	
# samples:	1	min:	< 0.50 ug/L	
# detects:	0	max:	< 0.50 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00050 mg/L	2,3,4,6-Tetrachlorophenol	River Rd Reducer	<=0.001	AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.50 ug/L	2,3,4-Trichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.50 ug/L	2,3,5-Trichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.50 ug/L	2,3,6-Trichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.20 ug/L	2,3-Dichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.20 ug/L	2,4 + 2,5-Dichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
------------	---	------	-------------

# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.50 ug/L	2,4,5-Trichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.10 ug/L	2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T	River Rd Reducer	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.00050 mg/L	2,4,6-Trichlorophenol	River Rd Reducer	<=0.002 AO (MAC is 0.005 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,6-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.20 ug/L	2,6-Dichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chloronaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	2-Chloronaphthalene	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.10 ug/L	2-Chlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.02 ug/L	2-methyl-4-chlorophe noxyacetic acid / MCPA	River Rd Reducer	

# samples:	1	min:	< 0.02 ug/L
# detects:	0	max:	< 0.02 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	2-Methylnaphthalene	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.10 ug/L	3 and 4-Chlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.50 ug/L	3,4,5-Trichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.20 ug/L	3,4-Dichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,5-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.20 ug/L	3,5-Dichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.50 ug/L	4-Chloro-3-methylphenol (Parachlorometacresol)	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acenaphthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Acenaphthene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Acenaphthylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.200 ug/L	Acenaphthylene	River Rd Reducer	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acridine(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.050 ug/L	Acridine	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aldrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.006 ug/L	Aldrin	River Rd Reducer	

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.010 ug/L	alpha-BHC	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.010 ug/L	Anthracene	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Atrazine + N-dealkylated metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---	--	------------------	---------------------	----------

08/18/2025 10:20	< 0.000100 mg/L	Atrazine + N-dealkylated metabolites	River Rd Reducer	<=0.005 MAC
------------------	-----------------	--------------------------------------	------------------	-------------

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Azinphos-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
------------------------------------	--	------------------	---------------------	----------

08/18/2025 10:20	< 0.000200 mg/L	Azinphos-methyl	River Rd Reducer	<=0.02 MAC
------------------	-----------------	-----------------	------------------	------------

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---------------------------------------	--	------------------	---------------------	----------

08/18/2025 10:20	< 0.010 ug/L	Benzo(a)anthracene	River Rd Reducer	
------------------	--------------	--------------------	------------------	--

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
-----------------------------------	--	------------------	---------------------	----------

08/18/2025 10:20	< 0.000010 mg/L	Benzo(a)pyrene	River Rd Reducer	<=0.0002 MCL
------------------	-----------------	----------------	------------------	--------------

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---	--	------------------	---------------------	----------

08/18/2025 10:20	< 0.050 ug/L	Benzo(b,j)fluoranthene	River Rd Reducer	
------------------	--------------	------------------------	------------------	--

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Benzo(g,h,i)perylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20		< 0.050 ug/L	Benzo(g,h,i)perylene	River Rd Reducer
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Benzo(k)fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Benzo(k)fluoranthene	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

beta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	beta-BHC	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Bromacil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	Bromacil	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.0010 mg/L	Bromodichloromethane (dichlorobromomethane)	River Rd Reducer	<=0.016 MAC

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoform(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 1.0 ug/L	Bromoform	River Rd Reducer	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoxynil(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000200 mg/L	Bromoxynil	River Rd Reducer	<=0.005 MAC
08/18/2025 10:20 < 0.00010 mg/L	Bromoxynil	River Rd Reducer	<=0.005 MAC

# samples:	2	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.020 ug/L	Butachlor	River Rd Reducer	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Captan	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloroform(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 1.0 ug/L	Chloroform	River Rd Reducer	

# samples:	1	min:	< 1.0 ug/L
------------	---	------	------------

# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorothalonil(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.050 ug/L	Chlorothalonil	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorpyrifos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000010 mg/L	Chlorpyrifos	River Rd Reducer	<=0.09 MAC

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chrysene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.050 ug/L	Chrysene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Cyanazine	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.010 ug/L	DDT + metabolites	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

delta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	delta-BHC	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Deltamethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	Deltamethrin	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Diazinon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.000020 mg/L	Diazinon	River Rd Reducer	<=0.02 MAC
# samples:	1	min:	< 0.000020 mg/L	
# detects:	0	max:	< 0.000020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibenzo(a,h)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.010 ug/L	Dibenzo(a,h)anthracene	River Rd Reducer	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 1.0 ug/L	Dibromochloromethane (Chlorodibromomethane)	River Rd Reducer	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dicamba(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.00010 mg/L	Dicamba	River Rd Reducer	<=0.12 MAC

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichlorvos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Dichlorvos	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diclofop-methyl(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000100 mg/L	Diclofop-methyl	River Rd Reducer	<=0.009 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.010 ug/L	Dieldrin	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000200 mg/L	Dimethoate	River Rd Reducer	<=0.02 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Disulfoton(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Disulfoton	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diuron(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000200 mg/L	Diuron	River Rd Reducer	<=0.15 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.010 ug/L	Endosulfan (total)	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan sulfate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.050 ug/L	Endosulfan sulfate	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin aldehyde(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.020 ug/L	Endrin aldehyde	River Rd Reducer	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin ketone(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.020 ug/L	Endrin ketone	River Rd Reducer	

# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fenchlorphos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	Fenchlorphos	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.030 ug/L	Fluoranthene	River Rd Reducer	

# samples:	1	min:	< 0.030 ug/L	
# detects:	0	max:	< 0.030 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluorene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Fluorene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Indeno(1,2,3-c,d)pyrene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Linuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Linuron	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.000100 mg/L	Malathion	River Rd Reducer	<=0.19 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	Methyl parathion	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.000100 mg/L	Metolachlor	River Rd Reducer	<=0.05 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.000200 mg/L	Metribuzin	River Rd Reducer	<=0.08 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.200 ug/L	Naphthalene	River Rd Reducer	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.20 mg/L	Nitrilotriacetic acid / NTA	River Rd Reducer	<=0.4 MAC

# samples:	1	min:	< 0.20 mg/L
# detects:	0	max:	< 0.20 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.0050 mg/L	Paraquat	River Rd Reducer	<=0.007 MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Parathion	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Pentachloronitrobenzene / PCNB	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachlorophenol / PCP(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00050 mg/L	Pentachlorophenol / PCP	River Rd Reducer	<=0.001	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Permethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.010 ug/L	Permethrin	River Rd Reducer		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phenanthrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.100 ug/L	Phenanthrene	River Rd Reducer		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phorate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000100 mg/L	Phorate	River Rd Reducer	<=0.002	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.300 ug/L	Prometon	River Rd Reducer		

# samples:	1	min:	< 0.300 ug/L
# detects:	0	max:	< 0.300 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometryn(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	Prometryn	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.020 ug/L	Pyrene	River Rd Reducer	

# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Quinoline(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Quinoline	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Sulfotep(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.100 ug/L	Sulfotep	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Tebuthiuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.200 ug/L	Tebuthiuron	River Rd Reducer	

# samples:	1	min:	< 0.200 ug/L	
# detects:	0	max:	< 0.200 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Temephos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.500 ug/L	Temephos	River Rd Reducer	

# samples:	1	min:	< 0.500 ug/L
# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Terbufos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000100 mg/L	Terbufos	River Rd Reducer	<=0.001 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.100 ug/L	Triallate	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trifluralin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000200 mg/L	Trifluralin	River Rd Reducer	<=0.045 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

PCBS

Aroclor 1016(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.050 ug/L	Aroclor 1016	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.050 ug/L	Aroclor 1221	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
------------	---	------	--------------

# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1232	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1242	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1248	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1254	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1260	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Aroclor 1262(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1262	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1268(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.050 ug/L	Aroclor 1268	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	< 0.150 ug/L	Polychlorinated Biphenyls / PCBs (as arochlor total)	River Rd Reducer	
# samples:	1	min:	< 0.150 ug/L	
# detects:	0	max:	< 0.150 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

PHYSICAL

Hardness (total, as CaCO3)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	26.8 mg/L	Hardness (total, as CaCO3)	River Rd Reducer	
# samples:	1	min:	26.8 mg/L	
# detects:	1	max:	26.8 mg/L	
# non-detects:	0	avg:	26.8 mg/L (based on 1 numerical results)	
# of Exceedences:	0			

pH(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20	7.48	pH	River Rd Reducer	>=6.5, <=8.5 Secondary Standard

# samples:	1	min:	7.48
# detects:	1	max:	7.48
# non-detects:	0	avg:	7.48 (based on 1 numerical results)
# of Exceedences:	0		

RADIONUCLIDES

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000020 mg/L	Uranium (total)	River Rd Reducer	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

SOCS

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00010 mg/L	2,4-Dichlorophenoxy acetic acid / 2,4-D	River Rd Reducer	<=0.07	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000100 mg/L	Alachlor	River Rd Reducer	<=0.002	MCL

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlordane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000050 mg/L	Chlordane	River Rd Reducer	<=0.002	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dinoseb(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.00010 mg/L	Dinoseb	River Rd Reducer	<=0.007	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.0100 mg/L	Diquat	River Rd Reducer	<=0.02	MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000020 mg/L	Endrin	River Rd Reducer	<=0.002	MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.050 mg/L	Glyphosate	River Rd Reducer	<=0.7	MCL

# samples:	1	min:	< 0.050 mg/L
# detects:	0	max:	< 0.050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor epoxide(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000010 mg/L	Heptachlor epoxide	River Rd Reducer	<=0.0002	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 10:20	< 0.000010 mg/L	Heptachlor	River Rd Reducer	<=0.0004	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000050 mg/L	Lindane	River Rd Reducer	<=0.0002 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methoxychlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000050 mg/L	Methoxychlor	River Rd Reducer	<=0.04 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Picloram(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.00010 mg/L	Picloram	River Rd Reducer	<=0.5 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Simazine(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 10:20 < 0.000200 mg/L	Simazine	River Rd Reducer	<=0.004 MCL

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 < means less than lower detection limit shown
 > means greater than upper detection limit shown

« means detected & less than number shown
» means detected & greater than number shown
* Indicates Criteria is exceeded

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/06/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
03/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
04/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
05/05/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
06/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
07/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
08/05/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
09/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
10/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
11/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
# samples:	12	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	12	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
02/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
03/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
04/22/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
06/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
08/19/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
09/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
10/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
11/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	10139 Island View Close	<=0, OG, P	User-Defined
# samples:	11	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
03/24/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
06/23/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
08/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
09/23/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
10/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
11/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined

# samples:	9	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
03/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
04/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
06/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
08/11/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
09/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined
10/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3218 Channel Blvd	<=0, OG, P	User-Defined

# samples:	8	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	8	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
02/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
03/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
04/22/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
06/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/19/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
09/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
10/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
11/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
# samples:	11	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
05/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
06/23/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
08/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
09/23/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
10/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
11/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
12/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
# samples:	9	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)		

of Exceedences: 0

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
02/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
03/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
06/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
08/19/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
09/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
10/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
11/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	3483 Henry Rd	<=0, OG, P	User-Defined

# samples:	10	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/13/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
05/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
08/11/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
09/08/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
# samples:	10	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/13/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
05/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
07/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
08/11/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
09/08/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	River Rd Reducer	<=0, OG, P	User-Defined

# samples:	11	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
02/18/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
03/17/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
06/18/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
07/21/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
08/19/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
09/15/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
10/20/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
11/17/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	3483 Henry Rd	<=0, OG, P User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/13/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P User-Defined
05/12/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
06/09/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
07/15/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
08/11/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
09/08/2025 00:00	SC	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	Chemainus Rd South EOL	<=0, OG, P	User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
02/18/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
03/17/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
04/22/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
06/18/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
08/19/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
09/15/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
10/20/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
11/17/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	Mckay Rd PRV Vault	<=0, OG, P	User-Defined

# samples:	11	min:	< 1
------------	----	------	-----

# detects:	0	max:	< 1
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/06/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
03/03/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
04/07/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
05/05/2025 00:00	SC	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
06/02/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
07/08/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
08/05/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
09/02/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
* 10/07/2025 00:00	29	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
11/03/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1	Total Coliforms (counts)	Bare Pt Rd Tank Farm	<=0, OG, P	User-Defined

# samples:	12	min:	< 1
# detects:	1	max:	29
# non-detects:	11	Geometric Mean:	29 (based on 1 numerical results)
# of Exceedences:	1		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
02/18/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
03/17/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
04/22/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
06/18/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
08/19/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
09/15/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
10/20/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
11/17/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	10139 Island View Close	<=0, OG, P	User-Defined

# samples:	11	min:	< 1
# detects:	0	max:	< 1
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
03/24/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
06/23/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
08/26/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
09/23/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
10/28/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
11/25/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1	Total Coliforms (counts)	Old Victoria Rd PRV	<=0, OG, P	User-Defined

# samples:	9	min:	< 1
# detects:	0	max:	< 1
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
03/03/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
04/07/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
06/02/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
08/11/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
09/03/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined
10/28/2025 00:00	< 1	Total Coliforms (counts)	3218 Channel Blvd	<=0, OG, P User-Defined

# samples:	8	min:	< 1
# detects:	0	max:	< 1
# non-detects:	8	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/13/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined
05/12/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined
06/09/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined
07/15/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/11/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P	User-Defined
09/08/2025 00:00	SC	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	River Rd Reducer	<=0, OG, P	User-Defined

# samples:	11	min:	< 1
# detects:	0	max:	< 1
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
05/26/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
06/23/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
08/26/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
09/23/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
10/28/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
11/25/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined
12/02/2025 00:00	< 1	Total Coliforms (counts)	Henry Rd Reducer	<=0, OG, P	User-Defined

# samples:	9	min:	< 1
# detects:	0	max:	< 1
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

*** Indicates Criteria is exceeded**