

June 30, 2026

File: 5630-55

Island Health
Unit 202 – 6425 Norcross Road
Duncan, B.C.
V9L 6C5

Dear Environmental Health Officer,

**Re: South End Water System Water Quality Report
Premises Number 1310818
Report for the Period Jan 1/25 to Dec 31/25**

Please find the Municipality of North Cowichan's Water quality report for the South-end Water System attached.

Sincerely,

Clay Reitsma
Director of Engineering
Clay.Reitsma@northcowichan.ca

cc: Mike Brown, Manager of Utilities

1 Operator Information

Contact Name	Neil Gailey Foreperson, Utilities
Phone	250-746-3152
Email	neil.gailey@northcowichan.ca



2 System Description

This is a groundwater supply. Water is pumped from the Boys Road wells and treated with U.V disinfection. In 2018, Vancouver Island Health Authority amended the operating certificate for the South End Water System and the Municipality is now required to chlorinate continuously to reduce bacterial growth in the distribution system. In December of 2019 a new sodium hypochlorite injection system was installed to replace the existing calcium hypochlorite system.

3 Boil Advisories

None.

4 Future Improvements

No future improvements are contemplated at this time.

5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

6 Results

See below for the results of various water quality parameters.

Report Name: South-end Water Quality Report

Report Subtitle: Water Quality Report

	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd PS	
January 2025	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Flow (Volumetric Rate) (m³/d)	Avg Turbidity (Daily) (NTU)
1					5,602	0.08
2		0.66	0.84	0.42	5,594	0.07
3					5,266	0.09
4					5,179	0.08
5					5,310	0.08
6		0.59	0.80		5,476	0.09
7				0.48	5,329	0.09
8	0.65				5,365	0.08
9					5,540	0.09
10					5,691	0.07
11					5,385	0.09
12					5,298	0.08
13		0.84			5,378	0.07
14					5,222	0.09
15	0.69		0.96	0.93	5,228	0.08
16					5,118	0.09
17					5,058	0.08
18					5,260	0.09
19					5,547	0.08
20				0.49	5,455	0.08
21		0.61			5,328	0.09
22	0.75		0.67		5,293	0.08
23					5,129	0.08
24					5,262	0.09
25					5,395	0.09
26					5,343	0.08
27					5,255	0.08
28			0.83	0.48	5,415	0.08
29	0.50	0.33			5,613	0.09
30					5,451	0.08
31					5,317	0.09
Average	0.65	0.61	0.82	0.56	5,358	0.08
Minimum	0.50	0.33	0.67	0.42	5,058	0.07
Maximum	0.75	0.84	0.96	0.93	5,691	0.09
Count	4	5	5	5	31	31
Total					166,102	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.67	0.61	0.83	0.48	5,329	0.08

February 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d) Avg Turbidity (Daily) (NTU)	
1					5,230	0.08
2					5,541	0.08
3			0.75		5,781	0.10
4					5,566	0.09
5	0.66	0.59			5,449	0.09
6					5,429	0.10
7					5,384	0.09
8					5,356	0.10
9					5,512	0.09
10					5,715	0.10
11			0.57		5,741	0.09
12		0.57		0.47	5,579	0.09
13					5,318	0.09
14					5,550	0.09
15					5,818	0.09
16					5,874	0.09
17					5,735	0.10
18			0.62		6,245	0.09
19	0.54	0.56		0.44	6,181	0.09
20					5,864	0.09
21					6,025	0.09
22					5,925	0.09
23					6,291	0.09
24			0.83	0.46	6,086	0.09
25	0.65	0.57			5,697	0.10
26					5,487	0.09
27					5,544	0.09
28					5,309	0.09

Average	0.62	0.57	0.69	0.46	5,687	0.09
Minimum	0.54	0.56	0.57	0.44	5,230	0.08
Maximum	0.66	0.59	0.83	0.47	6,291	0.10
Count	3	4	4	3	28	28
Total					159,232	
95 Percentile						0.10
Exceedences	0	0	0	0	0	0
Median	0.65	0.57	0.69	0.46	5,638	0.09

March 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d)	Avg Turbidity (Daily) (NTU)
1					5,381	0.08
2					5,678	0.08
3					5,335	0.09
4	0.63	0.44	0.73	0.46	5,491	0.08
5					5,684	0.08
6					5,549	0.09
7					5,523	0.09
8					5,325	0.09
9					5,628	0.08
10			0.63	0.51	5,790	0.09
11	0.86	0.64			5,620	0.08
12					5,741	0.09
13					5,930	0.09
14					5,810	0.08
15					5,532	0.09
16					5,666	0.09
17			0.59	0.47	5,784	0.08
18	0.63	0.48			5,838	0.09
19					5,596	0.09
20					5,738	0.09
21					5,863	0.09
22					5,584	0.09
23					5,713	0.09
24			0.75		5,877	0.09
25		0.63			5,875	0.09
26					5,878	0.09
27	0.55				5,912	0.09
28					5,774	0.09
29					5,824	0.09
30					6,181	0.09
31					6,178	0.09

Average	0.67	0.55	0.68	0.48	5,719	0.09
Minimum	0.55	0.44	0.59	0.46	5,325	0.08
Maximum	0.86	0.64	0.75	0.51	6,181	0.09
Count	4	4	4	3	31	31
Total					177,298	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.63	0.56	0.68	0.47	5,738	0.09

April 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d) Avg Turbidity (Daily) (NTU)	
1		0.56		0.48	5,798	0.10
2	0.73		0.72		5,485	0.09
3					5,597	0.09
4					5,667	0.09
5					5,682	0.09
6					5,499	0.09
7		0.58	0.75	0.40	5,473	0.09
8	0.60				5,559	0.09
9					5,493	0.09
10					5,459	0.09
11					5,444	0.09
12					5,310	0.09
13					5,726	0.09
14					5,658	0.09
15					5,864	0.09
16		0.55	0.65	0.42	6,487	0.09
17					6,597	0.09
18					6,707	0.09
19					6,354	0.08
20					6,203	0.09
21					6,479	0.09
22				0.46	6,687	0.09
23					6,895	0.09
24			0.58		7,156	0.09
25					7,462	0.09
26					7,528	0.09
27					7,907	0.09
28	0.58		0.65	0.46	8,134	0.09
29		0.49			7,855	0.09
30					7,576	0.09

Average	0.64	0.55	0.67	0.44	6,325	0.09
Minimum	0.58	0.49	0.58	0.40	5,310	0.08
Maximum	0.73	0.58	0.75	0.48	8,134	0.10
Count	3	4	5	5	30	30
Total					189,741	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.60	0.56	0.65	0.46	6,034	0.09

May 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d)	Avg Turbidity (Daily) (NTU)
1					7,447	0.08
2					7,446	0.09
3					7,446	0.08
4					7,651	0.09
5	0.55	0.51		0.47	8,031	0.09
6			0.66		8,411	0.09
7					8,647	0.08
8					8,759	0.09
9					8,871	0.09
10					8,889	0.09
11					8,827	0.09
12			0.65	0.51	8,662	0.09
13	0.62	0.49			8,697	0.09
14					8,677	0.09
15					8,403	0.09
16					8,128	0.09
17					7,853	0.09
18					7,579	0.09
19					7,241	0.09
20	0.54		0.58	0.46	7,261	0.09
21					7,630	0.09
22		0.63			8,000	0.09
23					8,369	0.09
24					9,150	0.09
25					9,689	0.09
26	0.54		0.75	0.41	8,853	0.09
27					8,603	0.09
28		0.58			9,026	0.09
29					9,058	0.09
30					9,090	0.09
31					8,602	0.09

Average	0.56	0.55	0.66	0.46	8,355	0.09
Minimum	0.54	0.49	0.58	0.41	7,241	0.08
Maximum	0.62	0.63	0.75	0.51	9,689	0.09
Count	4	4	4	4	31	31
Total					258,996	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.55	0.55	0.66	0.47	8,602	0.09

June 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d) Avg Turbidity (Daily) (NTU)	
1					8,724	0.09
2					9,462	0.09
3	0.58		0.58	0.46	9,418	0.09
4					11,026	0.09
5					12,051	0.09
6					11,911	0.09
7					12,340	0.09
8					13,600	0.08
9			0.48	0.42	13,647	0.08
10	0.59	0.46			12,527	0.09
11					13,178	0.09
12					14,200	0.09
13					14,607	0.09
14					15,014	0.09
15					15,420	0.09
16	0.55	0.50	0.50	0.44	14,680	0.09
17					12,419	0.09
18					10,898	0.09
19					10,950	0.09
20					10,470	0.09
21					9,521	0.09
22					9,491	0.09
23	0.45	0.50	0.73	0.60	15,081	0.09
24					14,279	0.09
25					10,487	0.09
26					10,721	0.09
27					9,356	0.09
28					9,559	0.09
29					11,554	0.09
30					12,274	0.08

Average	0.54	0.49	0.57	0.48	11,962	0.09
Minimum	0.45	0.46	0.48	0.42	8,724	0.08
Maximum	0.59	0.50	0.73	0.60	15,420	0.09
Count	4	3	4	4	30	30
Total					358,865	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.57	0.50	0.54	0.45	11,981	0.09

July 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d) Avg Turbidity (Daily) (NTU)	
1					12,588	0.08
2					12,572	0.09
3		0.51	0.68	0.60	12,582	0.09
4	0.44				12,552	0.09
5					12,040	0.09
6					12,513	0.08
7		0.53	0.66	0.48	12,891	0.08
8	0.58				12,179	0.08
9					12,170	0.08
10					12,292	0.08
11					12,589	0.08
12					13,196	0.08
13					13,728	0.07
14					13,674	0.08
15		0.48	0.51		13,710	0.08
16	0.51				13,966	0.08
17				0.51	14,561	0.08
18					13,808	0.08
19					12,863	0.08
20					13,535	0.08
21					13,912	0.08
22					13,050	0.08
23					13,002	0.08
24					13,766	0.07
25					13,396	0.08
26					12,698	0.08
27					12,990	0.07
28			0.50	0.55	13,266	0.09
29	0.88	0.51			12,931	0.10
30					13,250	0.09
31					13,696	0.10

Average	0.60	0.51	0.59	0.54	13,096	0.08
Minimum	0.44	0.48	0.50	0.48	12,040	0.07
Maximum	0.88	0.53	0.68	0.60	14,561	0.10
Count	4	4	4	4	31	31
Total					405,966	
95 Percentile						0.10
Exceedences	0	0	0	0	0	0
Median	0.55	0.51	0.59	0.53	13,002	0.08

August 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d)	Avg Turbidity (Daily) (NTU)
1					13,111	0.10
2					12,903	0.09
3					13,222	0.09
4					12,773	0.10
5	0.47	0.50	0.45	0.58	12,380	0.09
6					11,457	0.09
7					11,453	0.09
8					11,672	0.10
9					11,675	0.09
10					13,075	0.09
11					13,440	0.09
12					12,607	0.09
13					11,908	0.09
14					11,209	0.09
15					10,152	0.10
16	0.36	0.44	0.51	0.44	9,209	0.09
17					9,395	0.09
18			0.56	0.47	9,920	0.10
19					9,869	0.10
20					10,526	0.10
21					11,453	0.10
22					11,608	0.09
23					11,853	0.09
24					12,121	0.09
25			0.59	0.53	12,511	0.09
26					12,245	0.09
27					12,242	0.09
28	0.52	0.44			11,624	0.09
29					10,674	0.09
30					10,794	0.09
31					10,676	0.09

Average	0.45	0.46	0.53	0.51	11,605	0.09
Minimum	0.36	0.44	0.45	0.44	9,209	0.09
Maximum	0.52	0.50	0.59	0.58	13,440	0.10
Count	3	3	4	4	31	31
Total					359,757	
95 Percentile						0.10
Exceedences	0	0	0	0	0	0
Median	0.47	0.44	0.54	0.50	11,672	0.09

September 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d) Avg Turbidity (Daily) (NTU)	
1					10,652	0.09
2	0.42	0.61	0.63	0.46	10,578	0.09
3					10,936	0.09
4					11,202	0.09
5					10,719	0.09
6					10,233	0.09
7					10,188	0.09
8		0.64		0.33	10,151	0.09
9	0.41		0.66		9,920	0.09
10					9,847	0.09
11					10,173	0.09
12					10,198	0.09
13					9,873	0.09
14					9,484	0.09
15					9,205	0.09
16	0.58				9,352	0.09
17		0.83	0.80	0.81	9,787	0.08
18					9,627	0.09
19					9,318	0.09
20					8,943	0.08
21					8,691	0.09
22			0.67	0.53	8,559	0.09
23					8,239	0.08
24	0.55	0.79			8,517	0.09
25					8,655	0.08
26					8,006	0.09
27					7,507	0.09
28					8,137	0.08
29	0.51	0.79	0.66	0.50	7,881	0.09
30					7,089	0.08

Average	0.49	0.73	0.68	0.53	9,389	0.09
Minimum	0.41	0.61	0.63	0.33	7,089	0.08
Maximum	0.58	0.83	0.80	0.81	11,202	0.09
Count	5	5	5	5	30	30
Total					281,667	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.51	0.79	0.66	0.50	9,556	0.09

October 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d) Avg Turbidity (Daily) (NTU)	
1					7,055	0.09
2					7,265	0.09
3					7,336	0.09
4					8,194	0.09
5					9,130	0.08
6		0.63	0.58	0.55	8,299	0.09
7	0.50				6,870	0.09
8					6,258	0.09
9					6,225	0.09
10					5,980	0.09
11					5,985	0.09
12					6,101	0.09
13					5,977	0.09
14		0.66	0.59	0.55	5,829	0.09
15					5,678	0.09
16					5,731	0.09
17	0.48				5,590	0.09
18					5,348	0.09
19					5,561	0.09
20			0.58	0.48	5,735	0.09
21	0.49				5,513	0.09
22					5,389	0.09
23					5,348	0.09
24					5,214	0.09
25					5,081	0.09
26					5,182	0.09
27		0.51	0.73	0.22	5,370	0.09
28					5,460	0.09
29	0.73				5,391	0.09
30					5,369	0.09
31					5,096	0.09

Average	0.55	0.60	0.62	0.45	6,083	0.09
Minimum	0.48	0.51	0.58	0.22	5,081	0.08
Maximum	0.73	0.66	0.73	0.55	9,130	0.09
Count	4	3	4	4	31	31
Total					188,560	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.50	0.63	0.59	0.52	5,731	0.09

November 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d)	Avg Turbidity (Daily) (NTU)
1					5,291	0.09
2					5,672	0.09
3					5,484	0.08
4					5,324	0.07
5					5,461	0.07
6					4,445	0.07
7					5,128	0.07
8					6,196	0.07
9					5,548	0.07
10					5,575	0.07
11					5,381	0.07
12					5,032	0.08
13			0.62	0.53	5,174	0.07
14	0.75	0.75			5,144	0.07
15					5,242	0.07
16					5,598	0.07
17	0.63	0.53	0.75	0.52	5,367	0.08
18					5,351	0.07
19					5,275	0.08
20					5,187	0.07
21					5,279	0.08
22					5,362	0.07
23					5,405	0.08
24		0.50	0.64	0.45	5,236	0.07
25					5,163	0.07
26	0.49				5,060	0.07
27					5,374	0.07
28					5,492	0.07
29					4,995	0.07
30					4,991	0.07

Average	0.62	0.59	0.67	0.50	5,308	0.07
Minimum	0.49	0.50	0.62	0.45	4,445	0.07
Maximum	0.75	0.75	0.75	0.53	6,196	0.09
Count	3	3	3	3	30	30
Total					159,232	
95 Percentile						0.09
Exceedences	0	0	0	0	0	0
Median	0.63	0.53	0.64	0.52	5,308	0.07

December 2025	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd PS Flow (Volumetric Rate) (m³/d)	Avg Turbidity (Daily) (NTU)
1		0.52	0.64	0.51	5,338	0.07
2	0.45				5,467	0.07
3					5,346	0.07
4					5,153	0.07
5					4,983	0.06
6					5,055	0.07
7					5,282	0.07
8			0.70	0.58	5,393	0.07
9	0.60	0.57			5,213	0.07
10					5,096	0.07
11					5,077	0.07
12					5,077	0.07
13					4,850	0.07
14					5,225	0.07
15					5,481	0.08
16		0.59	0.68	0.58	5,215	0.08
17	0.68				5,395	0.07
18					5,337	0.07
19					5,042	0.08
20					5,756	0.08
21					6,440	0.08
22	0.75	0.73	0.73	0.49	6,099	0.08
23					5,757	0.08
24					5,625	0.07
25					5,704	0.08
26					5,393	0.08
27					5,155	0.08
28					5,187	0.08
29	0.45	0.50	0.56		5,335	0.07
30					5,383	0.08
31					5,194	0.09

Average	0.59	0.58	0.66	0.54	5,357	0.07
Minimum	0.45	0.50	0.56	0.49	4,850	0.06
Maximum	0.75	0.73	0.73	0.58	6,440	0.09
Count	5	5	5	4	31	31
Total					166,053	
95 Percentile						0.08
Exceedences	0	0	0	0	0	0
Median	0.60	0.57	0.68	0.55	5,335	0.07

* indicates Geometric Mean
** indicates Intraday Average

DISINFECTANTS

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.42 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/07/2025	0.48 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/15/2025	0.93 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/20/2025	0.49 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/28/2025	0.48 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/12/2025	0.47 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/19/2025	0.44 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/24/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/04/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/10/2025	0.51 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/17/2025	0.47 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/01/2025	0.48 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/07/2025	0.40 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/16/2025	0.42 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/22/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/28/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/05/2025	0.47 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/12/2025	0.51 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/20/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/26/2025	0.41 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/03/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/09/2025	0.42 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/16/2025	0.44 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/23/2025	0.60 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/03/2025	0.60 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/07/2025	0.48 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/17/2025	0.51 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/28/2025	0.55 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/05/2025	0.58 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/16/2025	0.44 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/18/2025	0.47 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/25/2025	0.53 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/02/2025	0.46 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/08/2025	0.33 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/17/2025	0.81 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/22/2025	0.53 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/29/2025	0.50 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
10/06/2025	0.55 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/14/2025	0.55 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/20/2025	0.48 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/27/2025	0.22 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
11/13/2025	0.53 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
11/17/2025	0.52 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
11/24/2025	0.45 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/01/2025	0.51 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/08/2025	0.58 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/16/2025	0.58 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/22/2025	0.49 mg/L	Free Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined

# samples:	48	min:	0.22 mg/L
# detects:	48	max:	0.93 mg/L
# non-detects:	0	avg:	0.50 mg/L (based on 48 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.66 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/06/2025	0.59 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/13/2025	0.84 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/21/2025	0.61 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/29/2025	0.33 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/05/2025	0.59 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/12/2025	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/19/2025	0.56 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/25/2025	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/04/2025	0.44 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/11/2025	0.64 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/18/2025	0.48 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/25/2025	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/01/2025	0.56 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/07/2025	0.58 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/16/2025	0.55 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/29/2025	0.49 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/05/2025	0.51 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/13/2025	0.49 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/22/2025	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/28/2025	0.58 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
06/10/2025	0.46 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
06/16/2025	0.50 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
06/23/2025	0.50 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/03/2025	0.51 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/07/2025	0.53 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/15/2025	0.48 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/29/2025	0.51 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
08/05/2025	0.50 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
08/16/2025	0.44 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
08/28/2025	0.44 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/02/2025	0.61 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/08/2025	0.64 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/17/2025	0.83 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/24/2025	0.79 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/29/2025	0.79 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
10/06/2025	0.63 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
10/14/2025	0.66 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
10/27/2025	0.51 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
11/14/2025	0.75 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
11/17/2025	0.53 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
11/24/2025	0.50 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/01/2025	0.52 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/09/2025	0.57 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/16/2025	0.59 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/22/2025	0.73 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/29/2025	0.50 mg/L	Free Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined

# samples:	47	min:	0.33 mg/L
# detects:	47	max:	0.84 mg/L
# non-detects:	0	avg:	0.57 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.84 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/06/2025	0.80 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/15/2025	0.96 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/22/2025	0.67 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/28/2025	0.83 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/03/2025	0.75 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/11/2025	0.57 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/18/2025	0.62 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
02/24/2025	0.83 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/04/2025	0.73 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/10/2025	0.63 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/17/2025	0.59 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/24/2025	0.75 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/02/2025	0.72 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/07/2025	0.75 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/16/2025	0.65 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/24/2025	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/28/2025	0.65 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/06/2025	0.66 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/12/2025	0.65 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/20/2025	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/26/2025	0.75 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/03/2025	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/09/2025	0.48 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/16/2025	0.50 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/23/2025	0.73 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/03/2025	0.68 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/07/2025	0.66 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/15/2025	0.51 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/28/2025	0.50 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/05/2025	0.45 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/16/2025	0.51 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/18/2025	0.56 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/25/2025	0.59 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/02/2025	0.63 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/09/2025	0.66 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/17/2025	0.80 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/22/2025	0.67 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/29/2025	0.66 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/06/2025	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/14/2025	0.59 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/20/2025	0.58 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/27/2025	0.73 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/13/2025	0.62 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/17/2025	0.75 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/24/2025	0.64 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/01/2025	0.64 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
12/08/2025	0.70 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/16/2025	0.68 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/22/2025	0.73 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/29/2025	0.56 mg/L	Free Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined

# samples:	51	min:	0.45 mg/L
# detects:	51	max:	0.96 mg/L
# non-detects:	0	avg:	0.66 mg/L (based on 51 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.70 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/10/2025	0.83 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/14/2025	0.79 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/22/2025	0.77 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/29/2025	0.80 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/05/2025	0.68 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/12/2025	0.65 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/18/2025	0.77 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/25/2025	0.79 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/04/2025	0.79 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/10/2025	0.76 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/17/2025	0.74 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/25/2025	0.70 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/01/2025	0.79 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/08/2025	0.58 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/14/2025	0.76 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/24/2025	0.62 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/29/2025	0.55 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/06/2025	0.58 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/12/2025	0.60 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/22/2025	0.60 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/28/2025	0.58 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/03/2025	0.74 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/09/2025	0.44 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/17/2025	0.45 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/25/2025	0.52 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/04/2025	0.55 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/08/2025	0.77 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/14/2025	0.42 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
07/29/2025	0.74 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
08/05/2025	0.50 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
08/12/2025	0.33 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
08/27/2025	0.51 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/02/2025	0.65 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/08/2025	0.74 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/17/2025	0.76 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/29/2025	0.68 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/07/2025	0.55 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/14/2025	0.68 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/21/2025	0.61 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/29/2025	0.50 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
11/10/2025	0.71 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
11/17/2025	0.76 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
11/25/2025	0.34 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/01/2025	0.55 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/08/2025	0.64 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/17/2025	0.66 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/22/2025	0.78 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/30/2025	0.52 mg/L	Free Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined

# samples:	49	min:	0.33 mg/L
# detects:	49	max:	0.83 mg/L
# non-detects:	0	avg:	0.64 mg/L (based on 49 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/08/2025	0.65 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
01/15/2025	0.69 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
01/22/2025	0.75 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
01/29/2025	0.50 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
02/05/2025	0.66 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
02/19/2025	0.54 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
02/25/2025	0.65 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/04/2025	0.63 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/11/2025	0.86 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/18/2025	0.63 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/27/2025	0.55 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
04/02/2025	0.73 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
04/08/2025	0.60 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
04/28/2025	0.58 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/05/2025	0.55 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/13/2025	0.62 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/20/2025	0.54 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/26/2025	0.54 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/03/2025	0.58 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/10/2025	0.59 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/16/2025	0.55 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/23/2025	0.45 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/04/2025	0.44 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/08/2025	0.58 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/16/2025	0.51 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/29/2025	0.88 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
08/05/2025	0.47 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
08/16/2025	0.36 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
08/28/2025	0.52 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/02/2025	0.42 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/09/2025	0.41 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/16/2025	0.58 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/24/2025	0.55 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/29/2025	0.51 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/07/2025	0.50 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/17/2025	0.48 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/21/2025	0.49 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/29/2025	0.73 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
11/14/2025	0.75 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
11/17/2025	0.63 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
11/26/2025	0.49 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/02/2025	0.45 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/09/2025	0.60 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/17/2025	0.68 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/22/2025	0.75 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/29/2025	0.45 mg/L	Free Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined

# samples:	46	min:	0.36 mg/L
# detects:	46	max:	0.88 mg/L
# non-detects:	0	avg:	0.58 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.91 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/08/2025	0.98 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/15/2025	0.94 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/22/2025	0.89 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/28/2025	0.82 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/05/2025	0.81 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/12/2025	0.66 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/26/2025	0.75 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/14/2025	1.04 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/18/2025	0.87 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/24/2025	0.87 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/02/2025	0.83 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/07/2025	0.78 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/24/2025	0.84 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/29/2025	0.71 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/05/2025	0.69 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/13/2025	0.80 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/20/2025	0.65 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/26/2025	0.71 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/03/2025	0.84 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/09/2025	0.72 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/16/2025	0.80 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/23/2025	0.92 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/03/2025	0.90 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/07/2025	0.89 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/28/2025	0.90 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/05/2025	0.87 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/16/2025	0.49 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/18/2025	0.68 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/26/2025	0.71 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/02/2025	0.70 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/09/2025	0.69 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/16/2025	0.86 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/22/2025	0.84 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/29/2025	0.88 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
10/06/2025	0.89 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
10/14/2025	0.88 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
10/20/2025	0.90 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
11/14/2025	0.57 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
11/17/2025	0.77 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
11/26/2025	0.73 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/02/2025	0.74 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/09/2025	0.79 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/16/2025	0.82 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/22/2025	0.85 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/30/2025	0.83 mg/L	Free Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined

# samples:	46	min:	0.49 mg/L
# detects:	46	max:	1.04 mg/L
# non-detects:	0	avg:	0.80 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.90 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/08/2025	1.12 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/15/2025	0.72 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/22/2025	1.05 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
01/28/2025	0.76 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/05/2025	0.82 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/12/2025	0.67 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
02/26/2025	0.78 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/14/2025	0.89 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/18/2025	0.82 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
03/24/2025	0.78 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/02/2025	0.81 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/07/2025	0.79 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/24/2025	0.87 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
04/29/2025	0.67 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/05/2025	0.72 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/13/2025	0.82 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/20/2025	0.67 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
05/26/2025	0.67 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/03/2025	0.87 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/09/2025	0.90 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/16/2025	0.90 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
06/23/2025	0.89 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/03/2025	0.92 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/07/2025	0.91 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
07/15/2025	0.87 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
07/28/2025	0.89 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/05/2025	0.84 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/16/2025	0.66 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/18/2025	0.72 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
08/26/2025	0.68 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/02/2025	0.70 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/09/2025	0.73 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/16/2025	0.92 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/22/2025	0.86 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
09/29/2025	0.89 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
10/06/2025	0.88 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
10/14/2025	0.89 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
10/20/2025	0.88 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
11/14/2025	0.78 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
11/17/2025	0.82 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
11/26/2025	0.75 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/02/2025	0.74 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/09/2025	0.78 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/16/2025	0.81 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/22/2025	0.86 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined
12/30/2025	0.88 mg/L	Total Cl2	Source at Lakes Rd	>=0.05, <=4 User-Defined

# samples:	47	min:	0.66 mg/L
# detects:	47	max:	1.12 mg/L
# non-detects:	0	avg:	0.82 mg/L (based on 47 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/08/2025	0.68 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
01/15/2025	0.51 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
01/22/2025	0.90 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
01/29/2025	0.74 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
02/05/2025	0.71 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
02/19/2025	0.61 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
02/25/2025	0.67 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/04/2025	0.71 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/11/2025	0.79 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/18/2025	0.60 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
03/27/2025	0.53 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
04/02/2025	0.65 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
04/08/2025	0.58 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
04/28/2025	0.54 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/05/2025	0.60 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/13/2025	0.59 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/20/2025	0.55 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
05/26/2025	0.58 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/03/2025	0.60 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/10/2025	0.67 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/16/2025	0.62 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
06/23/2025	0.52 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/04/2025	0.50 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/08/2025	0.61 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/16/2025	0.56 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
07/29/2025	0.87 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
08/05/2025	0.46 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
08/16/2025	0.39 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
08/28/2025	0.54 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/02/2025	0.55 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/09/2025	0.55 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/16/2025	0.51 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/24/2025	0.59 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
09/29/2025	0.54 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/07/2025	0.47 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/17/2025	0.80 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/21/2025	0.53 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
10/29/2025	0.83 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
11/14/2025	0.61 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
11/17/2025	0.63 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
11/26/2025	0.61 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/02/2025	0.47 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/09/2025	0.62 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/17/2025	0.67 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/22/2025	0.58 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined
12/29/2025	0.62 mg/L	Total Cl2	3908 Cowichan Lake Rd	>=0.05, <=4 User-Defined

# samples:	46	min:	0.39 mg/L
# detects:	46	max:	0.90 mg/L
# non-detects:	0	avg:	0.61 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.76 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/10/2025	0.65 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/14/2025	0.84 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/22/2025	0.87 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
01/29/2025	0.83 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/05/2025	0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/12/2025	0.79 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/18/2025	0.77 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
02/25/2025	0.79 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/04/2025	0.82 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/10/2025	0.81 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/17/2025	0.85 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
03/25/2025	0.66 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/01/2025	0.76 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/08/2025	0.72 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/14/2025	0.82 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/24/2025	0.66 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
04/29/2025	0.64 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/06/2025	0.57 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/12/2025	0.63 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/22/2025	0.66 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
05/28/2025	0.72 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/03/2025	0.81 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/09/2025	0.58 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/17/2025	0.53 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
06/25/2025	0.55 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/04/2025	0.58 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/08/2025	0.82 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/14/2025	0.50 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
07/29/2025	0.76 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
08/05/2025	0.63 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
08/12/2025	0.40 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
08/27/2025	0.44 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
* 09/02/2025	368 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/08/2025	0.55 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/17/2025	0.85 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
09/29/2025	0.57 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/07/2025	0.58 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/14/2025	0.66 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
10/21/2025	0.63 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
10/29/2025	0.56 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
11/10/2025	0.50 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
11/17/2025	0.83 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
11/25/2025	0.52 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/01/2025	0.58 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/08/2025	0.69 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/17/2025	0.71 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined
12/30/2025	0.60 mg/L	Total Cl2	North Rd Reservoir #2	>=0.05, <=4 User-Defined

# samples:	48	min:	0.40 mg/L
# detects:	48	max:	368 mg/L
# non-detects:	0	avg:	8.33 mg/L (based on 48 numerical results)
# of Exceedences:	1		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.78 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/06/2025	0.94 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/15/2025	0.88 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/22/2025	0.90 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
01/28/2025	0.83 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/03/2025	0.76 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/11/2025	0.84 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/18/2025	0.66 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
02/24/2025	0.80 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/04/2025	0.79 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/10/2025	0.62 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/17/2025	0.51 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
03/24/2025	0.73 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/02/2025	0.69 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/07/2025	0.70 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/16/2025	0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/24/2025	0.67 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
04/28/2025	0.68 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/06/2025	0.64 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/12/2025	0.68 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/20/2025	0.67 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
05/26/2025	0.73 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/03/2025	0.67 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/09/2025	0.55 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
06/16/2025	0.51 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
06/23/2025	0.74 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/03/2025	0.66 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/07/2025	0.70 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/15/2025	0.50 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
07/28/2025	0.52 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/05/2025	0.55 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/16/2025	0.54 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/18/2025	0.58 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
08/25/2025	0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/02/2025	0.71 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/09/2025	0.72 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/17/2025	0.89 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/22/2025	0.67 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
09/29/2025	0.64 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/06/2025	0.61 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/14/2025	0.63 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/20/2025	0.61 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
10/27/2025	0.84 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/13/2025	0.73 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/17/2025	0.81 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
11/24/2025	0.65 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/01/2025	0.71 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/08/2025	0.74 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/16/2025	0.71 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/22/2025	0.76 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined
12/29/2025	0.62 mg/L	Total Cl2	Maple Bay Marina	>=0.05, <=4 User-Defined

# samples:	51	min:	0.50 mg/L
# detects:	51	max:	0.94 mg/L
# non-detects:	0	avg:	0.69 mg/L (based on 51 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.71 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/06/2025	0.62 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/13/2025	0.67 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/21/2025	0.71 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
01/29/2025	0.39 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/05/2025	0.62 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
02/12/2025	0.65 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/19/2025	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
02/25/2025	0.61 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/04/2025	0.54 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/11/2025	0.67 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/18/2025	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
03/25/2025	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/01/2025	0.58 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/07/2025	0.50 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/16/2025	0.60 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
04/29/2025	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/05/2025	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/13/2025	0.51 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/22/2025	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
05/28/2025	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
06/10/2025	0.48 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
06/16/2025	0.61 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
06/23/2025	0.55 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/03/2025	0.56 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/07/2025	0.58 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/15/2025	0.52 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
07/29/2025	0.48 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
08/05/2025	0.52 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
08/16/2025	0.54 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
08/28/2025	0.44 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/02/2025	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/08/2025	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/17/2025	0.84 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/24/2025	0.78 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
09/29/2025	0.78 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
10/06/2025	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
10/14/2025	0.61 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
10/27/2025	0.44 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
11/14/2025	0.60 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
11/17/2025	0.63 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
11/24/2025	0.59 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/01/2025	0.61 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/09/2025	0.64 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/16/2025	0.66 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
12/22/2025	0.53 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
12/29/2025	0.53 mg/L	Total Cl2	Bell McKinnon Reservoir	>=0.05, <=4 User-Defined
# samples:	47	min:	0.39 mg/L	
# detects:	47	max:	0.84 mg/L	
# non-detects:	0	avg:	0.60 mg/L (based on 47 numerical results)	
# of Exceedences:	0			

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/02/2025	0.47 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/07/2025	0.53 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/15/2025	0.95 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/20/2025	0.56 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
01/28/2025	0.54 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/12/2025	0.47 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/19/2025	0.51 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
02/24/2025	0.47 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/04/2025	0.53 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/10/2025	0.52 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
03/17/2025	0.47 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/01/2025	0.40 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/07/2025	0.45 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/16/2025	0.42 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/22/2025	0.54 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
04/28/2025	0.53 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/05/2025	0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/12/2025	0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/20/2025	0.52 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
05/26/2025	0.42 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/03/2025	0.54 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/09/2025	0.63 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/16/2025	0.62 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
06/23/2025	0.62 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/03/2025	0.58 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/07/2025	0.52 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/17/2025	0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
07/28/2025	0.65 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/05/2025	0.45 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/16/2025	0.56 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
08/18/2025	0.52 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
08/25/2025 0.60 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/02/2025 0.47 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/08/2025 0.50 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/17/2025 0.78 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/22/2025 0.43 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
09/29/2025 0.42 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/06/2025 0.51 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/14/2025 0.52 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/20/2025 0.49 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
10/27/2025 0.31 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
11/13/2025 0.51 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
11/17/2025 0.57 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
11/24/2025 0.54 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/01/2025 0.58 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/08/2025 0.63 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/16/2025 0.57 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined
12/22/2025 0.57 mg/L	Total Cl2	Maple Mtn Reservoir	>=0.05, <=4 User-Defined

# samples:	48	min:	0.31 mg/L
# detects:	48	max:	0.95 mg/L
# non-detects:	0	avg:	0.53 mg/L (based on 48 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown
> means greater than upper detection limit shown
« means detected & less than number shown
» means detected & greater than number shown

* Indicates Criteria is exceeded

MICROORGANISMS

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
05/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
09/08/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Municipal Hall	<=0, OG, P	User-Defined
# samples:	10	min:	< 1 CFU/100ml	Geometric Mean: n/a (based on 0 numerical results)	
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	10				
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
05/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
08/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
09/22/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
11/24/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
# samples:	8	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	8	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
03/10/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
08/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
09/08/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
# samples:	9	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)		

of Exceedences: 0

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
03/24/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
04/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
05/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
07/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
08/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
09/22/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
10/27/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
11/24/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Bay Marina	<=0, OG, P User-Defined

# samples:	9	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/06/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
03/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
04/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
06/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined
07/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/05/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
09/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
10/06/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
11/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
# samples:	11	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
05/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
06/23/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
08/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
09/22/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
11/24/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
# samples:	9	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)		

of Exceedences: 0

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
02/11/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
05/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
07/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
08/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
10/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Vancouver Island Motorsports	<=0, OG, P User-Defined

# samples:	11	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P User-Defined
03/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P User-Defined
05/26/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P User-Defined
07/28/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P User-Defined
08/25/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
09/22/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Reservoir	<=0, OG, P	User-Defined
# samples:	7	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	7	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
05/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
08/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
09/08/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
# samples:	10	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/06/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
03/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
04/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
06/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
07/07/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
08/05/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
09/02/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
10/06/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
11/03/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined

# samples:	10	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
02/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
03/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
06/16/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
08/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
09/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
10/20/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
11/17/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
12/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Maple Mtn Pump House	<=0, OG, P	User-Defined
# samples:	10	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
08/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
09/08/2025 00:00	SC CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
# samples:	10	min:	< 1 CFU/100ml		
# detects:	0	max:	< 1 CFU/100ml		
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/15/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
05/12/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
08/12/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
09/08/2025 00:00	SC	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	Stonehouse Reservoir	<=0, OG, P	User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
03/25/2025 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
05/26/2025 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
* 08/25/2025 00:00	56.0	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
09/22/2025 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
12/01/2025 00:00	< 1	Total Coliforms (counts)	Properties Reservoir	<=0, OG, P	User-Defined
# samples:	7	min:	< 1		
# detects:	1	max:	56.0		
# non-detects:	6	Geometric Mean:	56.0 (based on 1 numerical results)		
# of Exceedences:	1				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/15/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
08/12/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
09/08/2025 00:00	SC	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	Lakeview Reservoir	<=0, OG, P	User-Defined
# samples:	10	min:	< 1		
# detects:	0	max:	< 1		
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
05/26/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
06/23/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
08/25/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
09/22/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
11/24/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Reservoir	<=0, OG, P	User-Defined

# samples:	9	min:	< 1
# detects:	0	max:	< 1
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/06/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
03/03/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
04/07/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
06/02/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
07/07/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
08/05/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
09/02/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
10/06/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
11/03/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
12/01/2025 00:00	< 1	Total Coliforms (counts)	Bell McKinnon Reservoir	<=0, OG, P	User-Defined
# samples:	11	min:	< 1		
# detects:	0	max:	< 1		
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
03/10/2025 00:00	SC	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
08/12/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
09/08/2025 00:00	SC	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
10/14/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	North Rd Reservoir #2	<=0, OG, P	User-Defined
# samples:	9	min:	< 1		
# detects:	0	max:	< 1		
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
05/26/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
08/25/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
09/22/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
11/24/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Reservoir #2	<=0, OG, P	User-Defined

# samples:	8	min:	< 1
# detects:	0	max:	< 1
# non-detects:	8	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
02/11/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
05/12/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
08/18/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
10/28/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	Vancouver Island Motorsports	<=0, OG, P	User-Defined

# samples:	11	min:	< 1
# detects:	0	max:	< 1
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
05/12/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
06/09/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
07/14/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
09/08/2025 00:00	SC	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
10/14/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	Municipal Hall	<=0, OG, P User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/06/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P User-Defined
03/03/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P User-Defined
04/07/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P User-Defined

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
06/02/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
07/07/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
08/05/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
09/02/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
10/06/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined
11/03/2025 00:00	< 1	Total Coliforms (counts)	Properties Water Pump Station	<=0, OG, P	User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025 00:00	SC	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
03/24/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
04/28/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
05/26/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
07/28/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
08/25/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
09/22/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
10/27/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
11/24/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined
12/01/2025 00:00	< 1	Total Coliforms (counts)	Maple Bay Marina	<=0, OG, P	User-Defined

# samples:	9	min:	< 1
# detects:	0	max:	< 1
# non-detects:	9	Geometric Mean:	n/a (based on 0 numerical results)

of Exceedences: 0

Total Coliforms (counts)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
01/20/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
02/18/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
03/17/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
06/16/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
07/21/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
08/18/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
09/15/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
10/20/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
11/17/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined
12/10/2025 00:00	< 1	Total Coliforms (counts)	Maple Mtn Pump House	<=0, OG, P User-Defined

# samples:	10	min:	< 1
# detects:	0	max:	< 1
# non-detects:	10	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown
> means greater than upper detection limit shown
« means detected & less than number shown
» means detected & greater than number shown

* Indicates Criteria is exceeded

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 1 (3-2-SR, 3B169)

Aluminum(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.0050 mg/L	Aluminum	Boys Rd - Well 1	<=0.2	Secondary Standard

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.00020 mg/L	Antimony (total)	Boys Rd - Well 1	<=0.006	MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.00050 mg/L	Arsenic (total)	Boys Rd - Well 1	<=0.010	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.0050 mg/L	Barium (total)	Boys Rd - Well 1	<=2	MCL

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.00010 mg/L	Beryllium (total)	Boys Rd - Well 1	<=0.004	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.10 ug/L	Bismuth (total)	Boys Rd - Well 1		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.0500 mg/L	Boron (total)	Boys Rd - Well 1	<=5	MAC

# samples:	1	min:	< 0.0500 mg/L
# detects:	0	max:	< 0.0500 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.005 mg/L	Bromate	Boys Rd - Well 1	<=0.01	MAC

# samples:	1	min:	< 0.005 mg/L
# detects:	0	max:	< 0.005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.000010 mg/L	Cadmium (total)	Boys Rd - Well 1	<=0.005	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	7,300 ug/L	Calcium (total)	Boys Rd - Well 1		

# samples:	1	min:	7,300 ug/L
# detects:	1	max:	7,300 ug/L
# non-detects:	0	avg:	7,300 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	1.75 mg/L	Chloride	Boys Rd - Well 1	<=250	Secondary Standard

# samples:	1	min:	1.75 mg/L
# detects:	1	max:	1.75 mg/L
# non-detects:	0	avg:	1.75 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.00050 mg/L	Chromium (total)	Boys Rd - Well 1	<=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 0.00263 mg/L	Copper (total)	Boys Rd - Well 1	<=1 Secondary Standard

# samples:	1	min:	0.00263 mg/L
# detects:	1	max:	0.00263 mg/L
# non-detects:	0	avg:	0.00263 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.0020 mg/L	Cyanide (total)	Boys Rd - Well 1	<=0.2 MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.0100 mg/L	Diquat	Boys Rd - Well 1	<=0.02 MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.10 mg/L	Fluoride	Boys Rd - Well 1	<=4.0 MCL

# samples:	1	min:	< 0.10 mg/L
------------	---	------	-------------

# detects:	0	max:	< 0.10 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.050 mg/L	Glyphosate	Boys Rd - Well 1	<=0.7	MCL
# samples:	1	min:	< 0.050 mg/L		
# detects:	0	max:	< 0.050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Hardness (total, as CaCO3)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	21.3 mg/L	Hardness (total, as CaCO3)	Boys Rd - Well 1		
# samples:	1	min:	21.3 mg/L		
# detects:	1	max:	21.3 mg/L		
# non-detects:	0	avg:	21.3 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Iron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.01 mg/L	Iron (total)	Boys Rd - Well 1	<=0.3	Secondary Standard
# samples:	1	min:	< 0.01 mg/L		
# detects:	0	max:	< 0.01 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Lead (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.00020 mg/L	Lead (total)	Boys Rd - Well 1	<=0.015	MCL
# samples:	1	min:	< 0.00020 mg/L		
# detects:	0	max:	< 0.00020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Lithium (dissolved)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.10 ug/L	Lithium (dissolved)	Boys Rd - Well 1		
# samples:	1	min:	< 0.10 ug/L		
# detects:	0	max:	< 0.10 ug/L		

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 738 ug/L	Magnesium (total)	Boys Rd - Well 1	

# samples:	1	min:	738 ug/L
# detects:	1	max:	738 ug/L
# non-detects:	0	avg:	738 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.00020 mg/L	Manganese (total)	Boys Rd - Well 1	<=0.05 Secondary Standard

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.000010 mg/L	Mercury (total)	Boys Rd - Well 1	<=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.10 ug/L	Molybdenum (total)	Boys Rd - Well 1	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.00040 mg/L	Nickel (total)	Boys Rd - Well 1	<=0.1 MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	0.075 mg/L	Nitrate (as N)	Boys Rd - Well 1	<=10	MCL
# samples:	1	min:	0.075 mg/L		
# detects:	1	max:	0.075 mg/L		
# non-detects:	0	avg:	0.075 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.2 mg/L	Nitrilotriacetic acid / NTA	Boys Rd - Well 1	<=0.4	MAC
# samples:	1	min:	< 0.2 mg/L		
# detects:	0	max:	< 0.2 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.0050 mg/L	Paraquat	Boys Rd - Well 1	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride
# samples:	1	min:	< 0.0050 mg/L		
# detects:	0	max:	< 0.0050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/06/2025	6.68	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
02/10/2025	6.76	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
03/03/2025	6.78	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
04/07/2025	6.73	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
05/05/2025	6.75	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
06/02/2025	6.7	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
07/07/2025	6.63	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
08/05/2025	6.65	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
09/02/2025	6.74	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
10/06/2025	6.79	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard
12/08/2025	6.95	pH	Boys Rd - Well 1	>=6.5, <=8.5	Secondary Standard

# samples:	11	min:	6.63
# detects:	11	max:	6.95
# non-detects:	0	avg:	6.74 (based on 11 numerical results)
# of Exceedences:	0		

pH(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 6.63	pH	Boys Rd - Well 1	>=6.5, <=8.5 Secondary Standard

# samples:	1	min:	6.63
# detects:	1	max:	6.63
# non-detects:	0	avg:	6.63 (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 180 ug/L	Potassium (total)	Boys Rd - Well 1	

# samples:	1	min:	180 ug/L
# detects:	1	max:	180 ug/L
# non-detects:	0	avg:	180 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.00050 mg/L	Selenium (total)	Boys Rd - Well 1	<=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 2,100 ug/L	Silicon (total, as Si)	Boys Rd - Well 1	

# samples:	1	min:	2,100 ug/L
# detects:	1	max:	2,100 ug/L
# non-detects:	0	avg:	2,100 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.000050 mg/L	Silver (total)	Boys Rd - Well 1	<=0.1 Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 1.53 mg/L	Sodium (total)	Boys Rd - Well 1	<=160 MCL

# samples:	1	min:	1.53 mg/L
# detects:	1	max:	1.53 mg/L
# non-detects:	0	avg:	1.53 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 20.6 ug/L	Strontium (total)	Boys Rd - Well 1	

# samples:	1	min:	20.6 ug/L
# detects:	1	max:	20.6 ug/L
# non-detects:	0	avg:	20.6 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 3,000 ug/L	Sulfur (total)	Boys Rd - Well 1	

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 1.3 mg/L	Sulphate	Boys Rd - Well 1	<=250 Secondary Standard

# samples:	1	min:	1.3 mg/L
# detects:	1	max:	1.3 mg/L
# non-detects:	0	avg:	1.3 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 20 ug/L	Sulphide (total, as S)	Boys Rd - Well 1	

# samples:	1	min:	< 20 ug/L
# detects:	0	max:	< 20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/06/2025	13.9 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
02/10/2025	12.5 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
03/03/2025	12.2 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
04/07/2025	11.4 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
05/05/2025	12.0 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
06/02/2025	13.3 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
* 07/07/2025	15.3 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
* 07/15/2025	1,400 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
* 08/05/2025	16.7 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
* 09/02/2025	1,802 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
* 10/06/2025	18.7 degrees C	Temperature	Boys Rd - Well 1	<=15 AO
* 12/08/2025	17.2 degrees C	Temperature	Boys Rd - Well 1	<=15 AO

# samples:	12	min:	11.4 degrees C
# detects:	12	max:	1,802 degrees C
# non-detects:	0	avg:	278.8 degrees C (based on 12 numerical results)
# of Exceedences:	6		

Thallium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.000020 mg/L	Thallium (total)	Boys Rd - Well 1	<=0.002 MCL
# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 0.20 ug/L	Tin (total)	Boys Rd - Well 1	
# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22 < 5.0 ug/L	Titanium (total)	Boys Rd - Well 1	
# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/06/2025	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
02/10/2025	0.094 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
03/03/2025	0.095 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
04/07/2025	0.099 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
05/05/2025	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
06/02/2025	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
* 07/07/2025	0.89 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
08/05/2025	0.10 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
09/02/2025	0.08 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
10/06/2025	0.09 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined
12/08/2025	0.07 NTU	Turbidity	Boys Rd - Well 1	<=0.5	User-Defined

# samples:	11	min:	0.07 NTU
# detects:	11	max:	0.89 NTU
# non-detects:	0	avg:	0.163 NTU (based on 11 numerical results)
# of Exceedences:	1	95th percentile:	0.890 NTU

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 0.000020 mg/L	Uranium (total)	Boys Rd - Well 1	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	< 5.0 ug/L	Vanadium (total)	Boys Rd - Well 1		

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/11/2025 09:22	0.0048 mg/L	Zinc (total)	Boys Rd - Well 1	<=5	Secondary Standard

# samples:	1	min:	0.0048 mg/L
# detects:	1	max:	0.0048 mg/L
# non-detects:	0	avg:	0.0048 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/11/2025 09:22	< 0.10 ug/L	Zirconium (total)	Boys Rd - Well 1	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Facility:	Water - Raw; Water - Raw
Sampling Point:	Boys Rd - Well 2 (3-3-SR, 3B16A)

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
--	--	------------------	---------------------	----------

01/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
06/09/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
07/14/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
07/21/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
08/18/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
10/15/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1 CFU/100ml	Escherichia coli / E. coli (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined

# samples:	11	min:	< 1 CFU/100ml
# detects:	0	max:	< 1 CFU/100ml
# non-detects:	11	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025	6.82	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/10/2025	6.76	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
03/10/2025	6.77	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
04/14/2025	6.87	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
05/13/2025	6.72	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
06/09/2025	6.76	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
07/15/2025	6.64	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
10/14/2025	6.62	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
* 11/17/2025	6.47	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard
12/08/2025	6.74	pH	Boys Rd - Well 2	>=6.5, <=8.5	Secondary Standard

# samples:	10	min:	6.47
# detects:	10	max:	6.87
# non-detects:	0	avg:	6.72 (based on 10 numerical results)
# of Exceedences:	1		

Temperature(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025	12.4 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
02/10/2025	12.4 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
03/10/2025	11.5 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
04/14/2025	9.6 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
05/13/2025	13.4 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
06/09/2025	14.0 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
* 07/15/2025	16.1 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
* 10/14/2025	16.07 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
* 11/17/2025	17.2 degrees C	Temperature	Boys Rd - Well 2	<=15	AO
* 12/08/2025	17.6 degrees C	Temperature	Boys Rd - Well 2	<=15	AO

# samples:	10	min:	9.6 degrees C
# detects:	10	max:	17.6 degrees C
# non-detects:	0	avg:	14.03 degrees C (based on 10 numerical results)
# of Exceedences:	4		

Time(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria
01/14/2025	1,300	Time	Boys Rd - Well 2	
02/10/2025	900	Time	Boys Rd - Well 2	
03/10/2025	1,100	Time	Boys Rd - Well 2	
04/14/2025	1,000	Time	Boys Rd - Well 2	
05/13/2025	900	Time	Boys Rd - Well 2	
06/09/2025	915	Time	Boys Rd - Well 2	

Time(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria
07/15/2025	830	Time	Boys Rd - Well 2	
11/17/2025	925	Time	Boys Rd - Well 2	
12/08/2025	1,040	Time	Boys Rd - Well 2	

# samples:	9	min:	830
# detects:	9	max:	1,300
# non-detects:	0	avg:	990 (based on 9 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
02/10/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
03/10/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
04/14/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
* 06/09/2025 00:00	1.0	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
* 07/14/2025 00:00	4.1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
* 07/21/2025 00:00	1.0	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
* 08/18/2025 00:00	30.5	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
10/15/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
11/12/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined
12/08/2025 00:00	< 1	Total Coliforms (counts)	Boys Rd - Well 2	<=0, OG, P	User-Defined

# samples:	11	min:	< 1
# detects:	4	max:	30.5
# non-detects:	7	Geometric Mean:	3.3 (based on 4 numerical results)
# of Exceedences:	4		

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/14/2025	0.1 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
* 02/10/2025	0.94 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
03/10/2025	0.13 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined

Turbidity(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
04/14/2025 0.15 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
05/13/2025 0.09 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
06/09/2025 0.09 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
07/15/2025 0.08 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
10/14/2025 0.09 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
11/17/2025 0.07 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined
12/08/2025 0.06 NTU	Turbidity	Boys Rd - Well 2	<=0.5	User-Defined

# samples:	10	min:	0.06 NTU
# detects:	10	max:	0.94 NTU
# non-detects:	0	avg:	0.18 NTU (based on 10 numerical results)
# of Exceedences:	1	95th percentile:	0.94 NTU

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 3 (3-4-SR, 3B16B)

1,1,1-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.0010 mg/L	1,1,1-Trichloroethane	Boys Rd - Well 3	<=0.2	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2,2-Tetrachloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.5 ug/L	1,1,2,2-Tetrachloroethane	Boys Rd - Well 3		

# samples:	1	min:	< 0.5 ug/L
# detects:	0	max:	< 0.5 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.0010 mg/L	1,1,2-Trichloroethane	Boys Rd - Well 3	<=0.005	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

1,1-Dichloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50		< 1.0 ug/L	1,1-Dichloroethane	Boys Rd - Well 3
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

1,1-Dichloroethylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	1,1-Dichloroethylene	Boys Rd - Well 3	<=0.007	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

1,2-Dichlorobenzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0005 mg/L	1,2-Dichlorobenzene	Boys Rd - Well 3	<=0.6	MCL
# samples:	1	min:	< 0.0005 mg/L		
# detects:	0	max:	< 0.0005 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

1,2-Dichloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	1,2-Dichloroethane	Boys Rd - Well 3	<=0.003	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

1,2-Dichloropropane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	1,2-Dichloropropane	Boys Rd - Well 3	<=0.005	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

1,3-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 1.0 ug/L	1,3-Dichlorobenzene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichloropropene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 1.0 ug/L	1,3-Dichloropropene	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,4-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0010 mg/L	1,4-Dichlorobenzene	Boys Rd - Well 3	<=0.075 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	1-Methylnaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.50 ug/L	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00050 mg/L	2,3,4,6-Tetrachlorophenol	Boys Rd - Well 3	<=0.001	AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.50 ug/L	2,3,4-Trichlorophenol	Boys Rd - Well 3		

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,5-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.50 ug/L	2,3,5-Trichlorophenol	Boys Rd - Well 3		

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.50 ug/L	2,3,6-Trichlorophenol	Boys Rd - Well 3		

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.20 ug/L	2,3-Dichlorophenol	Boys Rd - Well 3		

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.20 ug/L	2,4 + 2,5-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.50 ug/L	2,4,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.10 ug/L	2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.00050 mg/L	2,4,6-Trichlorophenol	Boys Rd - Well 3	<=0.002 AO (MAC is 0.005 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.00010 mg/L	2,4-Dichlorophenoxyacetic acid / 2,4-D	Boys Rd - Well 3	<=0.07 MCL

# samples:	1	min:	< 0.00010 mg/L
------------	---	------	----------------

# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,6-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.20 ug/L	2,6-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chloronaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	2-Chloronaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.10 ug/L	2-Chlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.02 ug/L	2-methyl-4-chlorophe noxyacetic acid / MCPA	Boys Rd - Well 3	

# samples:	1	min:	< 0.02 ug/L
# detects:	0	max:	< 0.02 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	2-Methylnaphthalene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.10 ug/L	3 and 4-Chlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.50 ug/L	3,4,5-Trichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.20 ug/L	3,4-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.20 ug/L	3,5-Dichlorophenol	Boys Rd - Well 3	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

4-Chloro-3-methylphenol (Parachlorometa cresol)(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
4-Chloro-3-methylphenol (Parachlorometa cresol)	Boys Rd - Well 3	

08/18/2025 08:50	< 0.50 ug/L	
# samples:	1	min: < 0.50 ug/L
# detects:	0	max: < 0.50 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Acenaphthene(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Acenaphthene	Boys Rd - Well 3	

08/18/2025 08:50	< 0.050 ug/L	
# samples:	1	min: < 0.050 ug/L
# detects:	0	max: < 0.050 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Acenaphthylene(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Acenaphthylene	Boys Rd - Well 3	

08/18/2025 08:50	< 0.200 ug/L	
# samples:	1	min: < 0.200 ug/L
# detects:	0	max: < 0.200 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Acridine(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Acridine	Boys Rd - Well 3	

08/18/2025 08:50	< 0.050 ug/L	
# samples:	1	min: < 0.050 ug/L
# detects:	0	max: < 0.050 ug/L
# non-detects:	1	avg: n/a (based on 0 numerical results)
# of Exceedences:	0	

Alachlor(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
Alachlor	Boys Rd - Well 3	<=0.002 MCL

08/18/2025 08:50	< 0.000100 mg/L	
# samples:	1	min: < 0.000100 mg/L
# detects:	0	max: < 0.000100 mg/L
# non-detects:	1	avg: n/a (based on 0 numerical results)

of Exceedences: 0

Aldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.006 ug/L	Aldrin	Boys Rd - Well 3	
# samples:	1	min:	< 0.006 ug/L	
# detects:	0	max:	< 0.006 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

alpha-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.010 ug/L	alpha-BHC	Boys Rd - Well 3	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aluminum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0050 mg/L	Aluminum (total)	Boys Rd - Well 3	<=0.2	Secondary Standard
# samples:	1	min:	< 0.0050 mg/L		
# detects:	0	max:	< 0.0050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.010 ug/L	Anthracene	Boys Rd - Well 3	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Antimony (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00020 mg/L	Antimony (total)	Boys Rd - Well 3	<=0.006	MCL
# samples:	1	min:	< 0.00020 mg/L		
# detects:	0	max:	< 0.00020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Aroclor 1016(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Aroclor 1016	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Aroclor 1221	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Aroclor 1232	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Aroclor 1242	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Aroclor 1248	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Aroclor 1254	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Aroclor 1260	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1262(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Aroclor 1262	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1268(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Aroclor 1268	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.00050 mg/L	Arsenic (total)	Boys Rd - Well 3	<=0.010 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Atrazine + N-dealkylated metabolites(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000100 mg/L	Atrazine + N-dealkylated metabolites	Boys Rd - Well 3	<=0.005 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Azinphos-methyl(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000200 mg/L	Azinphos-methyl	Boys Rd - Well 3	<=0.02 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0050 mg/L	Barium (total)	Boys Rd - Well 3	<=2 MCL

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0005 mg/L	Benzene	Boys Rd - Well 3	<=0.001 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)anthracene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.010 ug/L	Benzo(a)anthracene	Boys Rd - Well 3	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)pyrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000010 mg/L	Benzo(a)pyrene	Boys Rd - Well 3	<=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Benzo(b,j)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(g,h,i)perylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Benzo(g,h,i)perylene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(k)fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Benzo(k)fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.00010 mg/L	Beryllium (total)	Boys Rd - Well 3	<=0.004 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

beta-BHC(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	beta-BHC	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.10 ug/L	Bismuth (total)	Boys Rd - Well 3	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0500 mg/L	Boron (total)	Boys Rd - Well 3	<=5 MAC

# samples:	1	min:	< 0.0500 mg/L
# detects:	0	max:	< 0.0500 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromacil(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	Bromacil	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.005 mg/L	Bromate	Boys Rd - Well 3	<=0.01 MAC

# samples:	1	min:	< 0.005 mg/L
# detects:	0	max:	< 0.005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0010 mg/L	Bromodichloromethane (dichlorobromomethane)	Boys Rd - Well 3	<=0.016 MAC

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoform(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 1.0 ug/L	Bromoform	Boys Rd - Well 3	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoxynil(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000200 mg/L	Bromoxynil	Boys Rd - Well 3	<=0.005 MAC
08/18/2025 08:50 < 0.00010 mg/L	Bromoxynil	Boys Rd - Well 3	<=0.005 MAC

# samples:	2	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.020 ug/L	Butachlor	Boys Rd - Well 3	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000010 mg/L	Cadmium (total)	Boys Rd - Well 3	<=0.005 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 9,100 ug/L	Calcium (total)	Boys Rd - Well 3	

# samples:	1	min:	9,100 ug/L
------------	---	------	------------

# detects:	1	max:	9,100 ug/L
# non-detects:	0	avg:	9,100 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	Captan	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Carbon tetrachloride(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0005 mg/L	Carbon tetrachloride	Boys Rd - Well 3	<=0.003 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlordane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000050 mg/L	Chlordane	Boys Rd - Well 3	<=0.002 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 2.69 mg/L	Chloride	Boys Rd - Well 3	<=250 Secondary Standard

# samples:	1	min:	2.69 mg/L
# detects:	1	max:	2.69 mg/L
# non-detects:	0	avg:	2.69 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0010 mg/L	Chlorobenzene	Boys Rd - Well 3	<=0.1 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Chloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 2.0 ug/L	Chloroethane	Boys Rd - Well 3	
# samples:	1	min:	< 2.0 ug/L	
# detects:	0	max:	< 2.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chloroform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 1.0 ug/L	Chloroform	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chlorothalonil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Chlorothalonil	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Chlorpyrifos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000010 mg/L	Chlorpyrifos	Boys Rd - Well 3	<=0.09	MAC
# samples:	1	min:	< 0.000010 mg/L		
# detects:	0	max:	< 0.000010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chromium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00050 mg/L	Chromium (total)	Boys Rd - Well 3	<=0.1	MCL
# samples:	1	min:	< 0.00050 mg/L		
# detects:	0	max:	< 0.00050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chrysene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.050 ug/L	Chrysene	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

cis-1,2-Dichloroethylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	cis-1,2-Dichloroethylene	Boys Rd - Well 3	<=0.07	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.10 ug/L	Cobalt (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	0.00913 mg/L	Copper (total)	Boys Rd - Well 3	<=1	Secondary Standard

# samples:	1	min:	0.00913 mg/L
# detects:	1	max:	0.00913 mg/L
# non-detects:	0	avg:	0.00913 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Cyanazine	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0020 mg/L	Cyanide (total)	Boys Rd - Well 3	<=0.2	MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.010 ug/L	DDT + metabolites	Boys Rd - Well 3		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

delta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.050 ug/L	delta-BHC	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Deltamethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Deltamethrin	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diazinon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000020 mg/L	Diazinon	Boys Rd - Well 3	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dibenzo(a,h)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.010 ug/L	Dibenzo(a,h)anthracene	Boys Rd - Well 3	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 1.0 ug/L	Dibromochloromethane (Chlorodibromomethane)	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromomethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 1.0 ug/L	Dibromomethane	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dicamba(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.00010 mg/L	Dicamba	Boys Rd - Well 3	<=0.12 MAC
# samples:	1	min:	< 0.00010 mg/L	
# detects:	0	max:	< 0.00010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dichloromethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.0030 mg/L	Dichloromethane	Boys Rd - Well 3	<=0.005 MCL
# samples:	1	min:	< 0.0030 mg/L	
# detects:	0	max:	< 0.0030 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	

of Exceedences: 0

Dichlorvos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.100 ug/L	Dichlorvos	Boys Rd - Well 3	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Diclofop-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000100 mg/L	Diclofop-methyl	Boys Rd - Well 3	<=0.009	MAC
# samples:	1	min:	< 0.000100 mg/L		
# detects:	0	max:	< 0.000100 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Dieldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.010 ug/L	Dieldrin	Boys Rd - Well 3	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dimethoate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000200 mg/L	Dimethoate	Boys Rd - Well 3	<=0.02	MAC
# samples:	1	min:	< 0.000200 mg/L		
# detects:	0	max:	< 0.000200 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Dinoseb(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00010 mg/L	Dinoseb	Boys Rd - Well 3	<=0.007	MCL
# samples:	1	min:	< 0.00010 mg/L		
# detects:	0	max:	< 0.00010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Diquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0100 mg/L	Diquat	Boys Rd - Well 3	<=0.02	MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Disulfoton(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Disulfoton	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000200 mg/L	Diuron	Boys Rd - Well 3	<=0.15	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.010 ug/L	Endosulfan (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan sulfate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.050 ug/L	Endosulfan sulfate	Boys Rd - Well 3		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin aldehyde(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.020 ug/L	Endrin aldehyde	Boys Rd - Well 3		

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin ketone(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.020 ug/L	Endrin ketone	Boys Rd - Well 3	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000020 mg/L	Endrin	Boys Rd - Well 3	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Ethylbenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0010 mg/L	Ethylbenzene	Boys Rd - Well 3	<=0.7 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Ethylene dibromide / EDB(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.0003 mg/L	Ethylene dibromide / EDB	Boys Rd - Well 3	<=0.00002 MCL

# samples:	1	min:	< 0.0003 mg/L
# detects:	0	max:	< 0.0003 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fenchlorphos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	Fenchlorphos	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
------------	---	------	--------------

# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoranthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.030 ug/L	Fluoranthene	Boys Rd - Well 3	

# samples:	1	min:	< 0.030 ug/L
# detects:	0	max:	< 0.030 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluorene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Fluorene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.10 mg/L	Fluoride	Boys Rd - Well 3	<=4.0 MCL

# samples:	1	min:	< 0.10 mg/L
# detects:	0	max:	< 0.10 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 mg/L	Glyphosate	Boys Rd - Well 3	<=0.7 MCL

# samples:	1	min:	< 0.050 mg/L
# detects:	0	max:	< 0.050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Hardness (total, as CaCO3)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 27.0 mg/L	Hardness (total, as CaCO3)	Boys Rd - Well 3	

# samples:	1	min:	27.0 mg/L
# detects:	1	max:	27.0 mg/L

# non-detects:	0	avg:	27.0 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Heptachlor epoxide(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000010 mg/L	Heptachlor epoxide	Boys Rd - Well 3	<=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000010 mg/L	Heptachlor	Boys Rd - Well 3	<=0.0004 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Indeno(1,2,3-c,d)pyrene	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.01 mg/L	Iron (total)	Boys Rd - Well 3	<=0.3 Secondary Standard

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 0.00059 mg/L	Lead (total)	Boys Rd - Well 3	<=0.015 MCL

# samples:	1	min:	0.00059 mg/L
# detects:	1	max:	0.00059 mg/L
# non-detects:	0	avg:	0.00059 mg/L (based on 1 numerical results)

of Exceedences: 0

Lindane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000050 mg/L	Lindane	Boys Rd - Well 3	<=0.0002	MCL
# samples:	1	min:	< 0.000050 mg/L		
# detects:	0	max:	< 0.000050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Linuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.050 ug/L	Linuron	Boys Rd - Well 3	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Lithium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.10 ug/L	Lithium (total)	Boys Rd - Well 3	
# samples:	1	min:	< 0.10 ug/L	
# detects:	0	max:	< 0.10 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Magnesium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	1,020 ug/L	Magnesium (total)	Boys Rd - Well 3	
# samples:	1	min:	1,020 ug/L	
# detects:	1	max:	1,020 ug/L	
# non-detects:	0	avg:	1,020 ug/L (based on 1 numerical results)	
# of Exceedences:	0			

Malathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000100 mg/L	Malathion	Boys Rd - Well 3	<=0.19	MAC
# samples:	1	min:	< 0.000100 mg/L		
# detects:	0	max:	< 0.000100 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Manganese (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00020 mg/L	Manganese (total)	Boys Rd - Well 3	<=0.05	Secondary Standard

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000010 mg/L	Mercury (total)	Boys Rd - Well 3	<=0.002	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methoxychlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000050 mg/L	Methoxychlor	Boys Rd - Well 3	<=0.04	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Methyl parathion	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl tert-butyl ether / MTBE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 1.0 ug/L	Methyl tert-butyl ether / MTBE	Boys Rd - Well 3		

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000100 mg/L	Metolachlor	Boys Rd - Well 3	<=0.05	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000200 mg/L	Metribuzin	Boys Rd - Well 3	<=0.08	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.10 ug/L	Molybdenum (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.200 ug/L	Naphthalene	Boys Rd - Well 3		

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00040 mg/L	Nickel (total)	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	0.099 mg/L	Nitrate (as N)	Boys Rd - Well 3	<=10	MCL

# samples:	1	min:	0.099 mg/L
# detects:	1	max:	0.099 mg/L
# non-detects:	0	avg:	0.099 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.20 mg/L	Nitrilotriacetic acid / NTA	Boys Rd - Well 3	<=0.4	MAC

# samples:	1	min:	< 0.20 mg/L
# detects:	0	max:	< 0.20 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0050 mg/L	Paraquat	Boys Rd - Well 3	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Parathion	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Pentachloronitrobenzene / PCNB	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachlorophenol / PCP(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.00050 mg/L	Pentachlorophenol / PCP	Boys Rd - Well 3	<=0.001	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Permethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.010 ug/L	Permethrin	Boys Rd - Well 3		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025	6.66	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
* 02/18/2025	6.43	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
03/17/2025	6.50	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
* 04/22/2025	6.47	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
05/20/2025	6.77	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
06/16/2025	6.75	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
07/21/2025	6.76	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
08/18/2025	6.54	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
09/16/2025	6.77	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
10/20/2025	6.86	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard
12/10/2025	6.83	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard

# samples:	11	min:	6.43
# detects:	11	max:	6.86
# non-detects:	0	avg:	6.67 (based on 11 numerical results)
# of Exceedences:	2		

pH(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	7.27	pH	Boys Rd - Well 3	>=6.5, <=8.5	Secondary Standard

# samples:	1	min:	7.27
# detects:	1	max:	7.27

# non-detects:	0	avg:	7.27 (based on 1 numerical results)
# of Exceedences:	0		

Phenanthrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	Phenanthrene	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phorate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000100 mg/L	Phorate	Boys Rd - Well 3	<=0.002 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Picloram(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.00010 mg/L	Picloram	Boys Rd - Well 3	<=0.5 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.150 ug/L	Polychlorinated Biphenyls / PCBs (as arochlor total)	Boys Rd - Well 3	

# samples:	1	min:	< 0.150 ug/L
# detects:	0	max:	< 0.150 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 250 ug/L	Potassium (total)	Boys Rd - Well 3	

# samples:	1	min:	250 ug/L
------------	---	------	----------

# detects:	1	max:	250 ug/L
# non-detects:	0	avg:	250 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Prometon(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.300 ug/L	Prometon	Boys Rd - Well 3	

# samples:	1	min:	< 0.300 ug/L
# detects:	0	max:	< 0.300 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometryn(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.100 ug/L	Prometryn	Boys Rd - Well 3	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pyrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.020 ug/L	Pyrene	Boys Rd - Well 3	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Quinoline(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.050 ug/L	Quinoline	Boys Rd - Well 3	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.00050 mg/L	Selenium (total)	Boys Rd - Well 3	<=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Silicon (total, as Si)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	2,900 ug/L	Silicon (total, as Si)	Boys Rd - Well 3	
# samples:	1	min:	2,900 ug/L	
# detects:	1	max:	2,900 ug/L	
# non-detects:	0	avg:	2,900 ug/L (based on 1 numerical results)	
# of Exceedences:	0			

Silver (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.000050 mg/L	Silver (total)	Boys Rd - Well 3	<=0.1 Secondary Standard
# samples:	1	min:	< 0.000050 mg/L	
# detects:	0	max:	< 0.000050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Simazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.000200 mg/L	Simazine	Boys Rd - Well 3	<=0.004 MCL
# samples:	1	min:	< 0.000200 mg/L	
# detects:	0	max:	< 0.000200 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Sodium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	1.83 mg/L	Sodium (total)	Boys Rd - Well 3	<=160 MCL
# samples:	1	min:	1.83 mg/L	
# detects:	1	max:	1.83 mg/L	
# non-detects:	0	avg:	1.83 mg/L (based on 1 numerical results)	
# of Exceedences:	0			

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	29.1 ug/L	Strontium (total)	Boys Rd - Well 3	
# samples:	1	min:	29.1 ug/L	
# detects:	1	max:	29.1 ug/L	
# non-detects:	0	avg:	29.1 ug/L (based on 1 numerical results)	
# of Exceedences:	0			

Styrene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.0010 mg/L	Styrene	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.100 ug/L	Sulfotep	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 3,000 ug/L	Sulfur (total)	Boys Rd - Well 3		

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 1.4 mg/L	Sulphate	Boys Rd - Well 3	<=250	Secondary Standard

# samples:	1	min:	1.4 mg/L
# detects:	1	max:	1.4 mg/L
# non-detects:	0	avg:	1.4 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.020 mg/L	Sulphide (total, as S)	Boys Rd - Well 3		

# samples:	1	min:	< 0.020 mg/L
# detects:	0	max:	< 0.020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tebuthiuron(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50 < 0.200 ug/L	Tebuthiuron	Boys Rd - Well 3		

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temephos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.500 ug/L	Temephos	Boys Rd - Well 3	

# samples:	1	min:	< 0.500 ug/L
# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/20/2025 12.5 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
02/18/2025 14.1 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
03/17/2025 14.3 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
04/22/2025 14.0 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
05/20/2025 11.4 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
06/16/2025 13.8 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 07/21/2025 16.4 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 08/18/2025 16.3 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 09/16/2025 18 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 10/20/2025 17.8 degrees C	Temperature	Boys Rd - Well 3	<=15 AO
* 12/10/2025 16.0 degrees C	Temperature	Boys Rd - Well 3	<=15 AO

# samples:	11	min:	11.4 degrees C
# detects:	11	max:	18 degrees C
# non-detects:	0	avg:	15.0 degrees C (based on 11 numerical results)
# of Exceedences:	5		

Terbufos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50 < 0.000100 mg/L	Terbufos	Boys Rd - Well 3	<=0.001 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tetrachloroethylene / PCE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	Tetrachloroethylene / PCE	Boys Rd - Well 3	<=0.003	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Thallium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000020 mg/L	Thallium (total)	Boys Rd - Well 3	<=0.002	MCL
# samples:	1	min:	< 0.000020 mg/L		
# detects:	0	max:	< 0.000020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Time(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria
01/20/2025	1,030	Time	Boys Rd - Well 3	
02/18/2025	900	Time	Boys Rd - Well 3	
03/17/2025	1,030	Time	Boys Rd - Well 3	
04/22/2025	1,030	Time	Boys Rd - Well 3	
05/20/2025	915	Time	Boys Rd - Well 3	
06/16/2025	815	Time	Boys Rd - Well 3	
07/21/2025	1,100	Time	Boys Rd - Well 3	
08/18/2025	845	Time	Boys Rd - Well 3	
09/16/2025	905	Time	Boys Rd - Well 3	
10/20/2025	830	Time	Boys Rd - Well 3	
12/10/2025	930	Time	Boys Rd - Well 3	
# samples:	11	min:	815	
# detects:	11	max:	1,100	
# non-detects:	0	avg:	939 (based on 11 numerical results)	
# of Exceedences:	0			

Tin (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 0.20 ug/L	Tin (total)	Boys Rd - Well 3	
# samples:	1	min:	< 0.20 ug/L	
# detects:	0	max:	< 0.20 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Titanium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 5.0 ug/L	Titanium (total)	Boys Rd - Well 3		

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Toluene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	Toluene	Boys Rd - Well 3	<=1	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

trans-1,2-Dichloroethylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	trans-1,2-Dichloroethylene	Boys Rd - Well 3	<=0.1	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.100 ug/L	Triallate	Boys Rd - Well 3		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trichloroethylene / TCE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	Trichloroethylene / TCE	Boys Rd - Well 3	<=0.003	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trichlorofluoromethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/18/2025 08:50	< 1.0 ug/L	Trichlorofluoromethane	Boys Rd - Well 3	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Trifluralin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000200 mg/L	Trifluralin	Boys Rd - Well 3	<=0.045	MAC
# samples:	1	min:	< 0.000200 mg/L		
# detects:	0	max:	< 0.000200 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/20/2025	0.10 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
02/18/2025	0.089 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
03/17/2025	0.089 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
04/22/2025	0.093 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
05/20/2025	0.12 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
06/16/2025	0.09 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
* 07/21/2025	0.82 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
08/18/2025	0.10 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
09/16/2025	0.09 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
10/20/2025	0.09 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
12/10/2025	0.077 NTU	Turbidity	Boys Rd - Well 3	<=0.5	User-Defined
# samples:	11	min:	0.077 NTU		
# detects:	11	max:	0.82 NTU		
# non-detects:	0	avg:	0.160 NTU (based on 11 numerical results)		
# of Exceedences:	1	95th percentile:	0.820 NTU		

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.000020 mg/L	Uranium (total)	Boys Rd - Well 3	<=0.02	MAC
# samples:	1	min:	< 0.000020 mg/L		
# detects:	0	max:	< 0.000020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 5.0 ug/L	Vanadium (total)	Boys Rd - Well 3		

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vinyl chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0010 mg/L	Vinyl chloride	Boys Rd - Well 3	<=0.001	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Xylenes (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.0020 mg/L	Xylenes (total)	Boys Rd - Well 3	<=10	MCL

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	0.0125 mg/L	Zinc (total)	Boys Rd - Well 3	<=5	Secondary Standard

# samples:	1	min:	0.0125 mg/L
# detects:	1	max:	0.0125 mg/L
# non-detects:	0	avg:	0.0125 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/18/2025 08:50	< 0.10 ug/L	Zirconium (total)	Boys Rd - Well 3		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 5 (3-6-SR, 3B16D)

pH(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025	6.69	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
03/24/2025	6.64	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
04/28/2025	6.71	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
05/26/2025	6.76	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
06/23/2025	6.57	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
07/28/2025	6.66	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
08/25/2025	6.73	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
09/22/2025	6.78	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
10/27/2025	6.87	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
11/24/2025	6.71	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard
12/02/2025	6.73	pH	Boys Rd - Well 5	>=6.5, <=8.5	Secondary Standard

# samples:	11	min:	6.57
# detects:	11	max:	6.87
# non-detects:	0	avg:	6.71 (based on 11 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
* 02/24/2025	15.2 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
03/24/2025	14.3 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
04/28/2025	12.4 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
05/26/2025	13.3 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
06/23/2025	14.5 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 07/28/2025	15.9 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 08/25/2025	17.7 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 09/22/2025	18.7 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 10/27/2025	17.7 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 11/24/2025	17.4 degrees C	Temperature	Boys Rd - Well 5	<=15	AO
* 12/02/2025	17.5 degrees C	Temperature	Boys Rd - Well 5	<=15	AO

# samples:	11	min:	12.4 degrees C
# detects:	11	max:	18.7 degrees C
# non-detects:	0	avg:	15.9 degrees C (based on 11 numerical results)
# of Exceedences:	7		

Time(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria
02/24/2025	1,130	Time	Boys Rd - Well 5	
03/24/2025	1,110	Time	Boys Rd - Well 5	
04/28/2025	1,030	Time	Boys Rd - Well 5	
05/26/2025	830	Time	Boys Rd - Well 5	

Time(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria
06/23/2025	815	Time	Boys Rd - Well 5	
07/28/2025	830	Time	Boys Rd - Well 5	
08/25/2025	840	Time	Boys Rd - Well 5	
09/22/2025	1,100	Time	Boys Rd - Well 5	
10/27/2025	930	Time	Boys Rd - Well 5	
11/24/2025	830	Time	Boys Rd - Well 5	
12/02/2025	900	Time	Boys Rd - Well 5	

# samples:	11	min:	815
# detects:	11	max:	1,130
# non-detects:	0	avg:	940 (based on 11 numerical results)
# of Exceedences:	0		

Turbidity(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/24/2025	0.084 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
03/24/2025	0.088 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
04/28/2025	0.095 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
* 05/26/2025	0.91 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
* 06/23/2025	0.91 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
07/28/2025	0.08 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
08/25/2025	0.09 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
09/22/2025	0.08 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
10/27/2025	0.09 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
11/24/2025	0.08 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined
12/02/2025	0.07 NTU	Turbidity	Boys Rd - Well 5	<=0.5	User-Defined

# samples:	11	min:	0.07 NTU
# detects:	11	max:	0.91 NTU
# non-detects:	0	avg:	0.234 NTU (based on 11 numerical results)
# of Exceedences:	2	95th percentile:	0.910 NTU

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown
> means greater than upper detection limit shown
« means detected & less than number shown
» means detected & greater than number shown

* Indicates Criteria is exceeded