

June 15, 2022

File: 5620-55

Environmental Health Officer
Central Vancouver Island Health Region
1665 Grant Avenue
Nanaimo, BC V9S 5K7

Dear Environmental Health Officer

**Re: Chemainus Water System Water Quality Report
Premises Number 1310823
Report for the Period Jan 1/21 to Dec 31/21**

Please find the Municipality of North Cowichan's Water quality report for the Chemainus Water System attached.

Sincerely



Robert Bell
Manager, Utilities

robert.bell@northcowichan.ca



1 Operator Information

Contact Name Robert Bell Manager, Utilities
Phone 250-746-3100
Email robert.bell@northcowichan.ca

2 System Description

The Chemainus water system is supplied from the wells along the Chemainus River. The water is chlorinated at the well site prior to distribution. Water is then pumped from the well site into the Chemainus distribution system. Pumped well water in excess of the town's demand is delivered to two concrete reservoirs located on Copper Canyon Road.

3 Boil Advisories

None

4 Future Improvements

None proposed at this time

5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

6 Results

See below for the results of various water quality parameters.

Sincerely



Robert Bell

Manager, Utilities

cc Clay Reitsma Director, Engineering

Report Name: Chemainus, Water Quality Report

January 2021	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,027.71	1.41	0.6	0.15
2	2,948.05	1.49	0.75	0.19
3	2,932.72	1.61	0.79	0.16
4	2,957.66	1.95	0	0.13
5	2,981.50	1.61	0.58	0.12
6	2,979.66	1.48	0.68	0.12
7	3,022.88	1.68	0.73	0.18
8	2,990.65	1.91	0.69	0.15
9	2,908.45	1.76	0.77	0.12
10	2,916.96	1.48	0.73	0.12
11	3,013.32	1.68	0.69	0.12
12	3,044.61	1.69	0.66	0.12
13	2,930.67	1.56	0.62	0.16
14	2,939.24	1.66	0.65	0.12
15	2,953.38	1.9	0.59	0.12
16	2,795.65	1.42	0.63	0.12
17	2,690.82	1.68	0.61	0.12
18	2,643.03	1.31	0.57	0.12
19	2,765.83	1.42	0.6	0.12
20	2,960.61	1.46	0.63	0.12
21	2,966.59	1.29	0.6	0.12
22	2,904.22	1.57	0.62	0.12
23	2,810.96	1.47	0.61	0.12
24	2,753.05	1.54	0.63	0.12
25	2,844.03	1.55	0.61	0.12
26	2,916.67	1.44	0.63	0.12
27	2,823.62	1.64	0.61	0.12
28	2,821.02	1.39	0.65	0.12
29	2,927.53	1.59	0.64	0.12
30	2,896.64	1.52	0.58	0.11
31	2,811.87	1.47	0.62	0.12
Average	2,899.34	1.57	0.62	0.13
Minimum	2,643.03	1.29	0	0.11
Maximum	3,044.61	1.95	0.79	0.19
Count	31	31	31	31
Total	89,879.60			
95 Percentile				0.18
Exceedences	0	0	0	0
Median	2,927.53	1.55	0.63	0.12

February 2021	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,789.05	1.56	0	0.12
2	2,744.60	1.47	0.63	0.11
3	2,977.63	1.44	0.59	0.12
4	3,059.36	1.48	0.58	0.11
5	2,730.70	1.38	0.58	0.12
6	2,855.55	1.58	0.55	0.11
7	3,008.36	1.7	0.66	0.12
8	2,950.74	3.01	0.61	0.12
9	2,947.41	1.41	0.59	0.12
10	2,872.18	1.49	0.56	0.12
11	2,794.18	1.48	0.58	0.12
12	2,799.40	1.31	0.55	0.12
13	2,796.25	1.23	0.55	0.11
14	2,818.02	1.41	0.57	0.11
15	3,086.01	1.3	0.59	0.12
16	3,274.64	1.51	0.49	0.12
17	3,127.32	1.59	0.62	0.12
18	3,130.66	1.61	0.68	0.12
19	3,237.66	1.61	0.6	0.12
20	3,154.94	1.89	0.57	0.12
21	3,002.22	2.02	0.7	0.12
22	2,882.38	1.99	0.6	0.11
23	2,641.01	1.53	0.69	0.11
24	2,430.60	1.54	0.69	0.12
25	2,622.07	1.62	0.7	0.11
26	2,785.84	1.56	0.67	0.11
27	2,649.88	1.85	0.63	0.11
28	2,562.82	1.39	0.61	0.11

Average	2,883.27	1.61	0.59	0.12
Minimum	2,430.60	1.23	0	0.11
Maximum	3,274.64	3.01	0.7	0.12
Count	28	28	28	28
Total	80,731.48			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	2,863.87	1.54	0.60	0.12

March 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	2,577.25	1.44	0.6	0.11
2	2,727.93	1.53	0	0.11
3	2,777.64	1.57	0.61	0.11
4	2,730.71	1.68	0.62	0.11
5	2,533.43	2.02	0.64	0.12
6	2,459.37	1.48	0.62	0.11
7	2,644.08	1.55	0.59	0.11
8	2,771.07	1.65	0.62	0.11
9	2,752.69	2.56	0.64	0.12
10	2,721.68	1.42	0.62	0.12
11	2,743.54	1.59	0.61	0.11
12	2,788.16	1.52	0.65	0.11
13	2,756.91	1.65	0.57	0.12
14	2,694.64	2.75	0.64	0.12
15	2,757.29	1.46	0.55	0.12
16	2,688.35	1.45	0.53	0.12
17	2,564.03	1.4	0.62	0.11
18	2,748.20	1.39	0.61	0.11
19	2,880.31	1.67	0.58	0.11
20	2,793.29	1.52	0.64	0.12
21	2,732.84	1.43	0.61	0.11
22	2,805.46	1.5	0.57	0.12
23	2,860.70	1.53	0.58	0.11
24	2,871.58	1.62	0.6	0.12
25	2,703.61	1.67	0.63	0.11
26	2,683.90	1.48	0.69	0.12
27	2,887.56	1.72	0.62	0.12
28	2,862.22	1.64	0.67	0.11
29	2,893.94	1.71	0.56	0.12
30	2,958.18	1.61	0.68	0.12
31	2,930.90	1.64	0.69	0.12

Average	2,751.66	1.64	0.60	0.11
Minimum	2,459.37	1.39	0	0.11
Maximum	2,958.18	2.75	0.69	0.12
Count	31	31	31	31
Total	85,301.46			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	2,752.69	1.57	0.62	0.11

April 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	2,723.74	2.26	0.71	0.11
2	2,765.76	1.74	0.75	0.12
3	2,948.47	1.69	0.68	0.11
4	2,898.51	1.87	0.63	0.11
5	3,017.34	1.95	0.77	0.11
6	3,158.54	1.74	0.59	0.12
7	2,957.93	1.56	0.63	0.12
8	2,843.39	1.2	0.54	0.12
9	2,981.35	1.46	0	0.12
10	2,982.27	1.33	0.48	0.11
11	2,902.53	1.37	0.52	0.12
12	2,950.84	1.6	0.39	0.12
13	3,197.95	1.65	0	0.12
14	3,082.70	1.69	0.57	0.12
15	3,237.27	1.61	0.62	0.12
16	3,483.53	2.08	0.59	0.11
17	3,452.01	1.73	0.62	0.12
18	3,618.77	1.83	0.67	0.12
19	3,533.29	2.21	0.7	0.12
20	3,597.71	1.9	0.71	0.12
21	3,777.92	1.9	0.72	0.12
22	3,457.10	1.68	0.62	0.12
23	3,454.58	1.71	0.67	0.11
24	3,444.15	1.98	0.6	0.12
25	3,114.50	1.81	0.69	0.12
26	3,143.87	1.6	0.61	0.12
27	3,317.88	1.45	0.61	0.12
28	3,349.79	1.4	0	0.12
29	3,341.08	1.55	0.55	0.12
30	3,282.90	1.91	0.62	0.12

Average	3,200.59	1.72	0.56	0.12
Minimum	2,723.74	1.2	0	0.11
Maximum	3,777.92	2.26	0.77	0.12
Count	30	30	30	30
Total	96,017.67			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	3,178.25	1.70	0.62	0.12

May 2021	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,189.30	1.67	0.65	0.12
2	3,394.08	1.75	0.78	0.12
3	3,671.47	2.24	0.73	0.12
4	3,972.59	1.39	0.66	0.12
5	4,077.88	1.41	0.71	0.12
6	3,674.81	1.31	0.53	0.12
7	3,726.46	1.16	0.63	0.12
8	3,733.65	1.22	0.63	0.12
9	3,379.72	1.37	0.58	0.12
10	3,558.34	1.28	0.62	0.12
11	3,797.51	1.27	0.57	0.12
12	3,812.84	1.19	0	0.12
13	3,904.67	1.36	0.6	0.12
14	4,230.65	1.18	0.62	0.12
15	3,941.83	1.3	0.57	0.12
16	4,105.38	1.12	0.56	0.12
17	4,360.11	1.47	0.59	0.12
18	4,433.50	1.16	0.62	0.12
19	4,354.24	1.09	0.61	0.12
20	4,496.49	1.2	0.56	0.11
21	4,904.02	1.3	0.57	0.12
22	4,600.38	1.18	0.63	0.12
23	3,990.58	1.37	0.66	0.12
24	3,878.67	1.22	0.65	0.12
25	3,904.44	1.34	0.63	0.12
26	3,790.64	1.22	0.68	0.12
27	3,695.84	1.39	0.56	0.12
28	3,910.29	1.4	0.39	0.12
29	4,295.49	1.35	0.6	0.12
30	4,209.84	1.08	0.52	0.12
31	4,292.46	1.27	0.5	0.12

Average	3,977.04	1.33	0.59	0.12
Minimum	3,189.30	1.08	0	0.11
Maximum	4,904.02	2.24	0.78	0.12
Count	31	31	31	31
Total	123,288.17			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	3,910.29	1.30	0.61	0.12

June 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	4,511.82	1.31	0.58	0.12
2	4,724.97	1.43	0.57	0.12
3	5,018.62	1.06	0.63	0.12
4	4,707.59	1.24	0.65	0.12
5	4,231.96	1.34	0.7	0.12
6	3,832.80	1.29	0.71	0.12
7	3,741.58	1.3	0.63	0.12
8	3,807.55	1.31	0.62	0.12
9	3,994.36	1.33	0.57	0.12
10	3,837.46	1.19	0.6	0.12
11	3,681.64	1.21	0.5	0.12
12	3,757.68	1.11	0.54	0.12
13	3,496.29	1.03	0.61	0.12
14	3,340.15	1.22	0	0.12
15	3,708.84	1.13	0.57	0.12
16	3,679.94	0.95	0.55	0.11
17	4,288.72	0.96	0.53	0.12
18	4,382.22	1.11	0.3	0.12
19	4,286.57	1.07	0.26	0.13
20	4,637.67	1.45	0.65	0.12
21	4,964.07	1.43	0.68	0.11
22	4,982.51	1.32	0.53	0.12
23	5,021.07	1.5	0.59	0.12
24	5,038.77	1.2	0.61	0.12
25	5,210.73	1.49	0.68	0.12
26	5,339.37	1.67	0.73	0.13
27	5,497.25	1.55	0.86	0.11
28	5,855.39	1.23	0.55	0.11
29	5,872.11	0.91	0.61	0.11
30	5,840.07	1.47	0.31	0.12

Average	4,509.66	1.26	0.56	0.12
Minimum	3,340.15	0.91	0	0.11
Maximum	5,872.11	1.67	0.86	0.13
Count	30	30	30	30
Total	135,289.77			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	4,447.02	1.27	0.60	0.12

July 2021	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	5,418.47	1.7	1.09	0.13
2	5,045.28	1.86	1.02	0.12
3	5,108.47	1.83	1.15	0.13
4	5,126.00	1.92	1	0.13
5	5,314.16	1.7	0.7	0.12
6	5,356.81	1.17	0.58	0.11
7	5,292.72	1.43	0.63	0.12
8	5,283.32	1.02	0.64	0.12
9	5,129.99	1.13	0.59	0.12
10	4,861.88	1	0.58	0.12
11	5,064.39	0.93	0.59	0.12
12	5,171.25	1.13	0.6	0.12
13	4,927.17	1.16	0.61	0.12
14	5,024.03	1.2	0.65	0.12
15	5,105.33	1.32	0.63	0.12
16	4,690.47	1.21	0.61	0.12
17	4,290.98	1.15	0.58	0.12
18	4,286.12	1.31	0.56	0.12
19	4,644.48	1.3	0.56	0.12
20	4,658.75	1.32	0.7	0.12
21	4,581.49	1.31	0.78	0.12
22	4,572.98	1.52	0.72	0.12
23	4,567.13	1.37	0.74	0.12
24	4,215.86	1.37	0.77	0.12
25	4,262.90	1.21	0.77	0.12
26	4,330.83	1.31	0.71	0.12
27	4,544.30	1.37	0.73	0.12
28	4,527.47	1.33	0.64	0.12
29	4,629.26	1.3	0.64	0.12
30	4,654.02	1.31	0.69	0.12
31	4,330.47	1.18	0.64	0.12

Average	4,806.99	1.33	0.71	0.12
Minimum	4,215.86	0.93	0.56	0.11
Maximum	5,418.47	1.92	1.15	0.13
Count	31	31	31	31
Total	149,016.78			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	4,690.47	1.31	0.64	0.12

August 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	4,330.81	1.31	0.58	0.12
2	4,528.19	1.17	0.64	0.12
3	4,630.54	1.49	0.63	0.12
4	4,648.50	1.22	0.59	0.12
5	4,727.68	1.39	0.68	0.12
6	4,568.69	1.44	0.62	0.12
7	4,079.55	1.41	0.59	0.12
8	4,175.47	1.48	0.57	0.12
9	4,348.60	1.22	0.51	0.12
10	4,381.49	1.26	0.57	0.12
11	4,419.15	1.51	0.61	0.12
12	4,251.10	1.24	0.55	0.12
13	4,368.60	1.5	0.61	0.12
14	4,390.02	1.47	0.56	0.12
15	4,006.76	1.65	0.6	0.12
16	3,854.64	1.4	0.64	0.12
17	4,071.67	1.33	0.61	0.12
18	4,186.56	1.31	0.52	0.12
19	4,010.02	1.27	0.54	0.12
20	3,830.14	1.22	0	0.12
21	4,169.25	1.22	0.59	0.12
22	6,501.97	1.25	0.58	0.12
23	5,981.33	1.4	0.6	0.12
24	3,869.42	1.58	0.62	0.12
25	3,975.69	1.17	0.56	0.12
26	3,872.73	1.24	0.49	0.13
27	3,707.55	1.18	0.51	0.12
28	4,010.27	1.24	0.55	0.12
29	3,712.46	1.08	0.51	0.12
30	3,797.55	1.38	0.47	0.12
31	3,937.56	1.25	0.55	0.12

Average	4,301.42	1.33	0.56	0.12
Minimum	3,707.55	1.08	0	0.12
Maximum	6,501.97	1.65	0.68	0.13
Count	31	31	31	31
Total	133,343.96			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	4,175.47	1.31	0.58	0.12

September 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	3,553.05	1.25	0.5	0.13
2	3,575.89	1.37	0	0.12
3	3,729.67	1.34	0.62	0.12
4	3,303.02	1.12	0.71	0.12
5	3,348.65	1.31	0.69	0.12
6	3,414.00	1.26	0.67	0.12
7	3,492.61	1.33	0.66	0.12
8	3,534.52	1.22	0.6	0.13
9	3,421.90	1.21	0.66	0.13
10	3,325.21	1.51	0.69	0.12
11	3,311.01	1.25	0.65	0.12
12	3,318.66	1.33	0.69	0.12
13	3,442.92	1.35	0.62	0.13
14	3,529.27	1.24	0	0.12
15	3,129.77	1.45	0.62	0.13
16	3,328.33	1.26	0.6	0.13
17	3,364.71	1.21	0	0.12
18	3,161.95	1.23	0.6	0.13
19	3,043.93	1.28	0.69	0.12
20	3,145.18	1.67	0.72	0.13
21	3,233.66	1.53	0.59	0.13
22	3,122.01	1.18	0	0.13
23	3,123.53	1.12	0.53	0.13
24	3,376.25	1.28	0.42	0.13
25	3,260.30	1.46	0.47	0.12
26	3,104.03	1.41	0.56	0.13
27	3,079.05	1.53	0	0.12
28	3,216.77	1.07	0.34	0.12
29	3,237.56	1.19	0	0.12
30	3,148.84	1.27	0.39	0.12

Average	3,312.54	1.31	0.48	0.12
Minimum	3,043.93	1.07	0	0.12
Maximum	3,729.67	1.67	0.72	0.13
Count	30	30	30	30
Total	99,376.25			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	3,314.84	1.28	0.60	0.12

October 2021	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	4,091.99	1.2	0	0.12
2	4,502.15	1.1	0.36	0.12
3	3,079.61	1.11	0.39	0.13
4	3,145.16	1.33	0.29	0.12
5	3,189.52	1.26	0.38	0.13
6	3,137.96	1.35	0.67	0.13
7	2,953.84	1.44	0.61	0.13
8	3,040.25	1.32	0.7	0.13
9	3,174.52	1.57	0.64	0.13
10	3,060.76	1.27	0.76	0.13
11	3,004.30	1.41	0.78	0.13
12	3,056.93	1.24	0.76	0.13
13	3,093.91	1.36	0.64	0.13
14	3,113.55	1.25	0	0.13
15	3,197.28	1.2	0.61	0.13
16	3,117.23	1.19	0.59	0.13
17	3,079.00	1.17	0.59	0.13
18	3,109.17	1.07	0.6	0.13
19	3,146.09	1.23	0.65	0.13
20	3,135.47	1.19	0.62	0.13
21	3,162.19	1.19	0.63	0.13
22	3,106.50	1.13	0.59	0.13
23	2,926.11	1.1	0.65	0.13
24	2,888.05	1.33	0.64	0.13
25	3,129.62	1.44	0.64	0.13
26	3,255.64	1.15	0.62	0.13
27	3,141.69	1.05	0	0.13
28	2,914.61	1	0.67	0.13
29	2,953.94	1.05	0.59	0.13
30	3,085.52	1.04	0.65	0.12
31	3,050.64	1.02	0.65	0.13

Average	3,162.68	1.22	0.55	0.13
Minimum	2,888.05	1	0	0.12
Maximum	4,502.15	1.57	0.78	0.13
Count	31	31	31	31
Total	98,043.20			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	3,109.17	1.20	0.62	0.13

November 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	3,065.19	1.06	0.62	0.13
2	3,085.79	0.93	0.56	0.13
3	3,067.84	0.9	0.56	0.13
4	3,103.48	1.06	0.56	0.13
5	3,159.10	1.08	0.59	0.13
6	3,033.50	1.06	0.59	0.13
7	2,781.86	1.04	0.61	0.12
8	2,789.92	1.05	0.62	0.13
9	2,995.77	1.24	0.63	0.13
10	3,107.26	1.12	0.61	0.13
11	3,005.13	1.09	0.62	0.13
12	2,934.36	1.14	0.36	0.13
13	2,933.15	1.1	0.35	0.13
14	2,948.05	1.03	0.35	0.14
15	2,985.53	0.91	0.34	0.15
16	2,914.63	1.07	0.35	0.13
17	2,982.11	1.15	0.41	0.13
18	3,033.68	1.13	0.52	0.13
19	3,115.71	1.21	0.48	0.13
20	3,116.69	1.13	0.51	0.13
21	3,086.41	0.99	0.48	0.13
22	3,181.71	1.1	0	0.13
23	3,313.52	1.01	0.46	0.13
24	3,237.58	1.04	0.53	0.13
25	3,112.03	1.08	0.56	0.13
26	3,051.22	1.16	0.47	0.13
27	2,999.42	1.07	0.43	0.13
28	3,151.68	1.13	0.38	0.12
29	3,362.80	1.06	0.46	0.13
30	3,403.48	1.14	0.48	0.12

Average	3,068.62	1.08	0.48	0.13
Minimum	2,781.86	0.9	0	0.12
Maximum	3,403.48	1.24	0.63	0.15
Count	30	30	30	30
Total	92,058.60			
95 Percentile				0.14
Exceedences	0	0	0	0
Median	3,066.52	1.08	0.50	0.13

December 2021	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	3,403.71	1.17	0.43	0.12
2	3,328.04	1.15	0.43	0.12
3	3,205.46	1.1	0.43	0.13
4	3,279.95	1.03	0.44	0.12
5	3,462.97	1.11	0.55	0.13
6	3,487.49	1.21	0.52	0.13
7	3,371.11	0.92	0.4	0.13
8	3,162.32	1.01	0.42	0.13
9	3,266.59	1.02	0.45	0.12
10	3,477.00	1.06	0.41	0.12
11	3,417.65	0.9	0.38	0.13
12	3,355.26	0.99	0.49	0.13
13	3,318.06	1.01	0.49	0.13
14	3,260.76	0.84	0.5	0.13
15	3,269.73	0.9	0.44	0.12
16	3,458.17	0.95	0.47	0.12
17	3,559.81	0.86	0.48	0.13
18	3,333.80	0.89	0.45	0.12
19	3,478.37	0.9	0.47	0.13
20	3,423.10	0.88	0.41	0.13
21	3,383.32	0.94	0.41	0.13
22	3,257.00	0.92	0.46	0.13
23	3,482.19	0.9	0.42	0.13
24	3,643.22	0.94	0.39	0.13
25	3,394.01	0.9	0.44	0.13
26	3,305.96	1.06	0.38	0.12
27	3,337.53	0.94	0.38	0.12
28	3,328.26	0.87	0.33	0.13
29	3,356.87	0.87	0.41	0.13
30	3,659.79	0.84	0.36	0.13
31	3,624.74	0.86	0.35	0.12

Average	3,390.07	0.97	0.43	0.13
Minimum	3,162.32	0.84	0.33	0.12
Maximum	3,659.79	1.21	0.55	0.13
Count	31	31	31	31
Total	105,092.24			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	3,371.11	0.94	0.43	0.13

* indicates Geometric Mean
** indicates Intraday Average

DISINFECTANTS

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.73 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/12/2021	0.63 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/19/2021	0.63 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
01/25/2021	0.65 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/02/2021	0.76 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/08/2021	0.68 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/17/2021	0.61 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
02/23/2021	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/03/2021	0.70 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/10/2021	0.68 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/15/2021	0.89 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/22/2021	0.59 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
03/30/2021	0.64 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
04/06/2021	0.48 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
04/12/2021	0.47 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
05/17/2021	0.67 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
05/26/2021	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
06/14/2021	0.65 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
06/22/2021	0.88 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/06/2021	0.79 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/14/2021	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/19/2021	0.68 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
07/26/2021	0.72 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/16/2021	0.55 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/24/2021	0.54 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
08/30/2021	0.61 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/13/2021	0.77 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/22/2021	0.56 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
09/29/2021	0.32 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/05/2021	0.62 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/15/2021	0.65 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
10/19/2021	0.69 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
11/02/2021	0.54 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
11/16/2021	0.25 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
11/23/2021	0.44 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/01/2021	0.64 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/07/2021	0.64 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
12/13/2021 0.61 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/20/2021 0.51 mg/L	Free Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined

# samples:	39	min:	0.25 mg/L
# detects:	39	max:	0.89 mg/L
# non-detects:	0	avg:	0.63 mg/L (based on 39 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0.46 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/12/2021 0.34 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/19/2021 0.21 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/25/2021 0.35 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/01/2021 0.56 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/08/2021 0.26 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/23/2021 0.41 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/01/2021 0.34 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/10/2021 0.25 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/17/2021 0.32 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/22/2021 0.35 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/30/2021 0.35 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/06/2021 0.46 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/13/2021 0.09 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/18/2021 0.48 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/26/2021 0.22 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/15/2021 0.28 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/22/2021 0.22 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/06/2021 0.45 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/14/2021 0.38 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/20/2021 0.61 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/28/2021 0.58 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/03/2021 0.27 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 08/17/2021 0.04 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/24/2021 0.06 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/30/2021 0.06 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 09/07/2021 0.01 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
09/13/2021 0.05 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 10/01/2021 0.00 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/14/2021 0.27 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/20/2021 0.65 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/01/2021 0.16 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/17/2021 0.22 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/26/2021 0.10 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/29/2021 0.15 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/09/2021 0.15 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/16/2021 0.28 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/23/2021 0.36 mg/L	Free Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined

# samples:	38	min:	0.00 mg/L
# detects:	38	max:	0.65 mg/L
# non-detects:	0	avg:	0.28 mg/L (based on 38 numerical results)
# of Exceedences:	3		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0.75 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/12/2021 0.74 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/19/2021 0.59 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/25/2021 0.68 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/01/2021 0.75 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/08/2021 0.77 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/17/2021 0.68 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/23/2021 0.68 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/02/2021 0.65 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/10/2021 0.57 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/15/2021 0.56 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/22/2021 0.54 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/30/2021 0.59 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/06/2021 0.57 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/12/2021 0.56 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/17/2021 0.59 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/26/2021 0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/02/2021 0.78 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/14/2021 0.66 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/22/2021 0.85 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/06/2021 0.81 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/13/2021 0.64 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/19/2021 0.72 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/27/2021 0.70 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/12/2021 0.63 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/16/2021 0.66 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
08/24/2021	0.46 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/31/2021	0.67 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/13/2021	0.70 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/20/2021	0.66 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/29/2021	0.48 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/05/2021	0.51 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/13/2021	0.72 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/19/2021	0.66 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/02/2021	0.47 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/16/2021	0.45 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/24/2021	0.46 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/02/2021	0.58 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/09/2021	0.58 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/13/2021	0.65 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/23/2021	0.70 mg/L	Free Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined

# samples:	41	min:	0.45 mg/L
# detects:	41	max:	0.85 mg/L
# non-detects:	0	avg:	0.64 mg/L (based on 41 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/12/2021	0.65 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
01/19/2021	0.48 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
01/26/2021	0.57 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/02/2021	0.61 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/08/2021	0.60 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/17/2021	0.60 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/23/2021	0.76 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/02/2021	0.48 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/10/2021	0.54 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/15/2021	0.56 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/23/2021	0.54 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/29/2021	0.54 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
04/06/2021	0.51 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
04/13/2021	0.43 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
05/17/2021	0.45 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
05/26/2021	0.48 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
06/02/2021	0.55 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
06/14/2021	0.64 mg/L	Free Cl2	10139 Island View Close	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
06/22/2021	0.70 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
07/08/2021	0.67 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
07/13/2021	0.53 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
07/19/2021	0.47 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
07/27/2021	0.50 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
08/16/2021	0.45 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
08/24/2021	0.26 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
08/31/2021	0.31 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
09/13/2021	0.56 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
09/20/2021	0.40 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
09/29/2021	0.42 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
10/07/2021	0.41 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
10/13/2021	0.61 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
10/19/2021	0.51 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
11/02/2021	0.48 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
11/16/2021	0.37 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
11/26/2021	0.42 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/02/2021	0.40 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/07/2021	0.43 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/13/2021	0.46 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/21/2021	0.44 mg/L	Free Cl2	10139 Island View Close >=0.05, <=4 User-Defined

# samples:	39	min:	0.26 mg/L
# detects:	39	max:	0.76 mg/L
# non-detects:	0	avg:	0.51 mg/L (based on 39 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/05/2021	0.82 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
01/12/2021	0.72 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
01/19/2021	0.61 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
01/25/2021	0.62 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/02/2021	0.69 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/08/2021	0.820 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/17/2021	0.82 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/23/2021	0.66 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/02/2021	0.61 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/10/2021	0.53 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/17/2021	0.71 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/23/2021	0.50 mg/L	Free Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
03/29/2021	0.66 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/06/2021	0.59 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/12/2021	0.64 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/18/2021	0.52 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/25/2021	0.52 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/02/2021	1.07 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/15/2021	0.63 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/21/2021	0.70 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/06/2021	0.73 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/14/2021	0.58 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/20/2021	0.70 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/26/2021	0.75 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/17/2021	0.72 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/23/2021	0.56 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/31/2021	0.51 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/13/2021	0.68 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/27/2021	0.63 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/07/2021	0.58 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/13/2021	0.81 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/20/2021	0.67 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/25/2021	0.68 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/01/2021	0.49 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/17/2021	0.52 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/22/2021	0.43 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/01/2021	0.52 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/09/2021	0.52 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/15/2021	0.39 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/23/2021	0.52 mg/L	Free Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined

# samples:	40	min:	0.39 mg/L
# detects:	40	max:	1.07 mg/L
# non-detects:	0	avg:	0.636 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/12/2021	0.67 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/19/2021	0.72 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/25/2021	0.60 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/02/2021	0.67 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/08/2021	0.59 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/18/2021	0.51 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/23/2021	0.56 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/08/2021	0.68 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/17/2021	0.61 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/22/2021	0.56 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/29/2021	0.62 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/06/2021	0.772 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/12/2021	0.54 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/18/2021	0.57 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/26/2021	0.57 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/02/2021	0.91 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/22/2021	0.94 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/08/2021	0.75 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/12/2021	0.56 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/20/2021	0.66 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/27/2021	0.68 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/09/2021	0.60 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/17/2021	0.61 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
08/24/2021 0.52 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
08/30/2021 0.53 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
09/13/2021 0.55 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
09/22/2021 0.71 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
09/27/2021 0.51 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
10/07/2021 0.37 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
10/12/2021 0.54 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
11/01/2021 0.46 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
11/08/2021 0.65 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
11/17/2021 0.53 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
11/25/2021 0.25 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
12/06/2021 0.36 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
12/16/2021 0.46 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
12/20/2021 0.44 mg/L	Free Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined

# samples:	37	min:	0.25 mg/L
# detects:	37	max:	0.94 mg/L
# non-detects:	0	avg:	0.590 mg/L (based on 37 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/12/2021 0.79 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
01/19/2021 0.62 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
01/25/2021 0.47 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/02/2021 0.81 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/08/2021 0.76 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/17/2021 0.55 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/23/2021 0.88 mg/L	Free Cl2	3220 Dogwood	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
03/02/2021	0.62 mg/L	Free Cl2	3220 Dogwood
03/10/2021	0.54 mg/L	Free Cl2	3220 Dogwood
03/17/2021	0.53 mg/L	Free Cl2	3220 Dogwood
03/23/2021	0.49 mg/L	Free Cl2	3220 Dogwood
03/29/2021	0.52 mg/L	Free Cl2	3220 Dogwood
04/06/2021	0.52 mg/L	Free Cl2	3220 Dogwood
04/12/2021	0.54 mg/L	Free Cl2	3220 Dogwood
05/18/2021	0.56 mg/L	Free Cl2	3220 Dogwood
05/25/2021	0.64 mg/L	Free Cl2	3220 Dogwood
06/02/2021	1.13 mg/L	Free Cl2	3220 Dogwood
06/15/2021	0.52 mg/L	Free Cl2	3220 Dogwood
06/21/2021	0.65 mg/L	Free Cl2	3220 Dogwood
07/08/2021	0.68 mg/L	Free Cl2	3220 Dogwood
07/13/2021	0.58 mg/L	Free Cl2	3220 Dogwood
07/20/2021	0.68 mg/L	Free Cl2	3220 Dogwood
07/26/2021	0.66 mg/L	Free Cl2	3220 Dogwood
08/17/2021	0.44 mg/L	Free Cl2	3220 Dogwood
08/23/2021	0.48 mg/L	Free Cl2	3220 Dogwood
08/31/2021	0.54 mg/L	Free Cl2	3220 Dogwood
09/10/2021	0.44 mg/L	Free Cl2	3220 Dogwood
09/13/2021	0.66 mg/L	Free Cl2	3220 Dogwood
09/29/2021	0.38 mg/L	Free Cl2	3220 Dogwood
10/07/2021	0.66 mg/L	Free Cl2	3220 Dogwood
10/13/2021	0.74 mg/L	Free Cl2	3220 Dogwood
10/20/2021	0.59 mg/L	Free Cl2	3220 Dogwood
10/25/2021	0.61 mg/L	Free Cl2	3220 Dogwood
11/02/2021	0.45 mg/L	Free Cl2	3220 Dogwood
11/17/2021	0.46 mg/L	Free Cl2	3220 Dogwood
11/22/2021	0.34 mg/L	Free Cl2	3220 Dogwood
12/01/2021	0.57 mg/L	Free Cl2	3220 Dogwood
12/09/2021	0.47 mg/L	Free Cl2	3220 Dogwood
12/15/2021	0.49 mg/L	Free Cl2	3220 Dogwood
12/20/2021	0.63 mg/L	Free Cl2	3220 Dogwood

# samples:	40	min:	0.34 mg/L
# detects:	40	max:	1.13 mg/L
# non-detects:	0	avg:	0.59 mg/L (based on 40 numerical results)
# of Exceedences:	0		



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.90 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
01/12/2021	0.67 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
01/19/2021	0.67 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
01/25/2021	0.72 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/01/2021	0.80 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/08/2021	0.78 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/17/2021	0.64 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/23/2021	0.59 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/01/2021	0.54 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/10/2021	0.67 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/17/2021	0.63 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/22/2021	0.69 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/30/2021	0.55 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
04/06/2021	0.48 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
04/12/2021	0.54 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
05/18/2021	0.68 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
05/26/2021	0.79 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
06/02/2021	1.23 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
06/15/2021	0.71 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
06/22/2021	0.82 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/06/2021	0.73 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/14/2021	0.73 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/20/2021	0.75 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/27/2021	0.76 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/03/2021	0.53 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/12/2021	0.82 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/17/2021	0.56 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/24/2021	0.50 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/30/2021	0.59 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
09/07/2021	0.71 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
09/13/2021	0.82 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
09/29/2021	0.48 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
10/05/2021	0.45 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
10/13/2021	0.72 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
10/20/2021	0.68 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
11/01/2021	0.69 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
11/17/2021	0.49 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
11/24/2021	0.42 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
11/29/2021	0.61 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
12/09/2021	0.53 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
12/16/2021	0.52 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
12/23/2021	0.70 mg/L	Free Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined

# samples:	42	min:	0.42 mg/L
# detects:	42	max:	1.23 mg/L
# non-detects:	0	avg:	0.66 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.52 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
01/12/2021	0.60 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
01/19/2021	0.50 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
01/26/2021	0.75 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
02/01/2021	0.59 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
02/08/2021	0.70 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
02/17/2021	0.46 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
02/23/2021	0.60 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
03/01/2021	0.47 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
03/10/2021	0.73 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
03/17/2021	0.63 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
03/22/2021	0.62 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
03/29/2021	0.61 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
04/06/2021	0.39 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
04/13/2021	0.43 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
05/18/2021	0.45 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
05/26/2021	0.50 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
06/15/2021	0.53 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
06/22/2021	0.73 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
07/06/2021	0.67 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
07/13/2021	0.57 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
07/20/2021	0.56 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
07/28/2021	0.55 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
08/03/2021	0.40 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
08/18/2021	0.45 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
08/24/2021	0.50 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
08/30/2021	0.39 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
09/07/2021	0.26 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
09/13/2021	0.45 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined
09/24/2021	0.31 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
10/01/2021	0.31 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/05/2021	0.47 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/13/2021	0.55 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/20/2021	0.58 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/01/2021	0.37 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/17/2021	0.36 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/24/2021	0.36 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/29/2021	0.33 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/07/2021	0.40 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/16/2021	0.33 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/20/2021	0.56 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/31/2021	0.47 mg/L	Free Cl2	Ferry Terminal	>=0.05, <=4	User-Defined

# samples:	42	min:	0.26 mg/L
# detects:	42	max:	0.75 mg/L
# non-detects:	0	avg:	0.50 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/12/2021	0.81 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/19/2021	0.59 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/25/2021	0.63 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/02/2021	0.75 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/08/2021	0.48 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/17/2021	0.64 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/23/2021	0.65 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/03/2021	0.67 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/10/2021	0.59 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/17/2021	0.74 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/22/2021	0.63 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/30/2021	0.55 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/06/2021	0.66 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/12/2021	0.49 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/18/2021	0.68 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/25/2021	0.76 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/15/2021	0.72 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/21/2021	0.67 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/06/2021	0.77 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/12/2021	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/19/2021	0.75 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
07/26/2021	0.69 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/06/2021	0.63 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/12/2021	0.68 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/17/2021	0.93 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/23/2021	0.65 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/30/2021	0.56 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/08/2021	0.67 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/13/2021	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/20/2021	0.78 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/27/2021	0.49 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/07/2021	0.69 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/15/2021	0.80 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/20/2021	0.71 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/26/2021	0.63 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/02/2021	0.56 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/17/2021	0.45 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/23/2021	0.61 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/01/2021	0.59 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/07/2021	0.58 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/15/2021	0.83 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/20/2021	0.83 mg/L	Free Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined

# samples:	42	min:	0.45 mg/L
# detects:	42	max:	0.93 mg/L
# non-detects:	0	avg:	0.67 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/05/2021	0.89 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
01/12/2021	0.74 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
01/19/2021	0.77 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
01/25/2021	0.71 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
02/02/2021	0.82 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
02/08/2021	0.45 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
02/23/2021	0.79 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
03/08/2021	0.57 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
03/17/2021	0.72 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
03/22/2021	0.55 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
03/29/2021	0.72 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
04/06/2021	0.54 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
04/12/2021	0.46 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
05/18/2021	0.62 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
05/26/2021	0.78 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
06/02/2021	1.19 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
06/15/2021	0.58 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
06/22/2021	0.87 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
07/08/2021	0.81 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
07/12/2021	0.76 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
07/20/2021	0.62 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
07/27/2021	0.65 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
08/09/2021	0.53 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
08/17/2021	0.86 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
08/24/2021	0.62 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
08/31/2021	0.58 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
09/13/2021	0.60 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
09/22/2021	0.51 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
10/01/2021	0.45 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
10/07/2021	0.86 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
10/12/2021	0.62 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
10/20/2021	0.58 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
11/02/2021	0.49 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
11/08/2021	0.53 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
11/17/2021	0.49 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
11/25/2021	0.49 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
12/01/2021	0.58 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
12/06/2021	0.41 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
12/16/2021	0.81 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
12/20/2021	0.81 mg/L	Free Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined

# samples:	40	min:	0.41 mg/L
# detects:	40	max:	1.19 mg/L
# non-detects:	0	avg:	0.66 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/05/2021	0.62 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
01/12/2021	0.63 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
01/19/2021	0.55 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
01/26/2021	0.79 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
02/01/2021	0.62 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
02/08/2021	0.74 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
02/17/2021	0.63 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
02/23/2021	0.58 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
03/01/2021	0.60 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
03/10/2021	0.74 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
03/17/2021	0.58 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
03/22/2021	0.65 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
03/29/2021	0.55 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
04/06/2021	0.62 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
04/13/2021	0.45 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
05/18/2021	0.53 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
05/26/2021	0.51 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
06/15/2021	0.51 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
06/22/2021	0.71 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
07/06/2021	0.65 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
07/13/2021	0.47 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
07/20/2021	0.53 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
07/28/2021	0.54 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
08/03/2021	0.41 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
08/18/2021	0.53 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
08/24/2021	0.39 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
08/30/2021	0.44 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
09/07/2021	0.40 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
09/13/2021	0.43 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
09/24/2021	0.36 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/01/2021	0.36 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/05/2021	0.55 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/13/2021	0.48 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
10/20/2021	0.61 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/01/2021	0.41 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/17/2021	0.41 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/24/2021	0.41 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
11/29/2021	0.41 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/07/2021	0.42 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/16/2021	0.37 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/20/2021	0.54 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined
12/31/2021	0.67 mg/L	Total Cl2	Ferry Terminal	>=0.05, <=4	User-Defined

# samples:	42	min:	0.36 mg/L
# detects:	42	max:	0.79 mg/L



non-detects: 0 avg: 0.53 mg/L (based on 42 numerical results)
 # of Exceedences: 0

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/05/2021	0.77 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
01/12/2021	0.67 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
01/19/2021	0.70 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
01/25/2021	0.67 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
02/02/2021	0.80 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
02/08/2021	0.70 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
02/17/2021	0.61 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
02/23/2021	0.66 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
03/03/2021	0.61 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
03/10/2021	0.73 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
03/15/2021	0.71 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
03/22/2021	0.61 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
03/30/2021	0.76 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
04/06/2021	0.66 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
04/12/2021	0.49 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
05/17/2021	0.66 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
05/26/2021	0.76 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
06/14/2021	0.70 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
06/22/2021	0.99 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
07/06/2021	0.82 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
07/14/2021	0.71 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
07/19/2021	0.64 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
07/26/2021	0.70 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
08/16/2021	0.57 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
08/24/2021	0.66 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
08/30/2021	0.74 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
09/13/2021	0.76 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
09/22/2021	0.56 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
09/29/2021	0.30 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
10/05/2021	0.55 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
10/15/2021	0.52 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
10/19/2021	0.70 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
11/02/2021	0.73 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
11/16/2021	0.34 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
11/23/2021	0.49 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined
12/01/2021	0.66 mg/L	Total Cl2	3483 Henry Rd >=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
12/07/2021 0.58 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/13/2021 0.53 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined
12/20/2021 0.69 mg/L	Total Cl2	3483 Henry Rd	>=0.05, <=4 User-Defined

# samples:	39	min:	0.30 mg/L
# detects:	39	max:	0.99 mg/L
# non-detects:	0	avg:	0.65 mg/L (based on 39 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/12/2021 0.79 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
01/19/2021 0.74 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
01/25/2021 0.62 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/02/2021 0.72 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/08/2021 0.43 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/18/2021 0.56 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
02/23/2021 0.62 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/08/2021 0.69 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/17/2021 0.60 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/22/2021 0.69 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
03/29/2021 0.68 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
04/06/2021 0.73 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
04/12/2021 0.60 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
05/18/2021 0.61 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
05/26/2021 0.59 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined
06/02/2021 1.01 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4 User-Defined

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
06/22/2021	0.81 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/08/2021	0.80 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/12/2021	0.59 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/20/2021	0.64 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/27/2021	0.65 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/09/2021	0.56 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/17/2021	0.66 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/24/2021	0.46 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/30/2021	0.60 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/13/2021	0.57 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/22/2021	0.56 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/27/2021	0.68 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/07/2021	0.41 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/12/2021	0.63 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/01/2021	0.45 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/08/2021	0.65 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/17/2021	0.55 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/25/2021	0.34 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/06/2021	0.37 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/16/2021	0.43 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/20/2021	0.56 mg/L	Total Cl2	Chemainus Rd South EOL	>=0.05, <=4	User-Defined



# samples:	37	min:	0.34 mg/L
# detects:	37	max:	1.01 mg/L
# non-detects:	0	avg:	0.61 mg/L (based on 37 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.50 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/12/2021	0.37 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/19/2021	0.20 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
01/25/2021	0.38 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/01/2021	0.59 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/08/2021	0.20 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
02/23/2021	0.46 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/01/2021	0.48 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/10/2021	0.25 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/17/2021	0.35 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/22/2021	0.49 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
03/30/2021	0.38 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/06/2021	0.42 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
04/13/2021	0.18 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/18/2021	0.55 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
05/26/2021	0.28 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/15/2021	0.31 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
06/22/2021	0.25 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/06/2021	0.52 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/14/2021	0.42 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/20/2021	0.61 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
07/28/2021	0.62 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/03/2021	0.30 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/17/2021	0.11 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/24/2021	0.21 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
08/30/2021	0.15 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 09/07/2021	0.04 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
09/13/2021	0.08 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
* 10/01/2021	0.04 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/14/2021	0.26 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
10/20/2021	0.65 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/01/2021	0.21 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/17/2021	0.28 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
11/26/2021	0.12 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/29/2021 0.17 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/09/2021 0.16 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/16/2021 0.38 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined
12/23/2021 0.40 mg/L	Total Cl2	Bare Pt Rd Tank Farm	>=0.05, <=4 User-Defined

# samples:	38	min:	0.04 mg/L
# detects:	38	max:	0.65 mg/L
# non-detects:	0	avg:	0.33 mg/L (based on 38 numerical results)
# of Exceedences:	2		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0.82 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/12/2021 0.82 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/19/2021 0.63 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
01/25/2021 0.78 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/01/2021 0.79 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/08/2021 0.74 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/17/2021 0.70 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
02/23/2021 0.70 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/02/2021 0.72 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/10/2021 0.69 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/15/2021 0.73 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/22/2021 0.62 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
03/30/2021 0.62 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/06/2021 0.66 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
04/12/2021 0.62 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/17/2021 0.66 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
05/26/2021 0.71 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/02/2021 1.18 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/14/2021 0.68 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
06/22/2021 0.82 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/06/2021 1.00 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/13/2021 0.66 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/19/2021 0.83 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
07/27/2021 0.76 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/12/2021 0.73 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/16/2021 0.66 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/24/2021 0.68 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
08/31/2021 0.75 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined
09/13/2021 0.76 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
09/20/2021	0.60 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/29/2021	0.46 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/05/2021	0.45 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/13/2021	0.80 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/19/2021	0.73 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/02/2021	0.57 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/16/2021	0.46 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/24/2021	0.49 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/02/2021	0.60 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/09/2021	0.60 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/13/2021	0.65 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/23/2021	0.70 mg/L	Total Cl2	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined

# samples:	41	min:	0.45 mg/L
# detects:	41	max:	1.18 mg/L
# non-detects:	0	avg:	0.70 mg/L (based on 41 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
01/12/2021	0.69 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
01/19/2021	0.54 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
01/26/2021	0.60 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/02/2021	0.65 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/08/2021	0.62 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/17/2021	0.62 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
02/23/2021	0.78 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/02/2021	0.55 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/10/2021	0.56 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/15/2021	0.59 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/23/2021	0.55 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
03/29/2021	0.53 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
04/06/2021	0.52 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
04/13/2021	0.56 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
05/17/2021	0.51 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
05/26/2021	0.52 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
06/02/2021	0.88 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
06/14/2021	0.64 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
06/22/2021	0.64 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
07/08/2021	0.64 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined
07/13/2021	0.56 mg/L	Total Cl2	10139 Island View Close	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
07/19/2021	0.50 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
07/27/2021	0.52 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
08/16/2021	0.52 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
08/24/2021	0.42 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
08/31/2021	0.38 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
09/13/2021	0.55 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
09/20/2021	0.45 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
09/29/2021	0.51 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
10/07/2021	0.43 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
10/13/2021	0.52 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
10/19/2021	0.60 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
11/02/2021	0.51 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
11/16/2021	0.43 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
11/26/2021	0.50 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/02/2021	0.48 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/07/2021	0.43 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/13/2021	0.47 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined
12/21/2021	0.45 mg/L	Total Cl2	10139 Island View Close >=0.05, <=4 User-Defined

# samples:	39	min:	0.38 mg/L
# detects:	39	max:	0.88 mg/L
# non-detects:	0	avg:	0.55 mg/L (based on 39 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/05/2021	0.84 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
01/12/2021	0.78 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
01/19/2021	0.63 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
01/25/2021	0.70 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/02/2021	0.73 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/08/2021	0.92 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/17/2021	0.85 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
02/23/2021	0.68 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/02/2021	0.62 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/10/2021	0.63 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/17/2021	0.64 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/23/2021	0.67 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
03/29/2021	0.77 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
04/06/2021	0.71 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined
04/12/2021	0.65 mg/L	Total Cl2	Old Victoria Rd PRV >=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
05/18/2021	0.72 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/25/2021	0.54 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/02/2021	1.07 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/15/2021	0.69 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/21/2021	0.69 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/06/2021	0.64 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/14/2021	0.56 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/20/2021	0.74 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/26/2021	0.76 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/17/2021	0.60 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/23/2021	0.61 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/31/2021	0.58 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/13/2021	0.65 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/27/2021	0.75 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/07/2021	0.58 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/13/2021	0.77 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/20/2021	0.72 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/25/2021	0.76 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/01/2021	0.59 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/17/2021	0.54 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/22/2021	0.51 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/01/2021	0.57 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/09/2021	0.53 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/15/2021	0.63 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/23/2021	0.68 mg/L	Total Cl2	Old Victoria Rd PRV	>=0.05, <=4	User-Defined

# samples:	40	min:	0.51 mg/L
# detects:	40	max:	1.07 mg/L
# non-detects:	0	avg:	0.68 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/05/2021	0.92 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
01/12/2021	0.77 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
01/19/2021	0.74 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
01/25/2021	0.78 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
02/02/2021	0.85 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
02/08/2021	0.61 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
02/23/2021	0.77 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined
03/08/2021	0.66 mg/L	Total Cl2	9324 Cottonwood	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
03/17/2021	0.70 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
03/22/2021	0.82 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
03/29/2021	0.70 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
04/06/2021	0.60 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
04/12/2021	0.58 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
05/18/2021	0.61 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
05/26/2021	0.90 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
06/02/2021	1.28 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
06/15/2021	0.61 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
06/22/2021	0.87 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
07/08/2021	0.80 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
07/12/2021	0.66 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
07/20/2021	0.73 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
07/27/2021	0.69 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
08/09/2021	0.69 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
08/17/2021	0.96 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
08/24/2021	0.69 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
08/31/2021	0.66 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
09/13/2021	0.63 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
09/22/2021	0.50 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
10/01/2021	0.48 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
10/07/2021	0.83 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
10/12/2021	0.85 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
10/20/2021	0.59 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
11/02/2021	0.54 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
11/08/2021	0.71 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
11/17/2021	0.53 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
11/25/2021	0.55 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
12/01/2021	0.64 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
12/06/2021	0.42 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
12/16/2021	0.81 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined
12/20/2021	0.78 mg/L	Total Cl2	9324 Cottonwood >=0.05, <=4 User-Defined

# samples:	40	min:	0.42 mg/L
# detects:	40	max:	1.28 mg/L
# non-detects:	0	avg:	0.71 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/12/2021	0.83 mg/L	Total Cl2	3220 Dogwood >=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/19/2021	0.60 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
01/25/2021	0.56 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/02/2021	0.82 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/08/2021	0.83 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/17/2021	0.68 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
02/23/2021	0.85 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
03/02/2021	0.62 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
03/10/2021	0.54 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
03/17/2021	0.59 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
03/23/2021	0.63 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
03/29/2021	0.64 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
04/06/2021	0.66 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
04/12/2021	0.59 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
05/18/2021	0.59 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
05/25/2021	0.61 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
06/02/2021	1.10 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
06/15/2021	0.55 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
06/21/2021	0.68 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
07/08/2021	0.65 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
07/13/2021	0.56 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
07/20/2021	0.70 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
07/26/2021	0.71 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
08/17/2021	0.60 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
08/23/2021	0.75 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
08/31/2021	0.47 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
09/10/2021	0.38 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
09/13/2021	0.68 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
09/29/2021	0.45 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
10/07/2021	0.59 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
10/13/2021	0.77 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
10/20/2021	0.67 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
10/25/2021	0.60 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
11/02/2021	0.57 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
11/17/2021	0.51 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
11/22/2021	0.41 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
12/01/2021	0.59 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
12/09/2021	0.51 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
12/15/2021	0.57 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined
12/20/2021	0.72 mg/L	Total Cl2	3220 Dogwood	>=0.05, <=4 User-Defined



# samples:	40	min:	0.38 mg/L
# detects:	40	max:	1.10 mg/L
# non-detects:	0	avg:	0.64 mg/L (based on 40 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0.99 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
01/12/2021	0.76 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
01/19/2021	0.71 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
01/25/2021	0.84 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/01/2021	0.84 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/08/2021	0.81 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/17/2021	0.69 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
02/23/2021	0.70 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/01/2021	0.68 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/10/2021	0.71 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/17/2021	0.66 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/22/2021	0.75 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
03/30/2021	0.64 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
04/06/2021	0.57 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
04/12/2021	0.61 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
05/18/2021	0.71 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
05/26/2021	0.80 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
06/02/2021	1.29 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
06/15/2021	0.72 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
06/22/2021	0.86 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/06/2021	0.81 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/14/2021	0.69 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/20/2021	0.74 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
07/27/2021	0.73 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/03/2021	0.60 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/12/2021	0.85 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/17/2021	0.60 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/24/2021	0.54 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
08/30/2021	0.64 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
09/07/2021	0.76 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
09/13/2021	0.79 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
09/29/2021	0.64 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
10/05/2021	0.52 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined
10/13/2021	0.73 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
10/20/2021	0.73 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/01/2021	0.78 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/17/2021	0.54 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/24/2021	0.49 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/29/2021	0.63 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/09/2021	0.56 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/16/2021	0.66 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/23/2021	0.69 mg/L	Total Cl2	3217 Channel Blvd	>=0.05, <=4	User-Defined

# samples:	42	min:	0.49 mg/L
# detects:	42	max:	1.29 mg/L
# non-detects:	0	avg:	0.72 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/12/2021	0.85 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/19/2021	0.62 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/25/2021	0.69 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/02/2021	0.80 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/08/2021	0.68 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/17/2021	0.66 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/23/2021	0.73 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/03/2021	0.77 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/10/2021	0.66 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/17/2021	0.68 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/22/2021	0.63 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/30/2021	0.62 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/06/2021	0.73 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/12/2021	0.60 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/18/2021	0.69 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/25/2021	0.81 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/15/2021	0.70 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/21/2021	0.72 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/06/2021	0.67 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/12/2021	0.82 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/19/2021	0.79 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/26/2021	0.81 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/06/2021	0.58 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/12/2021	0.80 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/17/2021	0.98 mg/L	Total Cl2	Henry Rd Reducer	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
08/23/2021	0.65 mg/L	Total Cl2	Henry Rd Reducer
08/30/2021	0.78 mg/L	Total Cl2	Henry Rd Reducer
09/08/2021	0.71 mg/L	Total Cl2	Henry Rd Reducer
09/13/2021	0.83 mg/L	Total Cl2	Henry Rd Reducer
09/20/2021	0.75 mg/L	Total Cl2	Henry Rd Reducer
09/27/2021	0.53 mg/L	Total Cl2	Henry Rd Reducer
10/07/2021	0.71 mg/L	Total Cl2	Henry Rd Reducer
10/15/2021	0.90 mg/L	Total Cl2	Henry Rd Reducer
10/20/2021	0.74 mg/L	Total Cl2	Henry Rd Reducer
10/26/2021	0.75 mg/L	Total Cl2	Henry Rd Reducer
11/02/2021	0.61 mg/L	Total Cl2	Henry Rd Reducer
11/17/2021	0.48 mg/L	Total Cl2	Henry Rd Reducer
11/23/2021	0.68 mg/L	Total Cl2	Henry Rd Reducer
12/01/2021	0.59 mg/L	Total Cl2	Henry Rd Reducer
12/07/2021	0.66 mg/L	Total Cl2	Henry Rd Reducer
12/15/2021	0.69 mg/L	Total Cl2	Henry Rd Reducer
12/20/2021	0.95 mg/L	Total Cl2	Henry Rd Reducer

# samples:	42	min:	0.48 mg/L
# detects:	42	max:	0.98 mg/L
# non-detects:	0	avg:	0.72 mg/L (based on 42 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 < means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown
 * Indicates Criteria is exceeded



DISINFECTANTS

Total Chloramines (as combined chlorine)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
05/26/2021 00:00	< 0.0400 mg/L	Total Chloramines (as combined chlorine)	River Rd Reducer	<=3.0	MAC
08/10/2021 11:00	< 0.0400 mg/L	Total Chloramines (as combined chlorine)	River Rd Reducer	<=3.0	MAC
10/25/2021 11:30	0.0500 mg/L	Total Chloramines (as combined chlorine)	River Rd Reducer	<=3.0	MAC

# samples:	3	min:	< 0.0400 mg/L
# detects:	1	max:	0.0500 mg/L
# non-detects:	2	avg:	0.0500 mg/L (based on 1 numerical results)
# of Exceedences:	0		

INORGANIC

Aluminum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.0057 mg/L	Aluminum (total)	River Rd Reducer	<=0.2	Secondary Standard

# samples:	1	min:	0.0057 mg/L
# detects:	1	max:	0.0057 mg/L
# non-detects:	0	avg:	0.0057 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00020 mg/L	Antimony (total)	River Rd Reducer	<=0.006	MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00050 mg/L	Arsenic (total)	River Rd Reducer	<=0.010	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.0078 mg/L	Barium (total)	River Rd Reducer	<=2	MCL
# samples:	1	min:	0.0078 mg/L		
# detects:	1	max:	0.0078 mg/L		
# non-detects:	0	avg:	0.0078 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Beryllium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00010 mg/L	Beryllium (total)	River Rd Reducer	<=0.004	MCL
# samples:	1	min:	< 0.00010 mg/L		
# detects:	0	max:	< 0.00010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00010 mg/L	Bismuth (total)	River Rd Reducer		
# samples:	1	min:	< 0.00010 mg/L		
# detects:	0	max:	< 0.00010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.0500 mg/L	Boron (total)	River Rd Reducer	<=5	MAC
# samples:	1	min:	< 0.0500 mg/L		
# detects:	0	max:	< 0.0500 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.010 mg/L	Bromate	River Rd Reducer	<=0.01	MAC
# samples:	1	min:	< 0.010 mg/L		
# detects:	0	max:	< 0.010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Cadmium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000010 mg/L	Cadmium (total)	River Rd Reducer	<=0.005	MCL



# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	7.66 mg/L	Calcium (total)	River Rd Reducer	

# samples:	1	min:	7.66 mg/L
# detects:	1	max:	7.66 mg/L
# non-detects:	0	avg:	7.66 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	2.92 mg/L	Chloride	River Rd Reducer	<=250 Secondary Standard

# samples:	1	min:	2.92 mg/L
# detects:	1	max:	2.92 mg/L
# non-detects:	0	avg:	2.92 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	Chromium (total)	River Rd Reducer	<=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Cobalt (total)	River Rd Reducer	

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.0183 mg/L	Copper (total)	River Rd Reducer	<=1 Secondary Standard

# samples:	1	min:	0.0183 mg/L
# detects:	1	max:	0.0183 mg/L

non-detects: 0 **avg:** 0.0183 mg/L (based on 1 numerical results)
of Exceedences: 0

Cyanide (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0020 mg/L	Cyanide (total)	River Rd Reducer	<=0.2 MAC for Cyanide (free)

samples: 1 **min:** < 0.0020 mg/L
detects: 0 **max:** < 0.0020 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Fluoride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.10 mg/L	Fluoride	River Rd Reducer	<=4.0 MCL

samples: 1 **min:** < 0.10 mg/L
detects: 0 **max:** < 0.10 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Iron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.015 mg/L	Iron (total)	River Rd Reducer	<=0.3 Secondary Standard

samples: 1 **min:** 0.015 mg/L
detects: 1 **max:** 0.015 mg/L
non-detects: 0 **avg:** 0.015 mg/L (based on 1 numerical results)
of Exceedences: 0

Lead (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.00053 mg/L	Lead (total)	River Rd Reducer	<=0.015 MCL

samples: 1 **min:** 0.00053 mg/L
detects: 1 **max:** 0.00053 mg/L
non-detects: 0 **avg:** 0.00053 mg/L (based on 1 numerical results)
of Exceedences: 0

Lithium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Lithium (total)	River Rd Reducer	

samples: 1 **min:** < 0.00010 mg/L
detects: 0 **max:** < 0.00010 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)

of Exceedences: 0

Magnesium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.909 mg/L	Magnesium (total)	River Rd Reducer	

# samples:	1	min:	0.909 mg/L
# detects:	1	max:	0.909 mg/L
# non-detects:	0	avg:	0.909 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.00118 mg/L	Manganese (total)	River Rd Reducer	<=0.05 Secondary Standard

# samples:	1	min:	0.00118 mg/L
# detects:	1	max:	0.00118 mg/L
# non-detects:	0	avg:	0.00118 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000010 mg/L	Mercury (total)	River Rd Reducer	<=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Molybdenum (total)	River Rd Reducer	

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00040 mg/L	Nickel (total)	River Rd Reducer	<=0.1 MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.049 mg/L	Nitrate (as N)	River Rd Reducer	<=10	MCL

# samples:	1	min:	0.049 mg/L
# detects:	1	max:	0.049 mg/L
# non-detects:	0	avg:	0.049 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	0.22 mg/L	Potassium (total)	River Rd Reducer		

# samples:	1	min:	0.22 mg/L
# detects:	1	max:	0.22 mg/L
# non-detects:	0	avg:	0.22 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00050 mg/L	Selenium (total)	River Rd Reducer	<=0.05	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	3.4 mg/L	Silicon (total, as Si)	River Rd Reducer		

# samples:	1	min:	3.4 mg/L
# detects:	1	max:	3.4 mg/L
# non-detects:	0	avg:	3.4 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000050 mg/L	Silver (total)	River Rd Reducer	<=0.1	Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	2.26 mg/L	Sodium (total)	River Rd Reducer	<=160	MCL



# samples:	1	min:	2.26 mg/L
# detects:	1	max:	2.26 mg/L
# non-detects:	0	avg:	2.26 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.0303 mg/L	Strontium (total)	River Rd Reducer	

# samples:	1	min:	0.0303 mg/L
# detects:	1	max:	0.0303 mg/L
# non-detects:	0	avg:	0.0303 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 3.0 mg/L	Sulfur (total)	River Rd Reducer	

# samples:	1	min:	< 3.0 mg/L
# detects:	0	max:	< 3.0 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	2.4 mg/L	Sulphate	River Rd Reducer	<=250 Secondary Standard

# samples:	1	min:	2.4 mg/L
# detects:	1	max:	2.4 mg/L
# non-detects:	0	avg:	2.4 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 mg/L	Sulphide (total, as S)	River Rd Reducer	

# samples:	1	min:	< 0.020 mg/L
# detects:	0	max:	< 0.020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Thallium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000020 mg/L	Thallium (total)	River Rd Reducer	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00020 mg/L	Tin (total)	River Rd Reducer	

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0050 mg/L	Titanium (total)	River Rd Reducer	

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0010 mg/L	Vanadium (total)	River Rd Reducer	

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.0076 mg/L	Zinc (total)	River Rd Reducer	<=5 Secondary Standard

# samples:	1	min:	0.0076 mg/L
# detects:	1	max:	0.0076 mg/L
# non-detects:	0	avg:	0.0076 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Zirconium (total)	River Rd Reducer	

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

MICROORGANISMS

Iron Bacteria (counts)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 1 CFU/ml	Iron Bacteria (counts)	River Rd Reducer	
# samples:	1	min:	< 1 CFU/ml	
# detects:	0	max:	< 1 CFU/ml	
# non-detects:	1	Geometric Mean:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

ORGANIC

1-Methylnaphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	1-Methylnaphthalene	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	River Rd Reducer	
# samples:	1	min:	< 0.50 ug/L	
# detects:	0	max:	< 0.50 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	2,3,4,6-Tetrachlorop henol	River Rd Reducer	<=0.001 AO (MAC is 0.1 mg/L)
# samples:	1	min:	< 0.00050 mg/L	
# detects:	0	max:	< 0.00050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

2,3,4-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	2,3,4-Trichlorophenol	River Rd Reducer	
# samples:	1	min:	< 0.50 ug/L	

# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	2,3,5-Trichlorophenol River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	2,3,6-Trichlorophenol River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.20 ug/L	2,3-Dichlorophenol River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.20 ug/L	2,4 + 2,5-Dichlorophenol River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	2,4,5-Trichlorophenol River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.10 ug/L	2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T	River Rd Reducer	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.00050 mg/L	2,4,6-Trichlorophenol	River Rd Reducer	<=0.002 AO (MAC is 0.005 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,6-Dichlorophenol(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.20 ug/L	2,6-Dichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chloronaphthalene(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.100 ug/L	2-Chloronaphthalene	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00 < 0.10 ug/L	2-Chlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.02 ug/L	2-methyl-4-chlorophenoxyacetic acid / MCPA	River Rd Reducer	

# samples:	1	min:	< 0.02 ug/L
# detects:	0	max:	< 0.02 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Methylnaphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	2-Methylnaphthalene	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.10 ug/L	3 and 4-Chlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	3,4,5-Trichlorophenol	River Rd Reducer	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.20 ug/L	3,4-Dichlorophenol	River Rd Reducer	
# samples:	1	min:	< 0.20 ug/L	
# detects:	0	max:	< 0.20 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

3,5-Dichlorophenol(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.20 ug/L	3,5-Dichlorophenol	River Rd Reducer	
# samples:	1	min:	< 0.20 ug/L	
# detects:	0	max:	< 0.20 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.50 ug/L	4-Chloro-3-methylphenol (Parachlorometacresol)	River Rd Reducer	
# samples:	1	min:	< 0.50 ug/L	
# detects:	0	max:	< 0.50 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Acenaphthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Acenaphthene	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Acenaphthylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.200 ug/L	Acenaphthylene	River Rd Reducer	
# samples:	1	min:	< 0.200 ug/L	
# detects:	0	max:	< 0.200 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Acridine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Acridine	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.006 ug/L	Aldrin	River Rd Reducer	

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	alpha-BHC	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Anthracene	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Atrazine + N-dealkylated metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000100 mg/L	Atrazine + N-dealkylated metabolites	River Rd Reducer	<=0.005 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L



# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Azinphos-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Azinphos-methyl	River Rd Reducer	<=0.02	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.010 ug/L	Benzo(a)anthracene	River Rd Reducer		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 ug/L	Benzo(b,j)fluoranthene	River Rd Reducer		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(g,h,i)perylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 ug/L	Benzo(g,h,i)perylene	River Rd Reducer		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(k)fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 ug/L	Benzo(k)fluoranthene	River Rd Reducer		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

beta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	beta-BHC	River Rd Reducer	

samples: 1 **min:** < 0.050 ug/L
detects: 0 **max:** < 0.050 ug/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Bromacil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Bromacil	River Rd Reducer	

samples: 1 **min:** < 0.100 ug/L
detects: 0 **max:** < 0.100 ug/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	0.0018 mg/L	Bromodichloromethane (dichlorobromomethane)	River Rd Reducer	<=0.016 MAC

samples: 1 **min:** 0.0018 mg/L
detects: 1 **max:** 0.0018 mg/L
non-detects: 0 **avg:** 0.0018 mg/L (based on 1 numerical results)
of Exceedences: 0

Bromoform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 1.0 ug/L	Bromoform	River Rd Reducer	

samples: 1 **min:** < 1.0 ug/L
detects: 0 **max:** < 1.0 ug/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Bromoxynil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000200 mg/L	Bromoxynil	River Rd Reducer	<=0.005 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Butachlor	River Rd Reducer	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Captan	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloroform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	2.0 ug/L	Chloroform	River Rd Reducer	

# samples:	1	min:	2.0 ug/L
# detects:	1	max:	2.0 ug/L
# non-detects:	0	avg:	2.0 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Chlorothalonil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Chlorothalonil	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorpyrifos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000010 mg/L	Chlorpyrifos	River Rd Reducer	<=0.09 MAC

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chrysene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Chrysene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Cyanazine	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	DDT + metabolites	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

delta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	delta-BHC	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Deltamethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Deltamethrin	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Diazinon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000020 mg/L	Diazinon	River Rd Reducer	<=0.02 MAC
# samples:	1	min:	< 0.000020 mg/L	
# detects:	0	max:	< 0.000020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibenzo(a,h)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Dibenzo(a,h)anthracene	River Rd Reducer	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 1.0 ug/L	Dibromochloromethane (Chlorodibromomethane)	River Rd Reducer	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dicamba(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00010 mg/L	Dicamba	River Rd Reducer	<=0.12 MAC
# samples:	1	min:	< 0.00010 mg/L	
# detects:	0	max:	< 0.00010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dichlorvos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Dichlorvos	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Diclofop-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000100 mg/L	Diclofop-methyl	River Rd Reducer	<=0.009	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.010 ug/L	Dieldrin	River Rd Reducer		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Dimethoate	River Rd Reducer	<=0.02	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Disulfoton(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.100 ug/L	Disulfoton	River Rd Reducer		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Diuron	River Rd Reducer	<=0.15	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Endosulfan (total)	River Rd Reducer	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Endosulfan sulfate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Endosulfan sulfate	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Endrin aldehyde(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Endrin aldehyde	River Rd Reducer	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Endrin ketone(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Endrin ketone	River Rd Reducer	
# samples:	1	min:	< 0.020 ug/L	
# detects:	0	max:	< 0.020 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fenclorphos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Fenclorphos	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.030 ug/L	Fluoranthene	River Rd Reducer	



# samples:	1	min:	< 0.030 ug/L
# detects:	0	max:	< 0.030 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluorene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Fluorene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Indeno(1,2,3-c,d)pyrene	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Linuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Linuron	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000100 mg/L	Malathion	River Rd Reducer	<=0.19 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Methyl parathion	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
-------------------	---	-------------	--------------

# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000100 mg/L	Metolachlor	River Rd Reducer	<=0.05	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Metribuzin	River Rd Reducer	<=0.08	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.200 ug/L	Naphthalene	River Rd Reducer		

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitritotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.20 mg/L	Nitritotriacetic acid / NTA	River Rd Reducer	<=0.4	MAC

# samples:	1	min:	< 0.20 mg/L
# detects:	0	max:	< 0.20 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.0050 mg/L	Paraquat	River Rd Reducer	<=0.007
MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride				

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Parathion	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Pentachloronitrobenzene / PCNB	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachlorophenol / PCP(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.00050 mg/L	Pentachlorophenol / PCP	River Rd Reducer	<=0.001 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Permethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.010 ug/L	Permethrin	River Rd Reducer	

# samples:	1	min:	< 0.010 ug/L
-------------------	---	-------------	--------------



# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phenanthrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Phenanthrene	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phorate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000100 mg/L	Phorate	River Rd Reducer	<=0.002 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometon(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.300 ug/L	Prometon	River Rd Reducer	

# samples:	1	min:	< 0.300 ug/L
# detects:	0	max:	< 0.300 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometryn(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Prometryn	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.020 ug/L	Pyrene	River Rd Reducer	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Quinoline(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Quinoline	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Sulfotep	River Rd Reducer	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tebuthiuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.200 ug/L	Tebuthiuron	River Rd Reducer	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temephos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.500 ug/L	Temephos	River Rd Reducer	

# samples:	1	min:	< 0.500 ug/L
# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Terbufos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000100 mg/L	Terbufos	River Rd Reducer	<=0.001 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.100 ug/L	Triallate	River Rd Reducer	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Trifluralin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000200 mg/L	Trifluralin	River Rd Reducer	<=0.045 MAC
# samples:	1	min:	< 0.000200 mg/L	
# detects:	0	max:	< 0.000200 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

PCBS

Aroclor 1016(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1016	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1221(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1221	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1232(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1232	River Rd Reducer	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Aroclor 1242(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1242	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1248	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1254	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1260	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1262(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1262	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1268(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.050 ug/L	Aroclor 1268	River Rd Reducer	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.150 ug/L	Polychlorinated Biphenyls / PCBs (as arochlor total)	River Rd Reducer

# samples:	1	min:	< 0.150 ug/L
# detects:	0	max:	< 0.150 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

PHYSICAL

Hardness (total, as CaCO3)(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	22.9 mg/L	Hardness (total, as CaCO3)	River Rd Reducer

# samples:	1	min:	22.9 mg/L
# detects:	1	max:	22.9 mg/L
# non-detects:	0	avg:	22.9 mg/L (based on 1 numerical results)
# of Exceedences:	0		

pH(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	6.86	pH	River Rd Reducer >=6.5, <=8.5 Secondary Standard

# samples:	1	min:	6.86
# detects:	1	max:	6.86
# non-detects:	0	avg:	6.86 (based on 1 numerical results)
# of Exceedences:	0		

RADIONUCLIDES

Uranium (total)(Lab Data Transfer)

	Measurement Name	Sampling Point Name	Criteria
08/10/2021 11:00	< 0.000020 mg/L	Uranium (total)	River Rd Reducer <=0.02 MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

SOCS

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
------------------	---------------------	----------

08/10/2021 11:00	< 0.00010 mg/L	2,4-Dichlorophenoxy acetic acid / 2,4-D	River Rd Reducer	<=0.07	MCL
------------------	----------------	---	------------------	--------	-----

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alachlor(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
------------------	---------------------	----------

08/10/2021 11:00	< 0.000100 mg/L	Alachlor	River Rd Reducer	<=0.002	MCL
------------------	-----------------	----------	------------------	---------	-----

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlordane(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
------------------	---------------------	----------

08/10/2021 11:00	< 0.000050 mg/L	Chlordane	River Rd Reducer	<=0.002	MCL
------------------	-----------------	-----------	------------------	---------	-----

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dinoseb(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
------------------	---------------------	----------

08/10/2021 11:00	< 0.00010 mg/L	Dinoseb	River Rd Reducer	<=0.007	MCL
------------------	----------------	---------	------------------	---------	-----

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)

Measurement Name	Sampling Point Name	Criteria
------------------	---------------------	----------

08/10/2021 11:00	< 0.0100 mg/L	Diquat	River Rd Reducer	<=0.02	MCL
------------------	---------------	--------	------------------	--------	-----

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000020 mg/L	Endrin	River Rd Reducer	<=0.002	MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.050 mg/L	Glyphosate	River Rd Reducer	<=0.7	MCL

# samples:	1	min:	< 0.050 mg/L
# detects:	0	max:	< 0.050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor epoxide(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000010 mg/L	Heptachlor epoxide	River Rd Reducer	<=0.0002	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000010 mg/L	Heptachlor	River Rd Reducer	<=0.0004	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000050 mg/L	Lindane	River Rd Reducer	<=0.0002	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methoxychlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000050 mg/L	Methoxychlor	River Rd Reducer	<=0.04	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Picloram(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.00010 mg/L	Picloram	River Rd Reducer	<=0.5	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Simazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
08/10/2021 11:00	< 0.000200 mg/L	Simazine	River Rd Reducer	<=0.004	MCL

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/11/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
02/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
04/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
05/11/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Chemainus Rd South EOL	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
02/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
03/15/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
04/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
05/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
06/14/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
07/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
09/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined
10/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3483 Henry Rd	<=0, OG, P User-Defined

# samples:	9	min:	0 CFU/100ml
# detects:	9	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 9 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/11/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
02/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
04/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
05/11/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	River Rd Reducer	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)



of Exceedences: 0

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
02/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
03/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
04/06/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
05/04/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
05/31/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
07/06/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
08/03/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
09/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
10/05/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined
11/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Ferry Terminal	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
02/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
03/01/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
04/06/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
05/04/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria	
05/31/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
07/06/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
08/03/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
09/07/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
10/05/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined
11/01/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3217 Channel Blvd	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria	
01/25/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
02/23/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
03/23/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
04/27/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
05/25/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
06/21/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
07/26/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
09/27/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined
10/25/2021	0 CFU/100ml	Escherichia coli / E. coli (Count)	3220 Dogwood	<=0, OG, P User-Defined

# samples:	9	min:	0 CFU/100ml
# detects:	9	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 9 numerical results)



of Exceedences: 0

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/11/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
02/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
03/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
04/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
05/11/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
06/07/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
07/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
08/09/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
09/13/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
10/12/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined
11/08/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	9324 Cottonwood	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
02/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
03/15/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
04/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
05/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
06/14/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
07/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
09/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined
10/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	10139 Island View Close	<=0, OG, P User-Defined

# samples:	9	min:	0 CFU/100ml
# detects:	9	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 9 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
02/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
03/15/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
04/20/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
05/17/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
06/14/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
07/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
10/19/2021 0 CFU/100ml	Escherichia coli / E. coli (Count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined

# samples:	8	min:	0 CFU/100ml
# detects:	8	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 8 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/25/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined



Escherichia coli / E. coli (counts)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
02/23/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
03/23/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
04/27/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
05/25/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
06/21/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
07/26/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
09/27/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined
10/26/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Henry Rd Reducer	<=0, OG, P User-Defined

# samples:	9	min:	0 CFU/100ml
# detects:	9	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 9 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
02/02/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
03/01/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
04/06/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
05/04/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
05/31/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
07/06/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
08/03/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
09/07/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined



Escherichia coli / E. coli (counts)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
10/04/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
11/01/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
# samples: 11	min: 0 CFU/100ml		
# detects: 11	max: 0 CFU/100ml		
# non-detects: 0	Geometric Mean: 0 CFU/100ml (based on 11 numerical results)		
# of Exceedences: 0			

Escherichia coli / E. coli (counts)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/25/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
02/23/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
03/23/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
04/27/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
06/21/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
07/26/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
09/27/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
10/26/2021 0 CFU/100ml	Escherichia coli / E. coli (counts)	Old Victoria Rd PRV	<=0, OG, P User-Defined
# samples: 8	min: 0 CFU/100ml		
# detects: 8	max: 0 CFU/100ml		
# non-detects: 0	Geometric Mean: 0 CFU/100ml (based on 8 numerical results)		
# of Exceedences: 0			

Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/19/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
02/17/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
03/15/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined



Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
04/20/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
05/17/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
06/14/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
07/19/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined
10/19/2021 0	Total Coliforms (count)	Mckay Rd PRV Vault	<=0, OG, P User-Defined

# samples:	8	min:	0
# detects:	8	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 8 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/05/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
02/02/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
03/01/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
04/06/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
05/04/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
05/31/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
07/06/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
08/03/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
09/07/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
10/04/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined
11/01/2021 0	Total Coliforms (count)	Bare Pt Rd Tank Farm	<=0, OG, P User-Defined

# samples:	11	min:	0
# detects:	11	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 11 numerical results)



of Exceedences: 0

Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/11/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
02/08/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
03/08/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
04/12/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
05/11/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
06/07/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
07/12/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
08/09/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
09/13/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
10/12/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined
11/08/2021 0	Total Coliforms (count)	Chemainus Rd South EOL	<=0, OG, P User-Defined

# samples: 11	min: 0
# detects: 11	max: 0
# non-detects: 0	Geometric Mean: 0 (based on 11 numerical results)
# of Exceedences: 0	

Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/19/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
02/17/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
03/15/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
04/20/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
05/17/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined



Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
06/14/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
07/19/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
09/20/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined
10/19/2021 0	Total Coliforms (count)	3483 Henry Rd	<=0, OG, P User-Defined

# samples:	9	min:	0
# detects:	9	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 9 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/25/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
02/23/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
03/23/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
04/27/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
05/25/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
06/21/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
07/26/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
09/27/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined
10/26/2021 0	Total Coliforms (count)	Henry Rd Reducer	<=0, OG, P User-Defined

# samples:	9	min:	0
# detects:	9	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 9 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/11/2021 0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P User-Defined



Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
02/08/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
03/08/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
04/12/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
05/11/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
06/07/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
07/12/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
08/09/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
09/13/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
10/12/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined
11/08/2021	0	Total Coliforms (count)	River Rd Reducer	<=0, OG, P	User-Defined

# samples:	11	min:	0
# detects:	11	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 11 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
02/01/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
03/01/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
04/06/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
05/04/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
05/31/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
07/06/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
08/03/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined



Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
09/07/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
10/05/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
11/01/2021	0	Total Coliforms (count)	Ferry Terminal	<=0, OG, P	User-Defined
# samples:	11	min:	0		
# detects:	11	max:	0		
# non-detects:	0	Geometric Mean:	0 (based on 11 numerical results)		
# of Exceedences:	0				

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/05/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
02/01/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
03/01/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
04/06/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
05/04/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
05/31/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
07/06/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
08/03/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
* 09/07/2021	1	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
10/05/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
11/01/2021	0	Total Coliforms (count)	3217 Channel Blvd	<=0, OG, P	User-Defined
# samples:	11	min:	0		
# detects:	11	max:	1		
# non-detects:	0	Geometric Mean:	1 (based on 11 numerical results)		
# of Exceedences:	1				

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/25/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
02/23/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
03/23/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
04/27/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
05/25/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
06/21/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
07/26/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
09/27/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined
10/25/2021	0	Total Coliforms (count)	3220 Dogwood	<=0, OG, P	User-Defined

# samples:	9	min:	0
# detects:	9	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 9 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/11/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
02/08/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
03/08/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
04/12/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
05/11/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
06/07/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
07/12/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
08/09/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
09/13/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined



Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
10/12/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
11/08/2021	0	Total Coliforms (count)	9324 Cottonwood	<=0, OG, P	User-Defined
# samples:	11	min:	0		
# detects:	11	max:	0		
# non-detects:	0	Geometric Mean:	0 (based on 11 numerical results)		
# of Exceedences:	0				

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/25/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
02/23/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
03/23/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
04/27/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
06/21/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
07/26/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
* 09/27/2021	3	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
10/26/2021	0	Total Coliforms (count)	Old Victoria Rd PRV	<=0, OG, P	User-Defined
# samples:	8	min:	0		
# detects:	8	max:	3		
# non-detects:	0	Geometric Mean:	1 (based on 8 numerical results)		
# of Exceedences:	1				

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
01/19/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
02/17/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
03/15/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
04/20/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined

Total Coliforms (count)(Laboratory Report)		Measurement Name	Sampling Point Name	Criteria	
05/17/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
06/14/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
07/19/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
09/20/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined
10/19/2021	0	Total Coliforms (count)	10139 Island View Close	<=0, OG, P	User-Defined

# samples:	9	min:	0
# detects:	9	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 9 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded