

November 5, 2021

File: 5620-55

Environmental Health Officer
Central Vancouver Island Health Region
1665 Grant Avenue
Nanaimo, BC V9S 5K7

Dear Environmental Health Officer

**Re: Chemainus Water System Water Quality Report
Premises Number 1310823
Report for the Period Jan 1/20 to Dec 31/20**

Please find the Municipality of North Cowichan's Water quality report for the Chemainus Water System attached.

Sincerely

Clay Reitsma, M. Eng., P. Eng
Senior Manager, Engineering

clay.reitsma@northcowichan.ca

c: Robert Bell- Manager, Utilities



1 Operator Information

Contact Name Clay Reitsma, M.Eng. P.Eng.
Phone 250-746-3100
Email Clay.Reitsma@NorthCowichan.ca

2 System Description

The Chemainus water system is supplied from the wells along the Chemainus River. The water is chlorinated at the well site prior to distribution. Water is then pumped from the well site into the Chemainus distribution system. Pumped well water in excess of the town's demand is delivered to two concrete reservoirs located on Copper Canyon Road.

3 Boil Advisories

None

4 Future Improvements

None proposed at this time

5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

Sincerely



Clay Reitsma, M.Eng., P.Eng.
Senior Manager, Engineering

cc. Robert Bell - Manager, Utilities

6 Results

Report Name: Water Quality Table

January 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,488	0.8	0.42	0.11
2	2,449	1.04	0.52	0.11
3	2,438	1.02	0.54	0.11
4	2,462	0.94	0.6	0.11
5	2,546	1.05	0.56	0.11
6	2,620	0.95	0	0.11
7	2,642	0.98	0.53	0.12
8	2,613	0.86	0	0.12
9	2,580	0.85	0	0.11
10	2,561	1.08	0.49	0.11
11	2,520	0.88	0.42	0.11
12	2,461	0.96	0.53	0.10
13	3,723	1.11	0.53	0.11
14	3,787	0.92	0.56	0.11
15	2,981	0.98	0.55	0.11
16	3,789	1.01	0	0.11
17	3,356	0.96	0.57	0.11
18	2,558	1.04	0.59	0.11
19	2,550	0.97	0.55	0.11
20	2,571	1.06	0.63	0.11
21	2,661	0.92	0.59	0.11
22	2,648	0.87	0.62	0.11
23	2,626	1.07	0.57	0.11
24	2,582	1.13	0.58	0.11
25	2,464	0.99	0.6	0.11
26	2,559	1.04	0.59	0.11
27	2,724	1.01	0.53	0.11
28	2,693	0.95	0.58	0.11
29	2,640	1.06	0.62	0.11
30	2,647	0.98	0.63	0.11
31	2,652	1.06	0.61	0.11
Average	2,729	0.99	0.49	0.11
Minimum	2,438	0.8	0	0.10
Maximum	3,789	1.13	0.63	0.12
Count	31	31	31	31
Total	84,591			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	2,613	0.98	0.56	0.11

February 2020	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	2,627	1.02	0.6	0.14
2	2,637	1.01	0.6	0.11
3	2,741	0.99	0.56	0.11
4	2,685	0.89	0.55	0.11
5	2,548	0.85	0.47	0.11
6	2,573	0.92	0.55	0.11
7	2,624	0.98	0.52	0.11
8	2,658	0.98	0.61	0.11
9	2,641	0.99	0.57	0.11
10	2,679	1.14	0.58	0.11
11	2,693	1.08	0.58	0.11
12	2,542	0.98	0.57	0.11
13	2,505	1.2	0.52	0.11
14	2,640	1.09	0	0.11
15	2,700	0.97	0.57	0.11
16	2,648	1.01	0.55	0.11
17	2,531	0.96	0.53	0.11
18	2,569	1.15	0.55	0.11
19	2,645	0.87	0.54	0.11
20	2,676	0.95	0.5	0.11
21	2,671	1	0.48	0.11
22	2,564	0.83	0.5	0.11
23	2,558	0.9	0.49	0.11
24	2,652	1.07	0.5	0.11
25	2,664	0.85	0.49	0.11
26	2,501	0.88	0.46	0.11
27	2,519	0.93	0.45	0.11
28	2,718	0.85	0.46	0.11
29	2,754	0.93	0.48	0.11

Average	2,626	0.97	0.51	0.11
Minimum	2,501	0.83	0	0.11
Maximum	2,754	1.2	0.61	0.14
Count	29	29	29	29
Total	76,163			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	2,641	0.98	0.53	0.11

March 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,695	0.9	0.45	0.11
2	2,636	0.83	0.44	0.11
3	2,668	0.86	0.47	0.11
4	2,726	0.85	0.48	0.11
5	2,721	0.86	0.46	0.11
6	2,756	5	-1.25	0.11
7	2,680	0.81	0.35	0.11
8	2,562	0.75	0.35	0.11
9	2,598	1.12	0.37	0.12
10	2,617	1.06	0.51	0.11
11	2,620	1.08	0.5	0.11
12	2,687	1.17	0.52	0.11
13	2,747	1.13	0.51	0.11
14	2,702	1.07	0.54	0.11
15	2,650	1.08	0.57	0.11
16	2,598	1.19	0.56	0.11
17	2,631	1.12	0.56	0.11
18	2,884	1.16	0.57	0.11
19	2,926	1.16	0.52	0.11
20	2,842	1.26	0.56	0.11
21	2,797	1.05	0.56	0.11
22	2,653	1.15	0.5	0.11
23	2,617	1.34	0.52	0.11
24	2,651	1.23	0.35	0.11
25	2,757	1.27	0.57	0.11
26	2,817	1.2	0.54	0.11
27	2,692	1.29	0.51	0.11
28	2,575	1.05	0.52	0.11
29	2,481	1.15	0.51	0.11
30	2,451	1.16	0.45	0.11
31	2,572	1.13	0.51	0.11

Average	2,678	1.21	0.44	0.11
Minimum	2,451	0.75	-1.25	0.11
Maximum	2,926	5	0.57	0.12
Count	31	31	31	31
Total	83,009			
95 Percentile				0.11
Exceedences	0	0	0	0
Median	2,668	1.13	0.51	0.11

April 2020	Flowmeter (Wells PS) Flow (Volumetric Rate) (m³/d)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS) Turbidity (Daily Avg) (NTU)
		Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	
1	2,757	1.25	0.51	0.11
2	2,740	1.26	0.55	0.11
3	2,628	1.17	0.53	0.11
4	2,583	1.32	0.57	0.11
5	2,580	1.22	0.55	0.11
6	2,613	1.34	0	0.11
7	2,525	1.26	0.51	0.11
8	2,644	1.22	0.56	0.11
9	2,920	1.22	0.6	0.11
10	2,894	1.11	0.52	0.11
11	2,793	1.19	0.54	0.11
12	2,689	1.16	0.46	0.11
13	2,680	1.23	0.49	0.11
14	2,999	1.17	0.53	0.11
15	3,248	1.32	0.53	0.12
16	3,188	1.14	0.55	0.11
17	3,121	1.17	0.57	0.11
18	3,184	1.07	0.6	0.11
19	3,199	1.18	0.53	0.11
20	3,345	1.13	0.5	0.11
21	3,279	1.16	0.59	0.11
22	3,156	1.31	0.56	0.11
23	3,073	1.11	0.52	0.11
24	3,031	1.35	0.49	0.11
25	2,746	1.08	0.5	0.11
26	2,692	0.89	0.49	0.11
27	3,044	1.09	0.48	0.11
28	3,107	1.04	0.48	0.11
29	2,989	0.99	0.5	0.11
30	3,048	1.02	0.56	0.11

Average	2,917	1.17	0.51	0.11
Minimum	2,525	0.89	0	0.11
Maximum	3,345	1.35	0.6	0.12
Count	30	30	30	30
Total	87,495			
95 Percentile				0.11
Exceedences	0	0	0	0
Median	2,955	1.17	0.53	0.11

May 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,169	1.01	0.55	0.11
2	2,963	1.09	0.53	0.11
3	2,836	1.17	0.42	0.11
4	3,044	1.06	0.55	0.11
5	3,186	1.19	0.55	0.11
6	3,273	1.19	0.52	0.11
7	3,487	1.21	0.6	0.11
8	3,648	1.24	0.57	0.11
9	3,588	1.28	0.54	0.11
10	3,730	1.23	0.49	0.11
11	3,670	1.27	0.39	0.11
12	3,291	1.41	0.55	0.11
13	3,091	1.39	0.55	0.11
14	3,484	1.25	0.59	0.11
15	3,698	1.58	0.65	0.11
16	3,792	1.43	0.66	0.11
17	4,082	1.42	0.64	0.11
18	4,101	1.6	0.7	0.11
19	3,769	1.69	0.67	0.11
20	3,574	1.59	0.65	0.11
21	3,458	1.53	0.67	0.11
22	3,279	1.42	0.69	0.11
23	3,253	1.56	0.69	0.11
24	3,281	1.56	0.65	0.11
25	3,241	1.49	0.6	0.11
26	3,336	1.41	0.61	0.11
27	3,472	1.41	0.59	0.11
28	3,727	1.43	0.58	0.11
29	3,658	1.2	0.52	0.11
30	3,469	1.27	0.55	0.11
31	3,709	1.42	0.58	0.11

Average	3,463	1.35	0.58	0.11
Minimum	2,836	1.01	0.39	0.11
Maximum	4,101	1.69	0.7	0.11
Count	31	31	31	31
Total	107,359			
95 Percentile				0.11
Exceedences	0	0	0	0
Median	3,472	1.41	0.58	0.11

June 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	4,084	1.32	0	0.11
2	3,694	1.62	0.61	0.11
3	3,210	1.5	0.64	0.11
4	3,320	1.75	0.54	0.11
5	3,492	1.54	0.53	0.11
6	3,375	1.33	0.46	0.11
7	3,279	1.18	0.46	0.11
8	3,384	1.3	0	0.11
9	3,208	1.23	0.52	0.11
10	3,106	1.09	0.58	0.11
11	3,164	1.21	0.55	0.11
12	3,191	1.15	0.52	0.11
13	2,899	1.13	0.58	0.11
14	2,926	1.11	0.51	0.11
15	3,274	1.13	0.52	0.11
16	3,321	1.06	0.46	0.11
17	3,361	1.08	0.45	0.11
18	3,431	1.07	0.47	0.11
19	3,355	1.16	0.46	0.11
20	3,404	1.07	0.5	0.10
21	3,357	1.28	0.43	0.11
22	3,382	1.27	0.46	0.11
23	3,435	1.14	0.45	0.11
24	3,328	1.09	0.47	0.11
25	3,861	1.07	0.54	0.11
26	3,875	1.15	0.5	0.11
27	3,262	1.16	0.54	0.11
28	3,625	1.02	0.48	0.11
29	4,082	1.09	0.46	0.10
30	3,969	1.29	0.5	0.11

Average	3,422	1.22	0.47	0.11
Minimum	2,899	1.02	0	0.10
Maximum	4,084	1.75	0.64	0.11
Count	30	30	30	30
Total	102,654			
95 Percentile				0.11
Exceedences	0	0	0	0
Median	3,359	1.16	0.50	0.11

July 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,595	1.09	0.46	0.11
2	3,678	1.04	0.47	0.11
3	3,673	1.11	0.51	0.11
4	3,254	1.13	0.48	0.11
5	3,267	1.19	0.48	0.11
6	3,928	1.03	0.45	0.11
7	3,884	1.21	0.48	0.11
8	3,629	1.26	0.39	0.11
9	3,800	1.17	0.44	0.11
10	3,731	1.13	0.44	0.11
11	3,421	1.15	0.44	0.11
12	3,622	1.16	0.51	0.11
13	4,066	1.13	0.5	0.11
14	4,297	1.18	0.54	0.11
15	4,316	1.19	0.47	0.11
16	4,169	1.31	0.47	0.11
17	4,082	1.37	0.57	0.11
18	4,366	1.29	0.59	0.11
19	4,704	1.23	0.54	0.11
20	4,768	1.41	0.41	0.11
21	4,799	1.45	0.46	0.11
22	4,789	1.13	0.36	0.11
23	4,724	1.3	0.52	0.11
24	4,588	1.47	0.5	0.11
25	4,496	1.34	0.54	0.11
26	4,556	1.43	0.48	0.11
27	5,037	1.12	0.52	0.11
28	4,868	1.37	0.34	0.11
29	4,864	1	0.41	0.11
30	5,190	1.08	0.6	0.11
31	4,852	1.4	0.42	0.11

Average	4,226	1.22	0.48	0.11
Minimum	3,254	1	0.34	0.11
Maximum	5,190	1.47	0.6	0.11
Count	31	31	31	31
Total	131,013			
95 Percentile				0.11
Exceedences	0	0	0	0
Median	4,297	1.19	0.48	0.11

August 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	4,556	1.39	0.58	0.11
2	4,534	1.23	0.57	0.11
3	4,593	1.32	0.41	0.11
4	4,873	1.36	0.52	0.11
5	4,791	1.36	0.45	0.11
6	4,186	1.31	0.35	0.11
7	3,949	1.6	0.55	0.11
8	3,620	1.36	0.46	0.11
9	3,480	1.28	0.36	0.11
10	4,101	1.17	0.37	0.11
11	4,465	1.84	0.52	0.11
12	4,416	1.32	0	0.11
13	4,459	1.61	0.42	0.11
14	4,531	1.55	0.34	0.11
15	4,562	1.38	0.4	0.11
16	4,613	1.49	0.47	0.11
17	4,655	1.51	0.55	0.11
18	4,711	1.44	0.58	0.11
19	4,663	1.46	0.51	0.12
20	4,017	1.53	-1.25	0.11
21	3,688	1.29	0.53	0.11
22	3,780	1.46	0.53	0.11
23	3,705	1.51	0.45	0.11
24	3,749	1.51	0.52	0.11
25	4,004	1.47	0.47	0.11
26	4,433	1.36	0.54	0.12
27	4,639	1.86	0.61	0.11
28	4,367	1.76	0.58	0.11
29	4,046	1.56	0.54	0.11
30	4,029	1.35	0.42	0.11
31	3,838	1.54	0.54	0.11

Average	4,260	1.46	0.42	0.11
Minimum	3,480	1.17	-1.25	0.11
Maximum	4,873	1.86	0.61	0.12
Count	31	31	31	31
Total	132,053			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	4,416	1.46	0.51	0.11

September 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,635	1.68	0.53	0.11
2	4,070	1.37	0.54	0.12
3	4,258	1.27	0.59	0.11
4	4,162	1.41	0.61	0.11
5	4,136	1.39	0.58	0.11
6	3,898	1.29	0.59	0.11
7	4,303	1.29	0.62	0.11
8	4,697	1.49	0.59	0.11
9	4,602	1.39	0.65	0.12
10	4,567	1.38	0.64	0.11
11	4,547	1.42	0.59	0.11
12	4,538	1.45	0.51	0.11
13	4,538	1.5	0.5	0.11
14	0	1.7	0.38	0.11
15	3,783	1.72	0.4	0.11
16	3,866	1.07	0.38	0.11
17	4,023	0.95	0	0.12
18	3,911	1.11	0.29	0.11
19	3,509	0.73	0.32	0.12
20	3,406	0.76	0.37	0.11
21	3,336	0.91	0.33	0.12
22	3,550	1.09	0.52	0.11
23	3,752	1.14	0.5	0.12
24	3,576	1.69	0	0.12
25	3,354	1.61	0.52	0.12
26	3,219	1.57	0.54	0.11
27	3,282	1.49	0.49	0.12
28	3,279	1.57	0.48	0.11
29	3,415	1.45	0.6	0.11
30	3,547	1.39	0.45	0.12

Average	3,759	1.34	0.47	0.11
Minimum	0	0.73	0	0.11
Maximum	4,697	1.72	0.65	0.12
Count	30	30	30	30
Total	112,759			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	3,825	1.39	0.52	0.11

October 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,485	1.67	0.48	0.11
2	3,471	1.34	0.47	0.12
3	3,395	1.31	0.47	0.11
4	3,253	1.22	0.47	0.12
5	3,279	1.24	0.47	0.12
6	3,343	1.16	0.44	0.11
7	3,333	1.19	0.53	0.12
8	3,322	1.26	0.48	0.12
9	3,244	1.53	0.47	0.12
10	3,108	1.36	0.47	0.12
11	3,053	1.56	0.58	0.12
12	2,983	1.13	0.53	0.12
13	2,841	1.34	0	0.12
14	2,776	1.19	0.44	0.14
15	2,777	1.49	0.43	0.12
16	3,416	1.71	0.61	0.12
17	3,956	1.36	0.62	0.12
18	3,505	1.33	0.55	0.12
19	3,497	1.37	0.56	0.12
20	3,803	1.43	0.61	0.12
21	3,781	1.53	0.7	0.12
22	3,759	1.29	0.67	0.12
23	3,737	1.88	0.63	0.12
24	3,715	1.42	0.62	0.12
25	3,693	1.49	0.65	0.12
26	3,671	1.64	0.6	0.12
27	3,649	1.39	0.67	0.12
28	3,627	1.43	0.64	0.12
29	3,605	1.4	0	0.12
30	3,568	1.57	0.61	0.12
31	3,151	1.32	0.58	0.12

Average	3,413	1.40	0.52	0.12
Minimum	2,776	1.13	0	0.11
Maximum	3,956	1.88	0.7	0.14
Count	31	31	31	31
Total	105,796			
95 Percentile				0.13
Exceedences	0	0	0	0
Median	3,471	1.37	0.55	0.12

November 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	2,993	1.29	0.64	0.12
2	3,320	1.4	0	0.12
3	3,205	1.23	0.57	0.12
4	2,947	1.18	0.53	0.12
5	2,939	1.23	0.56	0.12
6	3,382	1.52	0.63	0.12
7	3,355	1.31	0.62	0.12
8	2,878	1.28	0.65	0.12
9	3,138	1.29	0.61	0.12
10	3,252	1.35	0.64	0.12
11	3,080	1.24	0.65	0.12
12	3,373	1.41	0.6	0.12
13	3,362	1.48	0.54	0.12
14	3,015	1.33	0.55	0.12
15	3,019	1.19	0.51	0.12
16	3,022	1.45	0.47	0.12
17	3,026	1.08	0.52	0.12
18	3,086	1.34	0.57	0.12
19	3,121	1.21	0.5	0.12
20	3,124	1.2	0.52	0.12
21	3,083	1.72	0.55	0.12
22	3,021	1.25	0.52	0.12
23	3,078	1.28	0.57	0.12
24	3,106	1.18	0.55	0.12
25	3,056	1.56	0.52	0.12
26	3,075	1.51	0.66	0.12
27	3,163	1.43	0	0.12
28	3,156	1.21	0.61	0.12
29	3,128	1.32	0.52	0.12
30	3,140	1.57	0.51	0.12

Average	3,121	1.33	0.53	0.12
Minimum	2,878	1.08	0	0.12
Maximum	3,382	1.72	0.66	0.12
Count	30	30	30	30
Total	93,643			
95 Percentile				0.12
Exceedences	0	0	0	0
Median	3,096	1.30	0.55	0.12

December 2020	Flowmeter (Wells PS)	Cl2 Analyzer (Well PS)		Turb Meter (Well PS)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)
1	3,172	1.17	0.53	0.12
2	3,226	1.22	0.5	0.12
3	3,235	1.29	0.49	0.12
4	3,189	1.28	0.54	0.12
5	3,137	1.28	0.52	0.12
6	3,139	1.19	0.58	0.12
7	3,251	1.32	0.6	0.12
8	3,316	1.25	0.54	0.11
9	3,229	1.57	0.63	0.12
10	3,121	1.32	0.59	0.12
11	3,163	1.25	0.57	0.12
12	3,333	1.29	0.56	0.12
13	3,361	1.2	0.59	0.12
14	3,332	1.59	0.56	0.12
15	3,346	1.33	0.6	0.12
16	3,359	1.39	0.56	0.12
17	3,348	1.24	0.47	0.12
18	3,295	1.37	0.42	0.12
19	3,274	1.48	0.57	0.12
20	3,246	1.25	0.66	0.12
21	3,527	1.88	0.67	0.12
22	3,604	1.89	0.78	0.12
23	3,263	1.68	0.6	0.12
24	3,097	1.49	0.59	0.12
25	3,126	1.65	0.56	0.12
26	3,246	1.36	0.55	0.12
27	3,260	1.3	0.43	0.12
28	3,259	1.25	0.49	0.17
29	3,216	1.05	0.47	0.15
30	2,912	1.17	0.56	0.12
31	2,917	1.35	0.54	0.13

Average	3,242	1.37	0.56	0.12
Minimum	2,912	1.05	0.42	0.11
Maximum	3,604	1.89	0.78	0.17
Count	31	31	31	31
Total	100,499			
95 Percentile				0.16
Exceedences	0	0	0	0
Median	3,246	1.30	0.56	0.12

* indicates Geometric Mean
** indicates Intraday Average

DISINFECTANTS

Chlorine (free)		Sampling Point Name	Criteria	
01/02/2020	0.76 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/02/2020	0.85 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/02/2020	0.23 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/02/2020	0.60 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/06/2020	0.33 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
01/06/2020	0.52 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/06/2020	0.62 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/07/2020	0.26 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/07/2020	0.68 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/07/2020	0.71 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/07/2020	0.58 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/07/2020	0.70 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/07/2020	0.71 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/07/2020	0.71 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/07/2020	0.28 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/07/2020	0.55 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/13/2020	0.49 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/13/2020	0.50 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/13/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/13/2020	0.30 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/13/2020	0.39 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/13/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/13/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
01/13/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/13/2020	0.51 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/13/2020	0.60 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/13/2020	0.13 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/17/2020	0.65 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/20/2020	0.60 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/20/2020	0.45 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
01/20/2020	0.50 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/20/2020	0.53 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/20/2020	0.55 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/20/2020	0.15 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/20/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/20/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined



Chlorine (free)		Sampling Point Name	Criteria	
01/21/2020	0.66 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/21/2020	0.29 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/22/2020	0.63 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/22/2020	0.51 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/27/2020	0.60 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/27/2020	0.69 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/27/2020	0.76 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/27/2020	0.47 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/29/2020	0.27 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/30/2020	0.67 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/30/2020	0.48 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/30/2020	0.64 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/30/2020	0.54 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/30/2020	0.37 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/31/2020	0.68 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/31/2020	0.53 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/03/2020	0.14 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/03/2020	0.62 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/03/2020	0.54 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/04/2020	0.66 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/04/2020	0.63 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/04/2020	0.67 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/04/2020	0.52 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/04/2020	0.79 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/04/2020	0.38 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/04/2020	0.72 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/04/2020	0.75 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/04/2020	0.52 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/10/2020	0.47 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/10/2020	0.87 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/10/2020	0.42 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/11/2020	0.61 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/11/2020	0.61 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/11/2020	0.51 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/11/2020	0.58 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/11/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
02/11/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/11/2020	0.50 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/11/2020	0.60 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/12/2020	0.41 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/18/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/18/2020	0.55 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/18/2020	0.44 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/18/2020	0.61 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/18/2020	0.52 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/19/2020	0.11 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/19/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/19/2020	0.29 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/20/2020	0.45 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/20/2020	0.61 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/20/2020	0.65 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/20/2020	0.71 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/24/2020	0.60 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/24/2020	0.29 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/24/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/24/2020	0.43 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/24/2020	0.63 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/24/2020	0.60 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/25/2020	0.34 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/25/2020	0.44 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/25/2020	0.24 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/25/2020	0.56 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/25/2020	0.34 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/25/2020	0.48 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/02/2020	0.35 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/02/2020	0.46 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/02/2020	0.60 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/03/2020	0.290 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/03/2020	0.57 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/03/2020	0.58 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/03/2020	0.63 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/03/2020	0.29 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/03/2020	0.60 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined



Chlorine (free)		Sampling Point Name	Criteria	
03/03/2020	0.76 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/03/2020	0.62 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/04/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/09/2020	0.65 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/09/2020	0.91 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/09/2020	0.59 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/09/2020	0.42 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/09/2020	0.55 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/09/2020	0.85 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/09/2020	0.43 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/09/2020	0.30 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/09/2020	0.73 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/09/2020	0.43 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/09/2020	0.45 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/09/2020	0.49 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/16/2020	0.24 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/16/2020	0.52 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/16/2020	0.28 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/18/2020	0.66 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/18/2020	0.62 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/18/2020	0.55 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/18/2020	0.32 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/18/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/18/2020	0.48 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/18/2020	0.62 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/20/2020	0.15 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/21/2020	0.53 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/23/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/23/2020	0.22 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/23/2020	0.65 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/23/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/25/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/25/2020	0.12 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/25/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/25/2020	0.55 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/25/2020	0.64 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/25/2020	0.55 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
03/31/2020	0.69 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/31/2020	0.86 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/31/2020	0.49 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/31/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/31/2020	0.69 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/31/2020	0.58 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/31/2020	0.58 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/31/2020	0.38 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/31/2020	0.62 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/31/2020	0.91 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/31/2020	0.54 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/31/2020	0.88 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/06/2020	0.56 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/06/2020	0.56 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/06/2020	0.66 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/06/2020	0.56 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/06/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
04/06/2020	0.58 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/06/2020	0.62 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/07/2020	0.25 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/07/2020	0.73 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/07/2020	0.47 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/07/2020	0.56 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/07/2020	0.56 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/15/2020	0.69 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/15/2020	0.64 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/15/2020	0.43 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/15/2020	0.56 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/15/2020	0.54 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/15/2020	0.60 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/15/2020	0.61 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/15/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/16/2020	0.13 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/16/2020	0.63 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/16/2020	0.55 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/20/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/20/2020	0.65 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
04/20/2020	0.53 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/20/2020	0.67 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/20/2020	0.63 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/20/2020 10:25	0.49 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/22/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/22/2020	0.39 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/22/2020	0.66 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/22/2020	0.28 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/22/2020	0.56 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
04/22/2020	0.69 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/22/2020	0.58 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/28/2020	0.70 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/28/2020	0.78 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/28/2020	0.43 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/28/2020	0.42 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/29/2020	0.77 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/29/2020	0.54 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/29/2020	0.69 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/29/2020	0.75 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/29/2020	0.18 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/29/2020	0.73 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/29/2020	0.48 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
04/29/2020	0.67 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/04/2020	0.66 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/04/2020	0.94 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/04/2020	0.48 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/04/2020	0.40 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/05/2020	0.71 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/05/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/05/2020	0.75 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/05/2020	0.70 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/05/2020	0.58 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/05/2020	0.63 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/05/2020	0.44 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
05/05/2020	0.35 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/11/2020	0.62 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
05/11/2020	0.63 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/11/2020	0.66 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/11/2020	0.60 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/12/2020	0.55 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/12/2020	0.11 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/12/2020	0.45 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/12/2020	0.36 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/12/2020	0.56 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/12/2020	0.48 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
05/12/2020	0.59 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/12/2020	0.48 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/19/2020	0.67 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/19/2020	0.66 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/19/2020	0.48 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
05/20/2020	0.60 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/20/2020	0.53 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/20/2020	0.65 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/20/2020	0.11 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/20/2020	0.56 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/20/2020	0.44 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/20/2020	0.82 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/20/2020	0.64 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/20/2020	0.71 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/25/2020	0.42 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/25/2020	0.49 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/25/2020	0.55 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/26/2020	0.49 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/26/2020	0.63 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/26/2020	0.32 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/26/2020	0.58 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/26/2020	0.57 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/26/2020	0.29 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/26/2020	0.63 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/26/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/01/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
06/01/2020	0.55 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
06/01/2020	0.25 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
06/01/2020	0.59 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
06/02/2020	0.24 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/02/2020	0.30 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/03/2020	0.46 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
06/03/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/04/2020	0.55 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/04/2020	0.62 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/04/2020	0.50 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/05/2020	0.58 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/11/2020	0.41 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/12/2020	0.51 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/12/2020	0.50 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/12/2020	0.49 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/12/2020	0.15 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/12/2020	0.60 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/12/2020	0.70 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/15/2020	0.33 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
06/15/2020	0.54 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/15/2020	0.56 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
06/15/2020	0.64 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/15/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
06/15/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/15/2020	0.57 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/15/2020	0.44 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/15/2020	0.51 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
06/15/2020	0.54 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/17/2020	0.25 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/17/2020	0.35 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/22/2020	0.43 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/22/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/22/2020	0.54 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
06/22/2020	0.54 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
06/22/2020	0.57 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/22/2020	0.61 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
06/23/2020	0.45 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/23/2020	0.43 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
06/23/2020	0.56 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/24/2020	0.48 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/24/2020	0.46 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/24/2020	0.37 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/03/2020	0.53 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/03/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/03/2020	0.43 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/03/2020	0.44 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/03/2020	0.45 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/03/2020	0.38 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/03/2020	0.38 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/03/2020	0.30 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/06/2020	0.54 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/06/2020	0.46 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/06/2020	0.57 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/06/2020	0.35 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/06/2020	0.51 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/06/2020	0.51 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/06/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/06/2020	0.44 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/07/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/07/2020	0.39 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/07/2020	0.23 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/07/2020	0.44 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/13/2020	0.55 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/13/2020	0.47 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/13/2020	0.27 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/14/2020	0.55 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/14/2020	0.45 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/14/2020	0.40 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/14/2020	0.66 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/14/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/14/2020	0.37 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/14/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/14/2020	0.21 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/14/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
* 07/20/2020	0.00 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined



Chlorine (free)		Sampling Point Name	Criteria	
07/21/2020	0.54 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/21/2020	0.43 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/21/2020	0.34 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/22/2020	0.40 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/23/2020	0.22 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/23/2020	0.38 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/23/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/23/2020	0.69 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/23/2020	0.36 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/23/2020	0.51 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/23/2020	0.43 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/27/2020	0.61 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/27/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/27/2020	0.52 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/28/2020	0.57 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/28/2020	0.56 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/28/2020	0.44 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/28/2020	0.63 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/28/2020	0.42 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/28/2020	0.54 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/28/2020	0.38 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/28/2020	0.64 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/29/2020	0.14 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/01/2020	0.42 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/01/2020	0.38 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/01/2020	0.73 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/01/2020	0.65 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/01/2020	0.31 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/01/2020	0.54 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/01/2020	0.70 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/01/2020	0.67 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/01/2020	0.67 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/02/2020	0.39 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/02/2020	0.11 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/02/2020	0.56 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/04/2020	0.43 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/04/2020	0.49 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
08/04/2020	0.20 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/04/2020 12:45	0.36 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/06/2020	0.51 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/06/2020	0.33 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/06/2020	0.53 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/06/2020	0.58 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/06/2020	0.47 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/06/2020	0.46 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/10/2020	0.33 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/10/2020	0.48 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/10/2020	0.53 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/11/2020	0.48 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/11/2020	0.22 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/11/2020	0.47 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/11/2020	0.13 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/11/2020	0.23 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/11/2020	0.52 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/11/2020	0.33 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/11/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/12/2020	0.32 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/12/2020	0.08 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/17/2020	0.50 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/17/2020	0.34 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/17/2020	0.53 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/18/2020	0.74 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/18/2020	0.64 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/19/2020	0.29 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/19/2020	0.51 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/19/2020	0.47 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/19/2020	0.62 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/20/2020	0.24 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/20/2020	0.68 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/21/2020	0.36 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/24/2020	0.44 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/24/2020	0.27 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/24/2020	0.48 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/25/2020	0.63 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/25/2020	0.57 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined



Chlorine (free)		Sampling Point Name	Criteria	
08/25/2020	0.52 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/26/2020	0.53 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/26/2020	0.31 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/27/2020	0.26 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/27/2020	0.54 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/27/2020	0.1 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/28/2020	0.54 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/28/2020	0.36 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/08/2020	0.61 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/08/2020	0.20 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/08/2020	0.31 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/14/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/14/2020	0.44 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/14/2020	0.33 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/14/2020	0.31 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/14/2020	0.51 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/14/2020	0.31 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
09/14/2020	0.43 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
09/14/2020	0.30 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
09/14/2020	0.44 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/15/2020	0.48 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
09/15/2020	0.24 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/15/2020	0.41 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/22/2020	0.37 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/22/2020	0.32 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
09/22/2020	0.25 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
09/23/2020	0.27 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/23/2020	0.44 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/23/2020	0.50 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/23/2020	0.53 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/23/2020	0.49 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
09/23/2020	0.38 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/23/2020	0.27 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/23/2020	0.30 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
09/23/2020	0.10 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/28/2020	0.52 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/28/2020	0.43 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
09/28/2020	0.45 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/28/2020	0.42 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/29/2020	0.50 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/29/2020	0.43 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/29/2020	0.21 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/29/2020	0.24 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
09/29/2020	0.50 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
09/29/2020	0.50 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/29/2020	0.55 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
09/29/2020	0.25 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
10/05/2020	0.11 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/05/2020	0.44 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/05/2020	0.38 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/06/2020	0.47 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/06/2020	0.46 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/06/2020	0.42 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/06/2020	0.50 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/06/2020	0.31 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/13/2020	0.45 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
10/13/2020	0.31 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/16/2020	0.34 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/16/2020	0.44 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/16/2020	0.54 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/16/2020	0.39 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/16/2020	0.40 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
10/16/2020	0.42 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/16/2020	0.44 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/16/2020	0.53 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/16/2020	0.29 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
10/16/2020	0.52 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/19/2020	0.60 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/19/2020	0.60 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/19/2020	0.25 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
10/19/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/19/2020	0.58 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/19/2020	0.38 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/19/2020	0.54 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/20/2020	0.28 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
10/20/2020	0.09 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/20/2020	0.30 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/20/2020	0.59 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
10/20/2020	0.39 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
10/26/2020	0.56 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/26/2020	0.66 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/26/2020	0.56 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/26/2020	0.38 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
10/26/2020	0.73 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/26/2020	0.86 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/26/2020	0.56 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/26/2020	0.64 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/26/2020	0.66 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
10/27/2020	0.53 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/27/2020	0.32 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/27/2020	0.49 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
10/27/2020 09:25	0.54 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/02/2020	0.51 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/02/2020	0.66 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/02/2020	0.62 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/02/2020	0.27 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/02/2020	0.58 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/03/2020	0.57 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/03/2020	0.76 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/03/2020	0.52 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/03/2020	0.60 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/03/2020	0.68 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/03/2020	0.55 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/03/2020	0.42 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
11/09/2020	0.43 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/09/2020	0.67 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/09/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/09/2020	0.65 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/09/2020	0.60 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/09/2020	0.82 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/09/2020	0.65 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
11/09/2020	0.43 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/13/2020	0.56 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
* 11/13/2020	0.03 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/13/2020	0.48 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/16/2020	0.70 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/16/2020	0.55 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/16/2020	0.45 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/17/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/17/2020	0.28 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
11/17/2020	0.51 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/17/2020	0.50 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/17/2020	0.98 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/17/2020	0.55 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/17/2020	0.78 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/17/2020	0.34 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/17/2020	0.60 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/24/2020	0.71 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/25/2020	0.62 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/25/2020	0.55 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/25/2020	0.41 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/25/2020	0.48 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/25/2020	0.61 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/25/2020	0.77 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/25/2020	0.72 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/26/2020	0.66 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/26/2020	0.57 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/26/2020	0.51 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
11/26/2020	0.45 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/30/2020	0.50 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/30/2020	0.32 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/01/2020	0.50 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/01/2020	0.45 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/01/2020	0.54 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/01/2020	0.53 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/01/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/01/2020	0.38 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
12/01/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/01/2020	0.28 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/01/2020	0.45 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/01/2020	0.44 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/01/2020	0.55 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/01/2020	0.48 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/07/2020	0.46 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/07/2020	0.43 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/07/2020	0.47 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/07/2020	0.53 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/08/2020	0.61 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/08/2020	0.54 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/08/2020	0.38 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/08/2020	0.63 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/08/2020	0.59 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/09/2020	0.59 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/09/2020	0.15 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/09/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/14/2020	0.46 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/14/2020	0.51 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/14/2020	0.46 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/14/2020	0.64 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/14/2020	0.62 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/14/2020	0.54 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/15/2020	0.68 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/15/2020	0.49 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/15/2020	0.71 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/15/2020	0.68 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/16/2020	0.32 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/16/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/22/2020	0.48 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/22/2020	0.55 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/22/2020	0.68 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/22/2020	0.50 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/22/2020	1.05 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/22/2020	0.69 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined

Chlorine (free)		Sampling Point Name	Criteria	
12/22/2020	0.38 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/22/2020	0.51 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/22/2020	0.87 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/22/2020	0.92 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/22/2020	0.97 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/22/2020	0.79 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/30/2020	0.48 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/30/2020	0.77 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/30/2020	0.62 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/30/2020	0.61 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/30/2020	0.51 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/30/2020	0.58 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/30/2020	0.76 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/31/2020	0.60 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/31/2020	0.36 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/31/2020	0.51 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/31/2020	0.60 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/31/2020	0.40 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined

# samples:	605	min:	0.00 mg/L
# detects:	605	max:	1.05 mg/L
# non-detects:	0	avg:	0.505 mg/L (based on 605 numerical results)
# of Exceedences:	2		

Chlorine (total)		Sampling Point Name	Criteria	
01/02/2020	0.74 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/02/2020	0.65 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/02/2020	0.29 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/02/2020	0.87 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/06/2020	0.63 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/06/2020	0.34 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
01/06/2020	0.52 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/07/2020	0.77 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/07/2020	0.66 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/07/2020	0.69 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/07/2020	0.45 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/07/2020	0.59 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/07/2020	0.27 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
01/07/2020	0.75 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/07/2020	0.71 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/07/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/13/2020	0.48 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/13/2020	0.32 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/13/2020	0.51 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/13/2020	0.41 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/13/2020	0.54 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/13/2020	0.63 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/13/2020	0.65 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/13/2020	0.56 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/13/2020	0.49 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/13/2020	0.14 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/13/2020	0.47 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
01/17/2020	0.52 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/20/2020	0.56 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/20/2020	0.49 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
01/20/2020	0.65 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/20/2020	0.59 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/20/2020	0.15 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/20/2020	0.50 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/20/2020	0.61 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/20/2020	0.58 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
01/21/2020	0.68 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/21/2020	0.32 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/22/2020	0.47 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/22/2020	0.65 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/27/2020	0.33 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
01/27/2020	0.79 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
01/27/2020	0.52 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
01/27/2020	0.66 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
01/29/2020	0.30 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
01/30/2020	0.46 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
01/30/2020	0.62 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
01/30/2020	0.64 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
01/30/2020	0.61 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
01/30/2020	0.64 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
01/31/2020	0.88 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
01/31/2020	0.56 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/03/2020	0.22 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/03/2020	0.64 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/03/2020	0.53 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/04/2020	0.80 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/04/2020	0.81 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/04/2020	0.76 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/04/2020	0.77 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/04/2020	0.55 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/04/2020	0.53 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/04/2020	0.80 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/04/2020	0.36 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/04/2020	0.71 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/10/2020	0.89 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/10/2020	0.51 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/10/2020	0.53 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/11/2020	0.63 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/11/2020	0.63 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/11/2020	0.68 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/11/2020	0.49 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/11/2020	0.56 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/11/2020	0.64 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/11/2020	0.65 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/11/2020	0.57 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/12/2020	0.43 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/18/2020	0.64 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/18/2020	0.50 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
02/18/2020	0.57 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/18/2020	0.55 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/18/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/19/2020	0.45 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/19/2020	0.57 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/19/2020	0.07 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/20/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/20/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/20/2020	0.55 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
02/20/2020	0.54 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/24/2020	0.45 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
02/24/2020	0.56 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
02/24/2020	0.57 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
02/24/2020	0.60 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
02/24/2020	0.49 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
02/24/2020	0.60 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
02/25/2020	0.45 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
02/25/2020	0.63 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
02/25/2020	0.70 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
02/25/2020	0.45 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
02/25/2020	0.30 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
02/25/2020	0.51 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/02/2020	0.39 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/02/2020	0.64 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/02/2020	0.26 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/03/2020	0.47 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/03/2020	0.41 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/03/2020	0.65 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/03/2020	0.27 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/03/2020	0.62 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/03/2020	0.46 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/03/2020	0.57 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/03/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/04/2020	0.51 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/09/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/09/2020	0.24 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/09/2020	0.56 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/09/2020	0.76 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/09/2020	0.60 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/09/2020	0.45 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/09/2020	0.89 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/09/2020	0.74 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/09/2020	0.83 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/09/2020	0.81 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/09/2020	0.66 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/09/2020	0.63 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
03/16/2020	0.39 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/16/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/16/2020	0.39 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/18/2020	0.49 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/18/2020	0.64 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/18/2020	0.64 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/18/2020	0.60 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/18/2020	0.54 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/18/2020	0.68 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/18/2020	0.52 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/20/2020	0.16 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/21/2020	0.61 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/23/2020	0.33 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/23/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/23/2020	0.62 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/23/2020	0.50 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/25/2020	0.14 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/25/2020	0.70 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
03/25/2020	0.64 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/25/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/25/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/25/2020	0.60 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/31/2020	0.62 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
03/31/2020	0.76 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
03/31/2020	0.59 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
03/31/2020	0.74 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
03/31/2020	0.57 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
03/31/2020	0.39 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
03/31/2020	0.56 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
03/31/2020	1.01 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
03/31/2020	0.69 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
03/31/2020	0.52 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
03/31/2020	0.88 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
03/31/2020	0.70 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/06/2020	0.50 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
04/06/2020	0.71 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/06/2020	0.55 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
04/06/2020	0.54 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/06/2020	0.68 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/06/2020	0.78 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/06/2020	0.66 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/07/2020	0.60 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/07/2020	0.59 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/07/2020	0.28 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/07/2020	0.50 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/07/2020	0.76 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/15/2020	0.66 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/15/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/15/2020	0.61 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/15/2020	0.58 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/15/2020	0.81 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/15/2020	0.65 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/15/2020	0.66 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/15/2020	0.58 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/16/2020	0.13 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/16/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/16/2020	0.61 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/20/2020	0.58 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/20/2020	0.65 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/20/2020	0.55 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/20/2020	0.52 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/20/2020	0.58 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/20/2020 10:25	0.51 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/22/2020	0.25 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/22/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/22/2020	0.51 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/22/2020	0.36 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/22/2020	0.66 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/22/2020	0.61 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
04/22/2020	0.67 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
04/28/2020	0.72 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
04/28/2020	0.44 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
04/28/2020	0.44 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
04/28/2020	0.79 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
04/29/2020	0.55 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
04/29/2020	0.21 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
04/29/2020	0.88 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
04/29/2020	0.70 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
04/29/2020	0.74 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
04/29/2020	0.68 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
04/29/2020	0.76 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
04/29/2020	0.49 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/04/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/04/2020	0.97 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/04/2020	0.42 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/04/2020	0.67 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/05/2020	0.46 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
05/05/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/05/2020	0.63 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/05/2020	0.73 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/05/2020	0.64 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/05/2020	0.76 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/05/2020	0.73 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/05/2020	0.44 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/11/2020	0.64 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/11/2020	0.64 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/11/2020	0.57 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/11/2020	0.69 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/12/2020	0.49 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/12/2020	0.58 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/12/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/12/2020	0.56 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/12/2020	0.38 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/12/2020	0.47 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/12/2020	0.13 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/12/2020	0.54 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
05/19/2020	0.55 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
05/19/2020	0.69 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/19/2020	0.70 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/20/2020	0.61 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
05/20/2020	0.65 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/20/2020	0.62 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/20/2020	0.59 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
05/20/2020	0.78 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/20/2020	0.16 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/20/2020	0.76 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/20/2020	0.84 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/20/2020	0.66 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/25/2020	0.35 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
05/25/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
05/25/2020	0.30 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
05/26/2020	0.60 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
05/26/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
05/26/2020	0.53 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
05/26/2020	0.29 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
05/26/2020	0.61 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
05/26/2020	0.45 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
05/26/2020	0.34 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
05/26/2020	0.58 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/01/2020	0.25 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/01/2020	0.61 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
06/01/2020	0.43 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
06/01/2020	0.41 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
06/02/2020	0.25 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/02/2020	0.33 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/03/2020	0.43 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
06/03/2020	0.51 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/04/2020	0.55 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/04/2020	0.44 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/04/2020	0.56 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/05/2020	0.60 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/11/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/12/2020	0.69 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/12/2020	0.33 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/12/2020	0.46 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/12/2020	0.79 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
06/12/2020	0.18 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/12/2020	0.56 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/15/2020	0.48 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/15/2020	0.56 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
06/15/2020	0.55 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
06/15/2020	0.51 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/15/2020	0.60 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/15/2020	0.52 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
06/15/2020	0.41 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/15/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
06/15/2020	0.44 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/15/2020	0.50 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/17/2020	0.39 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/17/2020	0.24 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/22/2020	0.58 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
06/22/2020	0.51 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
06/22/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
06/22/2020	0.46 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
06/22/2020	0.38 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
06/22/2020	0.49 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
06/23/2020	0.35 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
06/23/2020	0.50 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
06/23/2020	0.41 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
06/24/2020	0.50 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
06/24/2020	0.49 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
06/24/2020	0.34 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/03/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/03/2020	0.45 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/03/2020	0.61 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/03/2020	0.49 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/03/2020	0.47 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/03/2020	0.38 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/03/2020	0.52 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/03/2020	0.38 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/06/2020	0.43 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/06/2020	0.53 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/06/2020	0.57 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
07/06/2020	0.41 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/06/2020	0.53 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/06/2020	0.34 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/06/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/06/2020	0.48 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/07/2020	0.43 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/07/2020	0.37 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/07/2020	0.29 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/07/2020	0.39 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/13/2020	0.37 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/13/2020	0.61 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/13/2020	0.48 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/14/2020	0.57 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/14/2020	0.21 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/14/2020	0.37 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/14/2020	0.50 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/14/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/14/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/14/2020	0.62 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/14/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/14/2020	0.40 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
* 07/20/2020	0.04 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
07/21/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/21/2020	0.39 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/21/2020	0.55 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/22/2020	0.44 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/23/2020	0.50 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/23/2020	0.53 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/23/2020	0.40 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/23/2020	0.48 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/23/2020	0.60 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/23/2020	0.60 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
07/23/2020	0.45 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/27/2020	0.54 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
07/27/2020	0.54 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
07/27/2020	0.64 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
07/28/2020	0.62 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
07/28/2020	0.44 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
07/28/2020	0.56 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
07/28/2020	0.70 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
07/28/2020	0.57 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
07/28/2020	0.41 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
07/28/2020	0.61 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
07/28/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
07/29/2020	0.16 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/01/2020	0.65 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/01/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/01/2020	0.67 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/01/2020	0.59 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/01/2020	0.49 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/01/2020	0.63 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/01/2020	0.25 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/01/2020	0.63 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/01/2020	0.39 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/02/2020	0.62 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/02/2020	0.14 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/02/2020	0.46 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/04/2020	0.56 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/04/2020	0.24 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/04/2020	0.55 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/04/2020 12:45	0.38 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/06/2020	0.33 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/06/2020	0.51 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/06/2020	0.57 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/06/2020	0.55 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/06/2020	0.49 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/06/2020	0.62 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/10/2020	0.46 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/10/2020	0.53 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/10/2020	0.52 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/11/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/11/2020	0.43 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/11/2020	0.15 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/11/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
08/11/2020	0.31 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/11/2020	0.59 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/11/2020	0.41 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/11/2020	0.35 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/12/2020	0.29 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/12/2020	0.12 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/17/2020	0.27 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/17/2020	0.46 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/17/2020	0.47 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/18/2020	0.61 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/18/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/19/2020	0.58 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
08/19/2020	0.52 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/19/2020	0.43 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/19/2020	0.39 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/20/2020	0.31 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/20/2020	0.54 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/21/2020	0.21 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/24/2020	0.36 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
08/24/2020	0.45 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
08/24/2020	0.35 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
08/25/2020	0.50 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
08/25/2020	0.48 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
08/25/2020	0.51 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
08/26/2020	0.40 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
08/26/2020	0.35 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
08/27/2020	0.31 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
08/27/2020	0.62 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
08/27/2020	0.05 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/28/2020	0.32 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
08/28/2020	0.54 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/08/2020	0.24 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/08/2020	0.50 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/08/2020	0.41 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/14/2020	0.37 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/14/2020	0.39 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/14/2020	0.44 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/14/2020	0.52 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
09/14/2020	0.26 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
09/14/2020	0.43 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/14/2020	0.26 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
09/14/2020	0.41 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
09/14/2020	0.36 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/15/2020	0.22 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/15/2020	0.51 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
09/15/2020	0.53 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/22/2020	0.33 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/22/2020	0.39 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
09/22/2020	0.25 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
09/23/2020	0.17 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/23/2020	0.31 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/23/2020	0.51 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/23/2020	0.46 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/23/2020	0.45 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
09/23/2020	0.30 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/23/2020	0.35 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
09/23/2020	0.54 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/23/2020	0.42 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
09/28/2020	0.48 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
09/28/2020	0.49 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
09/28/2020	0.45 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
09/28/2020	0.35 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
09/29/2020	0.57 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
09/29/2020	0.53 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
09/29/2020	0.51 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
09/29/2020	0.22 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
09/29/2020	0.28 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
09/29/2020	0.32 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
09/29/2020	0.45 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
* 09/29/2020	50 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/05/2020	0.21 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/05/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/05/2020	0.46 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/06/2020	0.55 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/06/2020	0.44 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
10/06/2020	0.31 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/06/2020	0.51 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/06/2020	0.50 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/13/2020	0.34 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/13/2020	0.37 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
10/16/2020	0.39 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/16/2020	0.51 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/16/2020	0.36 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
10/16/2020	0.45 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/16/2020	0.43 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/16/2020	0.57 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/16/2020	0.55 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/16/2020	0.54 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/16/2020	0.48 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/16/2020	0.45 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
10/19/2020	0.45 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/19/2020	0.57 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/19/2020	0.63 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/19/2020	0.57 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/19/2020	0.73 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/19/2020	0.31 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
10/19/2020	0.71 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/20/2020	0.12 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/20/2020	0.43 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/20/2020	0.46 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/20/2020	0.68 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
10/20/2020	0.42 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
10/26/2020	0.60 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
10/26/2020	0.66 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
10/26/2020	0.99 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
10/26/2020	0.59 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
10/26/2020	0.64 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
10/26/2020	0.58 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
10/26/2020	0.86 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
10/26/2020	0.48 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
10/26/2020	0.72 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
10/27/2020	0.36 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
10/27/2020	0.48 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
10/27/2020	0.58 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
10/27/2020 09:25	0.62 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/02/2020	0.65 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/02/2020	0.69 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/02/2020	0.84 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/02/2020	0.38 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/02/2020	0.57 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/03/2020	0.59 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/03/2020	0.77 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/03/2020	0.48 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
11/03/2020	0.60 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/03/2020	0.62 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/03/2020	0.74 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/03/2020	0.55 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/09/2020	0.62 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/09/2020	0.49 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/09/2020	0.55 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/09/2020	0.70 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/09/2020	0.69 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/09/2020	0.69 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/09/2020	0.45 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/09/2020	0.90 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/13/2020	0.64 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/13/2020	0.51 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/13/2020	0.05 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/16/2020	0.57 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/16/2020	0.71 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/16/2020	0.21 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/17/2020	0.64 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/17/2020	0.60 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/17/2020	0.44 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/17/2020	0.36 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/17/2020	0.47 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
11/17/2020	0.50 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/17/2020	0.41 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/17/2020	0.54 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
11/17/2020	0.74 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/24/2020	0.68 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
11/25/2020	0.40 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
11/25/2020	0.51 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
11/25/2020	0.72 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
11/25/2020	0.58 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
11/25/2020	0.79 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/25/2020	0.48 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
11/25/2020	0.61 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
11/26/2020	0.60 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
11/26/2020	0.62 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
11/26/2020	0.47 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
11/26/2020	0.82 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
11/30/2020	0.63 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
11/30/2020	0.29 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/01/2020	0.28 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/01/2020	0.54 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/01/2020	0.56 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/01/2020	0.47 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/01/2020	0.52 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/01/2020	0.56 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/01/2020	0.54 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/01/2020	0.56 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/01/2020	0.44 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/01/2020	0.51 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/01/2020	0.52 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/01/2020	0.62 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/07/2020	0.67 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/07/2020	0.50 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/07/2020	0.52 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/07/2020	0.48 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/08/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/08/2020	0.57 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/08/2020	0.62 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/08/2020	0.42 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/08/2020	0.64 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/09/2020	0.26 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined

Chlorine (total)		Sampling Point Name	Criteria	
12/09/2020	0.60 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/09/2020	0.63 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/14/2020	0.64 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/14/2020	0.61 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/14/2020	0.58 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/14/2020	0.62 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/14/2020	0.62 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/14/2020	0.52 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/15/2020	0.71 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/15/2020	0.74 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/15/2020	0.52 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/15/2020	0.65 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/16/2020	0.28 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/16/2020	0.49 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/22/2020	0.81 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/22/2020	0.49 mg/L	Chemainus Rd South EOL	>=0.05, <=4	User-Defined
12/22/2020	1.06 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/22/2020	1.01 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/22/2020	0.63 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/22/2020	0.63 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/22/2020	0.58 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/22/2020	0.63 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/22/2020	1.00 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/22/2020	0.88 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/22/2020	0.58 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/22/2020	0.39 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined
12/30/2020	0.60 mg/L	3220 Dogwood	>=0.05, <=4	User-Defined
12/30/2020	0.65 mg/L	Mckay Rd PRV Vault	>=0.05, <=4	User-Defined
12/30/2020	0.63 mg/L	Old Victoria Rd PRV	>=0.05, <=4	User-Defined
12/30/2020	0.62 mg/L	3483 Henry Rd	>=0.05, <=4	User-Defined
12/30/2020	0.56 mg/L	Henry Rd Reducer	>=0.05, <=4	User-Defined
12/30/2020	0.83 mg/L	River Rd Reducer	>=0.05, <=4	User-Defined
12/30/2020	0.80 mg/L	3217 Channel Blvd	>=0.05, <=4	User-Defined
12/31/2020	0.43 mg/L	10139 Island View Close	>=0.05, <=4	User-Defined
12/31/2020	0.63 mg/L	9324 Cottonwood	>=0.05, <=4	User-Defined
12/31/2020	0.62 mg/L	Ferry Terminal	>=0.05, <=4	User-Defined
12/31/2020	0.46 mg/L	Bare Pt Rd Tank Farm	>=0.05, <=4	User-Defined

Chlorine (total)	Sampling Point Name	Criteria
12/31/2020 0.70 mg/L	Chemainus Rd South EOL	>=0.05, <=4 User-Defined

# samples:	605	min:	0.04 mg/L
# detects:	605	max:	50 mg/L
# non-detects:	0	avg:	0.61 mg/L (based on 605 numerical results)
# of Exceedences:	2		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



DISINFECTANTS

Total Chloramines (as combined chlorine)(Lab Data Transfer) Criteria

04/20/2020 10:25	< 0.0400 mg/L	<=3.0	MAC
08/04/2020 12:45	< 0.0400 mg/L	<=3.0	MAC
10/27/2020 09:25	0.0800 mg/L	<=3.0	MAC

# samples:	3	min:	< 0.0400 mg/L
# detects:	1	max:	0.0800 mg/L
# non-detects:	2	avg:	0.0800 mg/L (based on 1 numerical results)
# of Exceedences:	0		

INORGANIC

Aluminum (total)(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.0050 mg/L	<=0.2	Secondary Standard
------------------	---------------	-------	--------------------

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.00020 mg/L	<=0.006	MCL
------------------	----------------	---------	-----

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.00050 mg/L	<=0.010	MCL
------------------	----------------	---------	-----

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45	0.0074 mg/L	<=2	MCL
------------------	-------------	-----	-----

# samples:	1	min:	0.0074 mg/L
-------------------	---	-------------	-------------

# detects:	1	max:	0.0074 mg/L
# non-detects:	0	avg:	0.0074 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.00010 mg/L	<=0.004 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.00010 mg/L	

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 0.0870 mg/L	<=5 MAC

# samples:	1	min:	0.0870 mg/L
# detects:	1	max:	0.0870 mg/L
# non-detects:	0	avg:	0.0870 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Bromate(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.010 mg/L	<=0.01 MAC

# samples:	1	min:	< 0.010 mg/L
# detects:	0	max:	< 0.010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.000010 mg/L	<=0.005 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Calcium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 7.44 mg/L

# samples:	1	min:	7.44 mg/L
# detects:	1	max:	7.44 mg/L
# non-detects:	0	avg:	7.44 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer) Criteria

08/04/2020 12:45 2.47 mg/L <=250 Secondary Standard

# samples:	1	min:	2.47 mg/L
# detects:	1	max:	2.47 mg/L
# non-detects:	0	avg:	2.47 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00050 mg/L <=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00010 mg/L

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 0.0115 mg/L <=1 Secondary Standard

# samples:	1	min:	0.0115 mg/L
# detects:	1	max:	0.0115 mg/L
# non-detects:	0	avg:	0.0115 mg/L (based on 1 numerical results)
# of Exceedences:	0		



Cyanide (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.0020 mg/L <=0.2 MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.10 mg/L <=4.0 MCL

# samples:	1	min:	< 0.10 mg/L
# detects:	0	max:	< 0.10 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.010 mg/L <=0.3 Secondary Standard

# samples:	1	min:	< 0.010 mg/L
# detects:	0	max:	< 0.010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 0.00035 mg/L <=0.015 MCL

# samples:	1	min:	0.00035 mg/L
# detects:	1	max:	0.00035 mg/L
# non-detects:	0	avg:	0.00035 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lithium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00010 mg/L

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 0.832 mg/L

# samples:	1	min:	0.832 mg/L
# detects:	1	max:	0.832 mg/L
# non-detects:	0	avg:	0.832 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 0.00023 mg/L <=0.05 Secondary Standard

# samples:	1	min:	0.00023 mg/L
# detects:	1	max:	0.00023 mg/L
# non-detects:	0	avg:	0.00023 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000010 mg/L <=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 0.00010 mg/L

# samples:	1	min:	0.00010 mg/L
# detects:	1	max:	0.00010 mg/L
# non-detects:	0	avg:	0.00010 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00040 mg/L <=0.1 MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer) Criteria

08/04/2020 12:45 0.036 mg/L <=10 MCL

# samples:	1	min:	0.036 mg/L
# detects:	1	max:	0.036 mg/L
# non-detects:	0	avg:	0.036 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer) Criteria
 08/04/2020 12:45 0.16 mg/L

# samples:	1	min:	0.16 mg/L
# detects:	1	max:	0.16 mg/L
# non-detects:	0	avg:	0.16 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.00050 mg/L <=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer) Criteria
 08/04/2020 12:45 3.5 mg/L

# samples:	1	min:	3.5 mg/L
# detects:	1	max:	3.5 mg/L
# non-detects:	0	avg:	3.5 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000050 mg/L <=0.1 Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer) Criteria
 08/04/2020 12:45 2.11 mg/L <=160 MCL

# samples:	1	min:	2.11 mg/L
# detects:	1	max:	2.11 mg/L

# non-detects:	0	avg:	2.11 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 0.0292 mg/L	

# samples:	1	min:	0.0292 mg/L
# detects:	1	max:	0.0292 mg/L
# non-detects:	0	avg:	0.0292 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 3.0 mg/L	

# samples:	1	min:	< 3.0 mg/L
# detects:	0	max:	< 3.0 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Criteria
08/04/2020 12:45 2.5 mg/L	<=250 Secondary Standard

# samples:	1	min:	2.5 mg/L
# detects:	1	max:	2.5 mg/L
# non-detects:	0	avg:	2.5 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.020 mg/L	

# samples:	1	min:	< 0.020 mg/L
# detects:	0	max:	< 0.020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Thallium (total)(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.000020 mg/L	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Tin (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00020 mg/L

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.0050 mg/L

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.0010 mg/L

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.0040 mg/L <=5 Secondary Standard

# samples:	1	min:	< 0.0040 mg/L
# detects:	0	max:	< 0.0040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00010 mg/L

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

MICROORGANISMS



Iron Bacteria (counts)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 1 CFU/ml

# samples:	1	min:	< 1 CFU/ml
# detects:	0	max:	< 1 CFU/ml
# non-detects:	1	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

ORGANIC

1-Methylnaphthalene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6-Tetrachlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00050 mg/L <=0.001 AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



2,3,5-Trichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.20 ug/L

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.20 ug/L

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.10 ug/L		
# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.00050 mg/L	<=0.002	AO (MAC is 0.005 mg/L)
# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,6-Dichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.20 ug/L		
# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chloronaphthalene(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.100 ug/L		
# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45	< 0.10 ug/L		
# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.20 ug/L

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Methylnaphthalene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.10 ug/L

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.20 ug/L

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,5-Dichlorophenol(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.40 ug/L

# samples:	1	min:	< 0.40 ug/L
# detects:	0	max:	< 0.40 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.50 ug/L

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acenaphthene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acenaphthylene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.200 ug/L

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acridine(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Aldrin(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.006 ug/L

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Atrazine + N-dealkylated metabolites(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000100 mg/L <=0.005 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Azinphos-methyl(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000200 mg/L <=0.02 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Benzo(a)anthracene(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)pyrene(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000010 mg/L <=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(g,h,i)perylene(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(k)fluoranthene(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

beta-BHC(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.050 ug/L



# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromacil(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoxynil(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000200 mg/L <=0.005 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.020 ug/L

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorothalonil(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorpyrifos(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.000010 mg/L	<=0.09 MAC

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chrysene(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.050 ug/L	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.100 ug/L	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.010 ug/L	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

delta-BHC(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.050 ug/L	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Deltamethrin(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diazinon(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000020 mg/L <=0.02 MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dibenzo(a,h)anthracene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dicamba(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00010 mg/L <=0.12 MAC

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichlorvos(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diclofop-methyl(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000100 mg/L <=0.009 MAC



# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000200 mg/L <=0.02 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Disulfoton(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diuron(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000200 mg/L <=0.15 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan (total)(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan sulfate(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin aldehyde(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.020 ug/L

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin ketone(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.020 ug/L

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fenchlorphos(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoranthene(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.030 ug/L

# samples:	1	min:	< 0.030 ug/L
# detects:	0	max:	< 0.030 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluorene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Linuron(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000100 mg/L <=0.19 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl parathion(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000100 mg/L <=0.05 MAC



# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.000200 mg/L	<=0.08 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.200 ug/L	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitritotriacetic acid / NTA(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.20 mg/L	<=0.4 MAC

# samples:	1	min:	< 0.20 mg/L
# detects:	0	max:	< 0.20 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)	Criteria
08/04/2020 12:45 < 0.0050 mg/L	<=0.007 MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachlorophenol / PCP(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00050 mg/L <=0.001 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Permethrin(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.010 ug/L

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Phenanthrene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Phorate(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000100 mg/L <=0.002 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometon(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.300 ug/L

# samples:	1	min:	< 0.300 ug/L
# detects:	0	max:	< 0.300 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometryn(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pyrene(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.020 ug/L

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Quinoline(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.100 ug/L



# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tebuthiuron(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.200 ug/L

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temephos(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.500 ug/L

# samples:	1	min:	< 0.500 ug/L
# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Terbufos(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000100 mg/L <=0.001 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.100 ug/L

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trifluralin(Lab Data Transfer) Criteria
 08/04/2020 12:45 < 0.000200 mg/L <=0.045 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

PCBS

Aroclor 1016(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Aroclor 1254(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1262(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1268(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 ug/L

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



PHYSICAL

Hardness (total, as CaCO3)(Lab Data Transfer)		Criteria	
08/04/2020 12:45	22.0 mg/L		

# samples:	1	min:	22.0 mg/L
# detects:	1	max:	22.0 mg/L
# non-detects:	0	avg:	22.0 mg/L (based on 1 numerical results)
# of Exceedences:	0		

pH(Lab Data Transfer)		Criteria	
08/04/2020 12:45	7.09	>=6.5, <=8.5	Secondary Standard

# samples:	1	min:	7.09
# detects:	1	max:	7.09
# non-detects:	0	avg:	7.09 (based on 1 numerical results)
# of Exceedences:	0		

RADIONUCLIDES

Uranium (total)(Lab Data Transfer)		Criteria	
08/04/2020 12:45	< 0.000020 mg/L	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

SOCS

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)		Criteria	
08/04/2020 12:45	< 0.00010 mg/L	<=0.07	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alachlor(Lab Data Transfer)		Criteria	
08/04/2020 12:45	< 0.000100 mg/L	<=0.002	MCL

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Chlordane(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000050 mg/L <=0.002 MCL

samples: 1 **min:** < 0.000050 mg/L
detects: 0 **max:** < 0.000050 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Dinoseb(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00010 mg/L <=0.007 MCL

samples: 1 **min:** < 0.00010 mg/L
detects: 0 **max:** < 0.00010 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Diquat(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.0100 mg/L <=0.02 MCL

samples: 1 **min:** < 0.0100 mg/L
detects: 0 **max:** < 0.0100 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Endrin(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000020 mg/L <=0.002 MCL

samples: 1 **min:** < 0.000020 mg/L
detects: 0 **max:** < 0.000020 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0

Glyphosate(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.050 mg/L <=0.7 MCL

samples: 1 **min:** < 0.050 mg/L
detects: 0 **max:** < 0.050 mg/L
non-detects: 1 **avg:** n/a (based on 0 numerical results)
of Exceedences: 0



Heptachlor epoxide(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000010 mg/L <=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000010 mg/L <=0.0004 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000050 mg/L <=0.0002 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methoxychlor(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000050 mg/L <=0.04 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Picloram(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.00010 mg/L <=0.5 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Simazine(Lab Data Transfer) Criteria

08/04/2020 12:45 < 0.000200 mg/L <=0.004 MCL



# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* Indicates Criteria is exceeded

Escherichia coli / E. coli (Count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/13/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
02/10/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
03/09/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
04/15/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
05/11/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
06/08/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
07/07/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
07/13/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
08/10/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
09/14/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
10/13/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
11/09/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
12/07/2020 0 CFU/100ml	Chemainus Rd South EOL	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined

# samples:	13	min:	0 CFU/100ml
# detects:	13	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 13 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/20/2020 0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
02/24/2020 0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
03/16/2020 0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
04/20/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
05/19/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
06/15/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
07/21/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
08/17/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
09/22/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
10/19/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
11/16/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
12/14/2020	0 CFU/100ml	3483 Henry Rd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined

# samples:	12	min:	0 CFU/100ml
# detects:	12	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 12 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/13/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
02/10/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
03/09/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
04/15/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
05/11/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
06/08/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
07/13/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
08/10/2020	0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
09/14/2020 0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
11/09/2020 0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
12/07/2020 0 CFU/100ml	River Rd Reducer	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/06/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
02/03/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
03/02/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
04/06/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
05/04/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
06/01/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
07/07/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
08/04/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
09/08/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
10/05/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
10/13/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
11/02/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
11/30/2020 0 CFU/100ml	Ferry Terminal	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined

# samples:	13	min:	0 CFU/100ml
-------------------	----	-------------	-------------



# detects:	13	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 13 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/06/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
02/03/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
03/02/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
04/06/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
05/04/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
06/01/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
07/07/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
08/04/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
09/08/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
10/05/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
11/02/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
11/30/2020	0 CFU/100ml	3217 Channel Blvd	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined

# samples:	12	min:	0 CFU/100ml
# detects:	12	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 12 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
02/18/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
03/23/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
04/28/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
05/25/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
06/23/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
07/27/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
09/28/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
10/26/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
12/14/2020	0 CFU/100ml	3220 Dogwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined

# samples:	10	min:	0 CFU/100ml
# detects:	10	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 10 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/13/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
02/10/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
03/09/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
04/15/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
05/11/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
06/08/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
07/13/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
08/10/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
09/14/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
10/13/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
11/09/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
12/07/2020	0 CFU/100ml	9324 Cottonwood	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined

# samples:	12	min:	0 CFU/100ml
# detects:	12	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 12 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (Count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/20/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
02/24/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
03/16/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
04/20/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
06/15/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
07/21/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
08/17/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
09/22/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
10/19/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
11/16/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined
12/14/2020	0 CFU/100ml	10139 Island View Close	Escherichia coli / E. coli (Count)	<=0, OG, P	User-Defined

# samples:	11	min:	0 CFU/100ml
# detects:	11	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 11 numerical results)
# of Exceedences:	0		



Escherichia coli / E. coli (Count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/20/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
02/24/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
03/16/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
04/20/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
05/19/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
06/15/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
07/21/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
08/17/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
09/22/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
10/19/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
11/16/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined
12/14/2020 0 CFU/100ml	Mckay Rd PRV Vault	Escherichia coli / E. coli (Count)	<=0, OG, P User-Defined

# samples:	12	min:	0 CFU/100ml
# detects:	12	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 12 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts)	<=0, OG, P User-Defined
02/18/2020 0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts)	<=0, OG, P User-Defined
03/23/2020 0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts)	<=0, OG, P User-Defined
04/28/2020 0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts)	<=0, OG, P User-Defined
05/25/2020 0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts)	<=0, OG, P User-Defined



Escherichia coli / E. coli (counts)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
06/23/2020	0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
09/28/2020	0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
10/26/2020	0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
12/14/2020	0 CFU/100ml	Henry Rd Reducer	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined

# samples:	9	min:	0 CFU/100ml
# detects:	9	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 9 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/06/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
02/03/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
03/02/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
04/06/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
05/04/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
06/01/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
07/07/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
08/04/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
09/08/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
10/05/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
11/02/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined
11/30/2020	0 CFU/100ml	Bare Pt Rd Tank Farm	Escherichia coli / E. coli (counts) <=0, OG, P User-Defined

# samples:	12	min:	0 CFU/100ml
-------------------	----	-------------	-------------



# detects:	12	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 12 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
02/18/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
03/23/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
04/28/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
05/25/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
06/23/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
07/27/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
09/28/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
10/26/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined
12/14/2020	0 CFU/100ml	Old Victoria Rd PRV	Escherichia coli / E. coli (counts)	<=0, OG, P	User-Defined

# samples:	10	min:	0 CFU/100ml
# detects:	10	max:	0 CFU/100ml
# non-detects:	0	Geometric Mean:	0 CFU/100ml (based on 10 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/20/2020	0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P	User-Defined
02/24/2020	0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P	User-Defined
03/16/2020	0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P	User-Defined
04/20/2020	0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P	User-Defined
05/19/2020	0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P	User-Defined



Total Coliforms (count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
06/15/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined
07/21/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined
08/17/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined
09/22/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined
10/19/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined
11/16/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined
12/14/2020 0	Mckay Rd PRV Vault	Total Coliforms (count)	<=0, OG, P User-Defined

# samples:	12	min:	0
# detects:	12	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 12 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
* 01/06/2020 13	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
02/03/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
03/02/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
04/06/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
05/04/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
06/01/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
07/07/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
08/04/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
09/08/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
10/05/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined
11/02/2020 0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P User-Defined



Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
11/30/2020	0	Bare Pt Rd Tank Farm	Total Coliforms (count)	<=0, OG, P	User-Defined
# samples:	12	min:	0		
# detects:	12	max:	13		
# non-detects:	0	Geometric Mean:	1 (based on 12 numerical results)		
# of Exceedences:	1				

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/13/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
02/10/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
03/09/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
04/15/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
05/11/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
06/08/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
07/07/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
07/13/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
08/10/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
09/14/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
10/13/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
11/09/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
12/07/2020	0	Chemainus Rd South EOL	Total Coliforms (count)	<=0, OG, P	User-Defined
# samples:	13	min:	0		
# detects:	13	max:	0		
# non-detects:	0	Geometric Mean:	0 (based on 13 numerical results)		
# of Exceedences:	0				



Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/20/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
02/24/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
03/16/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
04/20/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
05/19/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
06/15/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
07/21/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
08/17/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
09/22/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
10/19/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
11/16/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined
12/14/2020	0	3483 Henry Rd	Total Coliforms (count)	<=0, OG, P	User-Defined

# samples:	12	min:	0
# detects:	12	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 12 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020	0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P	User-Defined
02/18/2020	0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P	User-Defined
03/23/2020	0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P	User-Defined
04/28/2020	0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P	User-Defined
05/25/2020	0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P	User-Defined
06/23/2020	0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P	User-Defined



Total Coliforms (count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
09/28/2020 0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
10/26/2020 0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
12/14/2020 0	Henry Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined

# samples:	9	min:	0
# detects:	9	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 9 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/13/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
02/10/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
03/09/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
04/15/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
05/11/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
06/08/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
07/13/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
08/10/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
09/14/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
11/09/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined
12/07/2020 0	River Rd Reducer	Total Coliforms (count)	<=0, OG, P User-Defined

# samples:	11	min:	0
# detects:	11	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 11 numerical results)
# of Exceedences:	0		



Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/06/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
02/03/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
03/02/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
04/06/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
05/04/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
06/01/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
07/07/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
08/04/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
09/08/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
10/05/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
10/13/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
11/02/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined
11/30/2020	0	Ferry Terminal	Total Coliforms (count)	<=0, OG, P	User-Defined

# samples:	13	min:	0
# detects:	13	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 13 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/06/2020	0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P	User-Defined
02/03/2020	0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P	User-Defined
03/02/2020	0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P	User-Defined
04/06/2020	0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P	User-Defined
05/04/2020	0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P	User-Defined



Total Coliforms (count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
06/01/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined
07/07/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined
08/04/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined
09/08/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined
10/05/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined
11/02/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined
11/30/2020 0	3217 Channel Blvd	Total Coliforms (count)	<=0, OG, P User-Defined

# samples:	12	min:	0
# detects:	12	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 12 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)	Sampling Point Name	Measurement Name	Criteria
01/27/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
02/18/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
03/23/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
04/28/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
05/25/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
06/23/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
07/27/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
09/28/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
10/26/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined
12/14/2020 0	3220 Dogwood	Total Coliforms (count)	<=0, OG, P User-Defined

# samples:	10	min:	0
-------------------	----	-------------	---



# detects:	10	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 10 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/13/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
02/10/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
03/09/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
04/15/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
05/11/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
06/08/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
07/13/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
* 08/10/2020	1	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
09/14/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
10/13/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
11/09/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined
12/07/2020	0	9324 Cottonwood	Total Coliforms (count)	<=0, OG, P	User-Defined

# samples:	12	min:	0
# detects:	12	max:	1
# non-detects:	0	Geometric Mean:	1 (based on 12 numerical results)
# of Exceedences:	1		

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/27/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
02/18/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
03/23/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined



Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
04/28/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
05/25/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
06/23/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
07/27/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
09/28/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
10/26/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined
12/14/2020	0	Old Victoria Rd PRV	Total Coliforms (count)	<=0, OG, P	User-Defined

# samples:	10	min:	0
# detects:	10	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 10 numerical results)
# of Exceedences:	0		

Total Coliforms (count)(Laboratory Report)		Sampling Point Name	Measurement Name	Criteria	
01/20/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
02/24/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
03/16/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
04/20/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
06/15/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
07/21/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
08/17/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
09/22/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
10/19/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
11/16/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined
12/14/2020	0	10139 Island View Close	Total Coliforms (count)	<=0, OG, P	User-Defined



# samples:	11	min:	0
# detects:	11	max:	0
# non-detects:	0	Geometric Mean:	0 (based on 11 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* Indicates Criteria is exceeded