

February 27, 2023

File: 5610-55

Environmental Health Officer  
Central Vancouver Island Health Region  
1665 Grant Avenue  
Nanaimo, BC V9S 5K7

Dear Environmental Health Officer

**Re: Crofton Water System Water Quality Report  
Premises Number 1310822  
Report for the Period Jan 1/22 to Dec 31/22**

Please find the Municipality of North Cowichan's Water quality report for the Crofton Water System attached.

Sincerely



Robert Bell  
Manager, Utilities

[robert.bell@northcowichan.ca](mailto:robert.bell@northcowichan.ca)



## 1 Operator Information

Contact Name Robert Bell Manager, Utilities  
Phone 250-746-3100  
Email [robert.bell@northcowichan.ca](mailto:robert.bell@northcowichan.ca)

## 2 System Description

This is a surface water supply. Water is pumped from the Cowichan River to Catalyst's water treatment plant. The water treatment plant consists of a coagulation and flocculation process, followed by sedimentation and filtration. The water is chlorinated at the water treatment plant and pumped to the Robert Street Reservoir where a small amount of additional chlorine is added to ensure adequate reduction of Giardia and Cryptosporidium cysts.

## 3 Boil Advisories

None

## 4 Future Improvements

No future improvements are contemplated at this time.

## 5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

## 6 Results

See below for the results of various water quality parameters.

Sincerely



Robert Bell  
Manager, Utilities  
cc Clay Reitsma Director, Engineering

Report Name: Crofton, Water Quality Report

Report Subtitle: Water Quality Report

January 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir (Turb Meter Data)	Mann St PS (Turb Meter Data)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)	Turbidity (Daily Avg) (NTU)
1	543.45	1.09	1.09	0.16	0.19
2	551.93	1.09	1.1	0.16	0.17
3	537.54	1.09	1.11	0.16	0.16
4	503.14	1.06	1.11	0.16	0.18
5	493.08	1.04	1.06	0.15	0.2
6	498.13	1.04	1.06	0.16	0.22
7	494.81	1.02	1.02	0.17	0.23
8	507.12	1.02	1.02	0.18	0.17
9	532.45	0.99	1	0.18	0.15
10	519.29	1.01	1.01	0.16	0.14
11	497.97	1.02	1.03	0.15	0.17
12	498.42	1.01	1.03	0.14	0.19
13	498.42	1.01	1.01	0.13	0.16
14	492.9	0.96	0.96	0.13	0.15
15	466.8	0.96	0.96	0.12	0.18
16	458.44	0.96	0.97	0.12	0.2
17	449.65	0.96	0.98	0.13	0.18
18	422.75	0.98	0.99	0.14	0.18
19	418.97	0.98	0.98	0.15	0.17
20	417.53	0.96	0.97	0.15	0.32
21	422	0.93	0.95	0.17	0.17
22	427.42	0.92	0.93	0.18	0.14
23	447.98	0.91	0.92	0.17	0.15
24	447.11	0.9	0.9	0.15	0.11
25	419.96	0.91	0.91	0.14	0.09
26	412.61	0.91	0.94	0.14	0.13
27	417.46	0.93	0.94	0.13	0.13
28	423.34	0.95	0.95	0.12	0.12
29	422.8	0.95	0.95	0.13	0.11
30	444.22	0.96	0.96	0.12	0.17
31	452.51	0.96	0.97	0.15	0.18
<b>Average</b>	469.04	0.98	0.99	0.15	0.17
<b>Minimum</b>	412.61	0.9	0.9	0.12	0.09
<b>Maximum</b>	551.93	1.09	1.11	0.18	0.32
<b>Count</b>	31	31	31	31	31
<b>Total</b>	14,540.20				
<b>95 Percentile</b>				0.18	0.27
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	458.44	0.96	0.98	0.15	0.17

February 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	430.87	0.95	0.95	0.17	0.13
2	426.64	0.94	0.95	0.19	0.14
3	429.01	0.94	0.95	0.19	0.12
4	422.44	0.92	0.93	0.18	0.11
5	416	0.92	0.92	0.16	0.11
6	441.98	0.93	0.93	0.15	0.1
7	454.72	0.93	0.94	0.14	0.11
8	416.84	0.95	0.95	0.14	0.1
9	412.94	0.96	0.98	0.13	0.1
10	417.72	0.98	0.98	0.12	0.1
11	407.24	0.98	0.98	0.13	0.11
12	421.71	0.97	0.97	0.13	0.11
13	450.55	0.98	0.98	0.13	0.13
14	442.59	0.97	0.97	0.13	0.11
15	409.28	0.97	0.97	0.13	0.1
16	408.7	0.97	0.97	0.13	0.1
17	418.66	0.92	0.93	0.12	0.11
18	417.07	0.91	0.92	0.11	0.1
19	429.35	0.93	0.93	0.11	0.1
20	442.88	0.94	0.95	0.11	0.1
21	451.99	0.95	0.95	0.11	0.1
22	457.15	0.95	0.95	0.1	0.1
23	441.11	0.96	0.99	0.1	0.1
24	437.54	0.99	1.02	0.1	0.11
25	426.23	1.02	1.02	0.1	0.13
26	432.96	1.02	1.02	0.11	0.13
27	465.37	0.99	0.99	0.11	0.3
28	459.12	0.99	1.03	0.12	0.25

<b>Average</b>	431.74	0.96	0.97	0.13	0.12
<b>Minimum</b>	407.24	0.91	0.92	0.1	0.1
<b>Maximum</b>	465.37	1.02	1.03	0.19	0.3
<b>Count</b>	28	28	28	28	28
<b>Total</b>	12,088.66				
<b>95 Percentile</b>				0.19	0.28
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	429.18	0.96	0.96	0.13	0.11

March 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	430.57	1	1	0.14	0.13
2	415.23	1.01	1.02	0.14	0.18
3	419.27	1.02	1.02	0.15	0.15
4	434.75	1	1.01	0.15	0.13
5	448.37	1.01	1.03	0.15	0.14
6	479.83	1.03	1.03	0.15	0.16
7	476.39	1.03	1.04	0.16	0.12
8	427.57	1.02	1.06	0.14	0.14
9	397.63	1.01	1.05	0.14	0.14
10	396.49	0.91	0.98	0.15	0.14
11	397.14	0.84	0.9	0.15	0.12
12	405.91	0.74	0.78	0.15	0.16
13	413.56	0.74	0.78	0.16	0.16
14	396.19	0.72	0.74	0.16	0.23
15	388.38	0.75	0.75	0.17	0.19
16	392.46	0.75	0.77	0.19	0.16
17	396.47	0.76	0.81	0.2	0.19
18	401.23	0.81	0.86	0.22	0.22
19	411.12	0.86	0.9	0.23	0.14
20	421.06	0.89	0.97	0.23	0.15
21	419.7	0.97	1.02	0.22	0.14
22	406.63	1	1.02	0.2	0.14
23	395.95	1	1.03	0.18	0.13
24	399.05	1.01	1.04	0.17	0.14
25	403.53	1.04	1.06	0.16	0.13
26	427.33	1.04	1.06	0.15	0.17
27	445.06	1.02	1.03	0.16	0.18
28	441.25	0.99	1.02	0.17	0.18
29	416.11	0.98	0.99	0.17	0.18
30	400.5	0.96	0.97	0.19	0.13
31	411.72	0.95	0.95	0.2	0.15

<b>Average</b>	416.66	0.93	0.96	0.17	0.16
<b>Minimum</b>	388.38	0.72	0.74	0.14	0.12
<b>Maximum</b>	479.83	1.04	1.06	0.23	0.23
<b>Count</b>	31	31	31	31	31
<b>Total</b>	12,916.45				
<b>95 Percentile</b>				0.23	0.22
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	411.72	0.99	1.01	0.16	0.15

April 2022	Robert St C12 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	408.65	0.93	0.96	0.21	0.16
2	409.03	0.93	0.95	0.21	0.13
3	425.34	0.95	0.97	0.19	0.17
4	421.69	0.93	0.97	0.18	0.19
5	408.89	0.91	0.93	0.18	0.21
6	408.23	0.92	0.93	0.18	0.14
7	413.94	0.92	0.95	0.18	0.14
8	408.96	0.93	0.97	0.17	0.13
9	418.69	0.97	0.99	0.16	0.13
10	441.3	0.98	1	0.14	0.14
11	435.78	0.99	1.01	0.14	0.13
12	424.05	0.99	1.01	0.13	0.14
13	443.21	0.99	1	0.14	0.18
14	483.59	0.99	1	0.13	0.16
15	520.63	1	1.02	0.13	0.16
16	530.1	1	1.01	0.12	0.19
17	464.33	0.99	1.01	0.12	0.16
18	436.15	0.98	1	0.12	0.18
19	422.78	0.96	0.98	0.1	0.18
20	409.18	0.94	0.98	0.1	0.18
21	412.36	0.95	0.96	0.11	0.18
22	422.49	0.92	0.95	0.11	0.18
23	429.13	0.93	0.96	0.1	0.18
24	464.6	0.95	0.97	0.1	0.18
25	479.85	0.96	0.99	0.11	0.12
26	453.8	0.96	0.98	0.1	0.12
27	445.64	0.92	0.98	0.1	0.12
28	439.87	0.97	1	0.1	0.13
29	422.25	0.99	1.02	0.1	0.13
30	423.88	0.99	1.03	0.1	0.12

<b>Average</b>	437.61	0.96	0.98	0.14	0.16
<b>Minimum</b>	408.23	0.91	0.93	0.1	0.12
<b>Maximum</b>	530.1	1	1.03	0.21	0.21
<b>Count</b>	30	30	30	30	30
<b>Total</b>	13,128.39				
<b>95 Percentile</b>				0.21	0.20
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	424.70	0.96	0.98	0.13	0.16

May 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir (Turb Meter Data)	Mann St PS (Turb Meter Data)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)	Turbidity (Daily Avg) (NTU)
1	458.45	1.01	1.05	0.1	0.17
2	453.02	0.96	1.04	0.1	0.12
3	418.81	0.93	0.96	0.09	0.11
4	424.49	0.93	0.94	0.09	0.11
5	422.1	0.9	0.94	0.08	0.11
6	430.27	0.92	0.94	0.08	0.11
7	459.96	0.93	0.97	0.08	0.13
8	490.7	0.95	0.99	0.08	0.15
9	492.58	0.95	0.98	0.08	0.15
10	446.62	0.95	0.98	0.08	0.14
11	439.69	0.95	0.98	0.08	0.15
12	439.93	0.94	0.97	0.08	0.15
13	424.86	0.94	0.98	0.08	0.16
14	423.22	0.94	0.99	0.08	0.15
15	437.87	0.94	0.98	0.08	0.16
16	467.55	0.97	1.06	0.09	0.06
17	518.46	1.05	1.09	0.1	0.02
18	527.88	1.05	1.09	0.1	0.02
19	548.57	1.07	1.09	0.09	0.02
20	626.08	1.09	1.13	0.08	0.01
21	630.72	1.06	1.12	0.08	0
22	632.84	1.01	1.06	0.08	0
23	633.19	1.02	1.05	0.07	-0.01
24	616.38	1.02	1.05	0.08	0.04
25	585.16	1.01	1.04	0.08	0.04
26	557.18	0.97	1.02	0.08	0.05
27	475.59	0.94	0.98	0.09	0.05
28	433.55	0.96	0.98	0.09	0.06
29	449.78	0.93	0.96	0.09	0.06
30	444.9	0.92	0.97	0.09	0.05
31	446.21	0.91	0.94	0.09	0.04

<b>Average</b>	492.15	0.97	1.01	0.09	0.08
<b>Minimum</b>	418.81	0.9	0.94	0.07	-0.01
<b>Maximum</b>	633.19	1.09	1.13	0.1	0.17
<b>Count</b>	31	31	31	31	31
<b>Total</b>	15,256.61				
<b>95 Percentile</b>				0.10	0.16
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	458.45	0.95	0.98	0.08	0.06

June 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	475.37	0.89	0.94	0.09	0.03
2	477.74	0.91	0.95	0.08	0.02
3	463.15	0.91	0.95	0.08	0.03
4	446.22	0.92	0.97	0.08	0.03
5	472.57	0.92	0.97	0.08	0.03
6	468.96	0.94	0.98	0.08	0.03
7	481.36	0.95	0.98	0.07	0.03
8	493.51	0.91	0.96	0.08	0.02
9	469.7	0.91	0.95	0.08	0.03
10	427.97	0.9	0.95	0.08	0.03
11	445.45	0.89	0.93	0.08	0.02
12	473.54	0.9	0.94	0.08	0.02
13	489.29	0.89	0.94	0.08	0.02
14	511.87	0.87	0.93	0.08	0.01
15	598.21	0.86	0.91	0.08	0.02
16	690.33	0.82	0.88	0.08	0.02
17	687.93	0.8	0.85	0.08	0.02
18	658.92	0.76	0.85	0.08	0.02
19	581.46	0.78	0.83	0.08	0.02
20	705.32	0.8	0.86	0.07	0.01
21	862.14	0.81	0.94	0.07	0.05
22	746.25	0.87	0.93	0.08	0.05
23	671.54	0.88	0.95	0.08	0.06
24	659.17	0.88	0.94	0.08	0.07
25	689.22	0.86	0.93	0.08	0.06
26	768.79	0.85	0.93	0.09	0.05
27	784.51	0.89	1.53	0.12	0.08
28	693.66	1.06	1.47	0.18	0.04
29	626.38	0.91	1.08	0.15	0.05
30	677.88	0.86	0.92	0.12	0.04

<b>Average</b>	589.95	0.88	0.97	0.09	0.03
<b>Minimum</b>	427.97	0.76	0.83	0.07	0.01
<b>Maximum</b>	862.14	1.06	1.53	0.18	0.08
<b>Count</b>	30	30	30	30	30
<b>Total</b>	17,698.41				
<b>95 Percentile</b>				0.16	0.07
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	589.84	0.89	0.94	0.08	0.03



July 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	737.63	0.85	0.86	0.1	0.04
2	722.52	0.86	0.87	0.09	0.03
3	641.11	0.84	0.95	0.09	0.04
4	564.26	0.95	1.07	0.08	0.05
5	426.07	0.68	1.04	0.28	0.06
6	390.15	0.8	0.93	0.18	0.08
7	595.38	0.86	0.91	0.21	0.04
8	618.73	0.68	0.92	0.15	0.05
9	558.9	0.77	0.88	0.13	0.1
10	583.09	0.84	0.93	0.12	0.06
11	766.94	0.95	1.02	0.12	0.04
12	805.37	0.92	1.01	0.09	0.03
13	755.73	0.94	0.97	0.08	0.04
14	635.42	0.62	0.93	0.09	0.04
15	522.68	0.84	0.86	0.08	0.05
16	547.57	0.88	0.93	0.09	0.16
17	549.8	0.94	0.96	0.11	0.08
18	572.96	0.95	0.98	0.11	0.1
19	673.01	0.94	0.97	0.11	0.12
20	735.58	0.91	0.94	0.13	0.09
21	757.87	0.91	0.97	0.13	0.03
22	752.79	0.95	1	0.1	0.03
23	713.24	1.01	1.03	0.09	0.03
24	735.07	1.02	1.04	0.07	0.03
25	778.43	1	1.04	0.06	0.02
26	822.65	0.96	1	0.06	0.01
27	888.24	0.95	0.98	0.06	0.08
28	901.6	0.88	0.94	0.1	0.15
29	849.48	0.88	0.93	0.16	0.15
30	833.46	0.91	0.95	0.2	0.14
31	837.67	0.92	0.96	0.2	0.08

<b>Average</b>	686.24	0.88	0.96	0.12	0.07
<b>Minimum</b>	390.15	0.62	0.86	0.06	0.01
<b>Maximum</b>	901.6	1.02	1.07	0.28	0.16
<b>Count</b>	31	31	31	31	31
<b>Total</b>	21,273.40				
<b>95 Percentile</b>				0.24	0.15
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	722.52	0.91	0.96	0.10	0.05

August 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir (Turb Meter Data)	Mann St PS (Turb Meter Data)
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)	Turbidity (Daily Avg) (NTU)
1	843.41	0.93	0.98	0.17	0.07
2	833.99	0.96	0.98	0.14	0.05
3	749.16	0.97	1.01	0.12	0.19
4	705.86	0.99	1.02	0.16	0.22
5	700.88	0.98	1	0.19	0.26
6	752.94	0.97	1.01	0.24	0.29
7	803.89	0.93	0.99	0.27	0.3
8	826.01	0.92	1.3	0.29	0.29
9	822.23	0.98	1.14	0.3	0.29
10	806.93	0.88	0.96	0.31	0.29
11	828.97	0	0.8	0.31	0.28
12	846.47	0.76	0.8	0.31	0.28
13	793.17	0.75	0.78	0.31	0.29
14	839.48	0.77	0.79	0.31	0.29
15	853.81	0.77	0.96	0.31	0.27
16	851.29	0.9	0.95	0.31	0.27
17	889.36	0.91	0.98	0.31	0.27
18	870.57	0.89	0.95	0.31	0.27
19	818.72	0.91	0.94	0.32	0.28
20	818	0.9	0.95	0.33	0.29
21	834.18	0.87	0.91	0.33	0.28
22	855.62	0.89	1.01	0.32	0.27
23	857.24	0.89	0.96	0.32	0.25
24	847.59	0.87	0.92	0.31	0.25
25	863.66	0.85	0.9	0.31	0.26
26	792.6	0.83	0.88	0.32	0.27
27	723.68	0.85	0.96	0.32	0.25
28	762.68	0.96	1.04	0.31	0.26
29	780.17	0.93	1.05	0.31	0.26
30	772.57	0.99	1.08	0.31	0.25
31	796.41	1.04	1.11	0.31	0.26

<b>Average</b>	811.02	0.87	0.97	0.28	0.25
<b>Minimum</b>	700.88	0	0.78	0.12	0.05
<b>Maximum</b>	889.36	1.04	1.3	0.33	0.3
<b>Count</b>	31	31	31	31	31
<b>Total</b>	25,141.54				
<b>95 Percentile</b>				0.33	0.29
<b>Exceedences</b>	0	1	0	0	0
<b>Median</b>	822.23	0.90	0.96	0.31	0.27

September 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	800	1.07	1.18	0.31	0.24
2	764.16	1.12	1.17	0.31	0.23
3	765.28	1.09	1.14	0.3	0.24
4	723.14	1.05	1.11	0.3	0.26
5	658.26	1.06	1.1	0.3	0.27
6	695.86	1.05	1.09	0.31	0.28
7	683.21	0.88	1.07	0.32	0.29
8	690.11	0.85	0.89	0.32	0.27
9	670.93	0.86	0.87	0.32	0.26
10	687.09	0.87	0.88	0.31	0.29
11	726.27	0.84	0.87	0.32	0.29
12	690.5	0.83	0.92	0.32	0.3
13	651.61	0.86	0.88	0.33	0.22
14	681.96	0.86	0.95	0.31	0.28
15	665.21	0.92	0.94	0.31	0.39
16	604.83	0.89	0.92	0.34	0.37
17	610.76	0.87	0.89	0.37	0.36
18	636.83	0.85	0.89	0.37	0.17
19	648.83	0.9	1.02	0.3	0.05
20	628.06	1.01	1.05	0.23	0.04
21	611.34	0.76	1.05	0.17	0.05
22	588.68	0.81	0.83	0.13	0.04
23	528.8	0.84	0.87	0.1	0.04
24	520.74	0.87	0.89	0.08	0.04
25	584	0.89	0.92	0.07	0.04
26	583.01	0.9	0.91	0.06	0.04
27	539.48	0.8	0.91	0.06	0.08
28	545.36	0.8	0.84	0.06	0.09
29	535.43	0.83	0.84	0.06	0.09
30	520.14	0.86	0.86	0.06	0.09
<b>Average</b>	641.33	0.90	0.96	0.24	0.19
<b>Minimum</b>	520.14	0.76	0.83	0.06	0.04
<b>Maximum</b>	800	1.12	1.18	0.37	0.39
<b>Count</b>	30	30	30	30	30
<b>Total</b>	19,239.88				
<b>95 Percentile</b>				0.37	0.38
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	650.22	0.87	0.92	0.31	0.24

October 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	529.33	0.85	0.87	0.06	0.09
2	575.65	0.87	0.88	0.06	0.09
3	561.29	0.86	0.87	0.06	0.09
4	520.93	0.81	0.87	0.06	0.1
5	523.08	0.81	0.83	0.06	0.09
6	509.21	0.83	0.84	0.06	0.1
7	503.54	0.84	0.87	0.06	0.1
8	517.09	0.87	0.89	0.06	0.1
9	543.36	0.89	0.9	0.06	0.11
10	547.51	0	0.91	0.11	0.14
11	520.8	0.91	0.97	0.13	0.12
12	480.47	0.95	0.95	0.12	0.16
13	483.42	0.95	0.95	0.11	0.17
14	462.27	0.94	0.95	0.09	0.19
15	470.16	0.96	0.96	0.09	0.15
16	503.65	0.95	0.96	0.08	0.15
17	501.29	0.97	0.97	0.08	0.16
18	476.85	0.97	1	0.07	0.16
19	465.16	0.99	0.99	0.07	0.16
20	447.02	0.98	0.98	0.06	0.15
21	422.81	0.98	0.98	0.06	0.16
22	414.78	0.99	1.02	0.06	0.17
23	427.72	1.03	1.04	0.06	0.18
24	426.47	1.03	1.04	0.06	0.18
25	406.39	1.06	1.15	0.06	0.19
26	397.81	1.16	1.24	0.06	0.2
27	394.03	1.24	1.35	0.06	0.19
28	386.75	1.35	1.46	0.06	0.24
29	399.05	1.46	1.53	0.07	0.19
30	426.5	1.53	1.58	0.08	0.19
31	416.87	1.32	1.6	0.08	0.16

<b>Average</b>	472.94	0.98	1.05	0.07	0.15
<b>Minimum</b>	386.75	0	0.83	0.06	0.09
<b>Maximum</b>	575.65	1.53	1.6	0.13	0.24
<b>Count</b>	31	31	31	31	31
<b>Total</b>	14,661.26				
<b>95 Percentile</b>				0.12	0.22
<b>Exceedences</b>	0	1	0	0	0
<b>Median</b>	476.85	0.96	0.97	0.06	0.16

November 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir	Mann St PS (Turb
	Flow (Volumetric Rate) (m³/d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	(Turb Meter Data) Turbidity (Daily Avg) (NTU)	Meter Data) Turbidity (Daily Avg) (NTU)
1	395.53	1.28	1.28	0.08	0.14
2	420.27	1.26	1.27	0.09	0.13
3	420.02	1.17	1.17	0.08	0.14
4	413.87	1.15	1.16	0.08	0.14
5	424.7	1.08	1.08	0.08	0.15
6	434.33	1.07	1.07	0.08	0.15
7	421.13	1.04	1.07	0.08	0.17
8	384.32	1.06	1.07	0.09	0.23
9	387.82	1	1.13	0.12	0.27
10	384.05	1	1.05	0.12	0.15
11	380.59	1.02	1.04	0.13	0.15
12	392.29	1.03	1.03	0.14	0.15
13	394.23	1.03	1.05	0.13	0.15
14	400.2	1.04	1.05	0.11	0.15
15	389.33	1.06	1.06	0.1	0.17
16	377.01	1.07	1.07	0.1	0.19
17	371	1.06	1.08	0.09	0.18
18	370.32	1.08	1.1	0.08	0.19
19	388.27	1.09	1.11	0.08	0.19
20	410.21	1.12	1.12	0.08	0.19
21	410.73	1.09	1.12	0.13	0.18
22	382.42	1.08	1.11	0.14	0.19
23	374.46	1.07	1.09	0.14	0.19
24	369.16	1.03	1.09	0.15	0.18
25	364.97	1.04	1.04	0.14	0.18
26	381.25	1.01	1.02	0.14	0.19
27	401.01	0.94	0.94	0.14	0.2
28	402.35	0.88	0.88	0.14	0.19
29	386.2	0.75	0.82	0.14	0.19
30	389.01	0.7	0.7	0.14	0.2
<b>Average</b>	394.04	1.04	1.06	0.11	0.18
<b>Minimum</b>	364.97	0.7	0.7	0.08	0.13
<b>Maximum</b>	434.33	1.28	1.28	0.15	0.27
<b>Count</b>	30	30	30	30	30
<b>Total</b>	11,821.05				
<b>95 Percentile</b>				0.14	0.25
<b>Exceedences</b>	0	0	0	0	0
<b>Median</b>	389.17	1.06	1.07	0.12	0.18

December 2022	Robert St Cl2 (Analyzer Data)			Robert St Reservoir (Turb Meter Data)	Mann St PS (Turb Meter Data)
	Flow (Volumetric Rate) (m <sup>3</sup> /d)	Free Cl2 (Max Day) (mg/L)	Free Cl2 (Min Day) (mg/L)	Turbidity (Daily Avg) (NTU)	Turbidity (Daily Avg) (NTU)
1	388.93	0.65	0.69	0.14	0.2
2	382.74	0.62	0.63	0.14	0.2
3	384.54	0.61	0.61	0.14	0.19
4	391.57	0.58	0.58	0.14	0.2
5	392.98	0.57	0.74	0.14	0.08
6	382.12	0.74	0.74	0.14	0.06
7	379.62	0.72	0.72	0.14	0.09
8	381	0.72	0.72	0.14	0.09
9	399.55	0.74	0.74	0.14	0.08
10	403.42	0.74	0.76	0.14	0.17
11	391.41	0.77	0.78	0.14	0.11
12	388.59	0.72	0.77	0.14	0.09
13	372.44	0.74	0.75	0.14	0.07
14	367.76	0.76	0.77	0.15	0.07
15	370.15	0.78	0.8	0.14	0.07
16	369.6	0.79	0.83	0.15	0.06
17	377.84	0.82	0.85	0.14	0.06
18	390.71	0.86	0.88	0.14	0.07
19	397.52	0.8	0.88	0.14	0.07
20	405.98	0.83	0.85	0.14	0.08
21	410.96	0.86	0.86	0.14	0.08
22	409.81	0.87	0.87	0.14	0.08
23	444.75	0.85	0.85	0.15	0.11
24	545.25	0.72	0.82	0.16	1.19
25	565.5	0.76	0.82	0.17	0.16
26	447.34	0.72	0.72	0.23	0.13
27	419.73	0.69	0.69	0.24	0.13
28	386.44	0.67	0.69	0.24	1.2
29	361.15	0.65	0.67	0.24	0.11
30	373.7	0.65	0.65	0.24	0.11
31	396.03	0.65	0.67	0.23	0.12

<b>Average</b>	402.55	0.73	0.75	0.16	0.18
<b>Minimum</b>	361.15	0.57	0.58	0.14	0.06
<b>Maximum</b>	565.5	0.87	0.88	0.24	1.2
<b>Count</b>	31	31	31	31	31
<b>Total</b>	12,479.13				
<b>95 Percentile</b>				0.24	1.19
<b>Exceedences</b>	0	0	0	0	2
<b>Median</b>	390.71	0.74	0.75	0.14	0.09

\* indicates Geometric Mean  
\*\* indicates Intraday Average

DISINFECTANTS

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 01/05/2022	0.00099 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 01/13/2022	0.00093 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 01/17/2022	0.00089 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 02/03/2022	0.00090 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 02/07/2022	0.00068 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 02/17/2022	0.00071 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 02/23/2022	0.00100 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 03/02/2022	0.00101 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 03/07/2022	0.00090 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 03/23/2022	0.00092 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 03/30/2022	0.00079 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 04/04/2022	0.00075 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
* 04/12/2022	0.00084 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
04/20/2022	0.68 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
04/29/2022	0.44 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
05/02/2022	0.77 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
05/10/2022	0.73 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
05/17/2022	0.65 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
05/30/2022	0.57 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
06/08/2022	0.58 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
06/13/2022	0.68 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
06/22/2022	0.71 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
07/04/2022	0.57 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
07/12/2022	0.48 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
07/19/2022	0.51 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
07/29/2022	0.68 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
07/30/2022	0.69 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
08/03/2022	0.65 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
08/11/2022	0.70 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
08/17/2022	0.47 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
08/23/2022	0.27 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
08/31/2022	0.61 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
09/06/2022	0.55 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
09/13/2022	0.64 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
09/21/2022	0.48 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
10/03/2022	0.58 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
10/14/2022	0.38 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
10/18/2022 0.77 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
10/24/2022 0.76 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
10/31/2022 0.76 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
11/07/2022 0.86 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
11/16/2022 0.73 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
11/23/2022 0.97 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
12/01/2022 0.64 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
12/06/2022 0.41 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined
12/15/2022 0.51 mg/L	Free Cl2	Crofton Auto Service	>=0.05, <=4 User-Defined

<b># samples:</b>	46	<b>min:</b>	0.00068 mg/L
<b># detects:</b>	46	<b>max:</b>	0.97 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.44546 mg/L (based on 46 numerical results)
<b># of Exceedences:</b>	13		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/14/2022 0.00061 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 01/20/2022 0.00064 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 01/28/2022 0.00063 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 02/04/2022 0.00075 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 02/10/2022 0.00085 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 02/24/2022 0.00097 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/02/2022 0.00093 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/18/2022 0.00078 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 03/28/2022 0.00047 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 04/07/2022 0.00074 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
* 04/13/2022 0.00082 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
04/20/2022 0.59 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
05/06/2022 0.77 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined





Free Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
05/11/2022	0.71 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/19/2022	0.56 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/26/2022	0.63 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/08/2022	0.31 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/16/2022	0.63 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/21/2022	0.77 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/07/2022	0.68 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/13/2022	0.52 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/20/2022	0.47 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/26/2022	0.83 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/18/2022	0.60 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/23/2022	0.59 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/08/2022	0.63 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/13/2022	0.69 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/21/2022	0.64 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/05/2022	0.68 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/14/2022	0.73 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/27/2022	0.76 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/03/2022	0.71 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/09/2022	0.83 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/16/2022	0.42 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/24/2022 0.91 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
11/30/2022 0.65 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined
12/16/2022 0.64 mg/L	Free Cl2	Osborne Bay Pump Station	>=0.05, <=4 User-Defined

<b># samples:</b>	37	<b>min:</b>	0.00047 mg/L
<b># detects:</b>	37	<b>max:</b>	0.91 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.45833 mg/L (based on 37 numerical results)
<b># of Exceedences:</b>	11		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/14/2022 0.65 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
01/17/2022 0.62 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
01/27/2022 0.66 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
02/04/2022 0.55 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
02/10/2022 0.86 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
02/14/2022 0.54 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
02/23/2022 0.74 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
02/28/2022 0.70 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
03/08/2022 0.87 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
03/16/2022 0.79 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
03/21/2022 0.58 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
03/29/2022 0.64 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
04/06/2022 0.64 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
04/11/2022 0.65 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
04/19/2022 0.44 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
05/06/2022 0.33 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
05/10/2022 0.50 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
05/16/2022 0.34 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
05/25/2022 0.61 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
06/07/2022 0.59 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
06/13/2022 0.64 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
06/20/2022 0.54 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
07/05/2022 0.64 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
07/11/2022 0.67 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
07/18/2022 0.60 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
07/26/2022 0.39 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined
08/03/2022 0.43 mg/L	Free Cl2	1414 Tatlo	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
08/11/2022	0.57 mg/L	Free Cl2	1414 Tatlo
08/17/2022	0.48 mg/L	Free Cl2	1414 Tatlo
08/23/2022	0.61 mg/L	Free Cl2	1414 Tatlo
08/29/2022	0.58 mg/L	Free Cl2	1414 Tatlo
09/07/2022	0.56 mg/L	Free Cl2	1414 Tatlo
09/13/2022	0.16 mg/L	Free Cl2	1414 Tatlo
09/20/2022	0.37 mg/L	Free Cl2	1414 Tatlo
10/05/2022	0.56 mg/L	Free Cl2	1414 Tatlo
10/14/2022	0.28 mg/L	Free Cl2	1414 Tatlo
10/17/2022	0.38 mg/L	Free Cl2	1414 Tatlo
10/24/2022	0.55 mg/L	Free Cl2	1414 Tatlo
11/07/2022	0.49 mg/L	Free Cl2	1414 Tatlo
11/15/2022	0.52 mg/L	Free Cl2	1414 Tatlo
11/23/2022	0.68 mg/L	Free Cl2	1414 Tatlo
11/29/2022	0.52 mg/L	Free Cl2	1414 Tatlo
12/06/2022	0.55 mg/L	Free Cl2	1414 Tatlo
12/14/2022	0.89 mg/L	Free Cl2	1414 Tatlo

<b># samples:</b>	44	<b>min:</b>	0.16 mg/L
<b># detects:</b>	44	<b>max:</b>	0.89 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.57 mg/L (based on 44 numerical results)
<b># of Exceedences:</b>	0		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
* 01/07/2022	0.00085 mg/L	Free Cl2	Crofton Treatment Plant
* 01/10/2022	0.00081 mg/L	Free Cl2	Crofton Treatment Plant
* 01/17/2022	0.00089 mg/L	Free Cl2	Crofton Treatment Plant
* 02/04/2022	0.00085 mg/L	Free Cl2	Crofton Treatment Plant
* 02/07/2022	0.00094 mg/L	Free Cl2	Crofton Treatment Plant
* 02/17/2022	0.00088 mg/L	Free Cl2	Crofton Treatment Plant
* 02/24/2022	0.00114 mg/L	Free Cl2	Crofton Treatment Plant
* 03/02/2022	0.00094 mg/L	Free Cl2	Crofton Treatment Plant



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 03/15/2022	0.00070 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/23/2022	0.00078 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 03/30/2022	0.00066 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 04/06/2022	0.00075 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
* 04/11/2022	0.00085 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
04/20/2022	0.68 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
04/25/2022	0.46 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/06/2022	0.91 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/09/2022	0.67 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/17/2022	0.53 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/26/2022	0.61 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/30/2022	0.58 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
06/08/2022	0.51 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
06/13/2022	0.85 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
06/20/2022	0.88 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
07/05/2022	0.73 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
07/11/2022	0.57 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
07/18/2022	0.71 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/04/2022	0.97 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/08/2022	1.00 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/17/2022	0.57 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/23/2022	0.69 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/30/2022	0.79 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
09/07/2022	0.92 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
09/12/2022	0.67 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
09/21/2022	0.53 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
09/26/2022	0.59 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
10/04/2022	0.67 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
10/12/2022	0.89 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
10/18/2022	0.38 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
10/26/2022	0.55 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
11/03/2022	1.19 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
11/07/2022	0.91 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
11/15/2022	0.71 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
11/21/2022	1.05 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
11/29/2022 0.84 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
12/06/2022 0.58 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined
12/12/2022 0.59 mg/L	Free Cl2	Crofton Treatment Plant	>=0.05, <=4	User-Defined

<b># samples:</b>	46	<b>min:</b>	0.00066 mg/L
<b># detects:</b>	46	<b>max:</b>	1.19 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.51720 mg/L (based on 46 numerical results)
<b># of Exceedences:</b>	13		

Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria	
* 01/05/2022 0.00085 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 01/13/2022 0.00095 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 01/17/2022 0.00090 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 01/27/2022 0.00079 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 02/04/2022 0.00071 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 02/10/2022 0.00088 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 02/17/2022 0.00056 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 02/23/2022 0.00066 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 03/02/2022 0.00089 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 03/07/2022 0.00081 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 03/16/2022 0.00074 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 03/23/2022 0.00079 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 03/29/2022 0.00083 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 04/04/2022 0.00100 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
* 04/11/2022 0.00072 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
04/20/2022 0.70 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
04/29/2022 0.60 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
05/02/2022 0.73 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
05/11/2022 0.49 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
05/16/2022 0.53 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
05/26/2022 0.64 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
06/08/2022 0.40 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
06/21/2022 0.77 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
07/04/2022 0.60 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
07/11/2022 0.65 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
07/19/2022 0.70 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
07/26/2022 0.94 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
08/04/2022 0.77 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
08/14/2022 0.75 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
08/17/2022 0.27 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined



Free Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
08/23/2022	0.67 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
08/30/2022	0.77 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
09/06/2022	0.60 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
09/12/2022	0.79 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
09/21/2022	0.47 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
10/04/2022	0.70 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
10/12/2022	0.77 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
10/18/2022	0.58 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
10/24/2022	0.68 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
10/31/2022	0.70 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/07/2022	0.76 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/16/2022	0.73 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/24/2022	0.9 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
11/30/2022	0.52 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
12/06/2022	0.45 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
12/13/2022	0.58 mg/L	Free Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined

<b># samples:</b>	46	<b>min:</b>	0.00056 mg/L
<b># detects:</b>	46	<b>max:</b>	0.94 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.43961 mg/L (based on 46 numerical results)
<b># of Exceedences:</b>	15		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/05/2022	1.04 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
01/13/2022	0.98 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
01/17/2022	0.89 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
02/03/2022	0.94 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
02/07/2022	0.75 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
02/17/2022	0.79 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
02/23/2022	0.90 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
03/02/2022	0.89 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
03/07/2022	0.90 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
03/23/2022	0.91 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
03/30/2022	0.60 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
04/04/2022	0.79 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
04/12/2022	0.84 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
04/20/2022	0.69 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
04/29/2022	0.48 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
05/02/2022	0.71 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
05/10/2022	0.76 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
05/17/2022	0.72 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
05/30/2022	0.58 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
06/08/2022	0.60 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
06/13/2022	0.69 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
06/22/2022	0.79 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
07/04/2022	0.62 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
07/12/2022	0.55 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
07/19/2022	0.63 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
07/29/2022	0.75 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
07/30/2022	0.63 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
08/03/2022	0.72 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
08/11/2022	0.84 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
08/17/2022	0.64 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
08/23/2022	0.65 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
08/31/2022	0.54 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
09/06/2022	0.55 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
09/13/2022	0.64 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
09/21/2022	0.50 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
10/03/2022	0.55 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
10/14/2022	0.57 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
10/18/2022	0.75 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
10/24/2022	0.76 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
10/31/2022	0.78 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
11/07/2022	0.98 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
11/16/2022	1.08 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
11/23/2022	1.02 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
12/01/2022	0.74 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
12/06/2022	0.62 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined
12/15/2022	0.61 mg/L	Total Cl2	Crofton Auto Service	>=0.05, <=4	User-Defined

<b># samples:</b>	46	<b>min:</b>	0.48 mg/L
<b># detects:</b>	46	<b>max:</b>	1.08 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.74 mg/L (based on 46 numerical results)
<b># of Exceedences:</b>	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/05/2022	0.91 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
01/13/2022	1.00 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
01/17/2022	0.84 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined
01/27/2022	0.83 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4	User-Defined



<b>Total Cl2(Inline Instrument)</b>	<b>Measurement Name</b>	<b>Sampling Point Name</b>	<b>Criteria</b>	
02/04/2022	0.86 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/10/2022	0.94 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/17/2022	0.60 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
02/23/2022	0.88 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/02/2022	0.96 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/07/2022	0.88 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/16/2022	0.71 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/23/2022	0.82 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
03/29/2022	0.89 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/04/2022	0.78 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/11/2022	0.80 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/20/2022	0.68 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
04/29/2022	0.58 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/02/2022	0.82 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/11/2022	0.53 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/16/2022	0.49 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
05/26/2022	0.74 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
06/08/2022	0.40 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
06/21/2022	0.82 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/04/2022	0.58 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/11/2022	0.69 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/19/2022	0.73 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
07/26/2022	0.84 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/04/2022	0.84 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/14/2022	0.87 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/17/2022	0.53 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/23/2022	0.78 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
08/30/2022	0.87 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/06/2022	0.73 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/12/2022	0.63 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
09/21/2022	0.45 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/04/2022	0.60 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/12/2022	0.76 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/18/2022	0.54 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/24/2022	0.69 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
10/31/2022	0.68 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
11/07/2022	1.11 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
11/16/2022	0.75 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
11/24/2022	0.94 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined





Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
11/30/2022 0.31 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
12/06/2022 0.37 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined
12/13/2022 0.58 mg/L	Total Cl2	Camp Qwanoes	>=0.05, <=4 User-Defined

<b># samples:</b>	46	<b>min:</b>	0.31 mg/L
<b># detects:</b>	46	<b>max:</b>	1.11 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.73 mg/L (based on 46 numerical results)
<b># of Exceedences:</b>	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/07/2022 1.02 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
01/10/2022 1.01 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
01/17/2022 0.91 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
02/04/2022 0.86 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
02/07/2022 0.96 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
02/17/2022 0.98 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
02/24/2022 0.95 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
03/02/2022 1.01 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
03/15/2022 0.72 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
03/23/2022 0.84 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
03/30/2022 0.85 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
04/06/2022 0.71 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
04/11/2022 0.88 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
04/20/2022 0.79 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
04/25/2022 0.49 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/06/2022 0.89 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/09/2022 0.59 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/17/2022 0.52 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/26/2022 0.63 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
05/30/2022 0.71 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
06/08/2022 0.59 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
06/13/2022 0.93 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
06/20/2022 0.89 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
07/05/2022 0.79 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
07/11/2022 0.74 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
07/18/2022 0.83 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/04/2022 0.62 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/08/2022 1.15 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/17/2022 0.60 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined
08/23/2022 0.79 mg/L	Total Cl2	Crofton Treatment Plant	>=0.05, <=4 User-Defined



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
08/30/2022	0.88 mg/L	Total Cl2	Crofton Treatment Plant
09/07/2022	0.91 mg/L	Total Cl2	Crofton Treatment Plant
09/12/2022	0.77 mg/L	Total Cl2	Crofton Treatment Plant
09/21/2022	0.52 mg/L	Total Cl2	Crofton Treatment Plant
09/26/2022	0.49 mg/L	Total Cl2	Crofton Treatment Plant
10/04/2022	0.72 mg/L	Total Cl2	Crofton Treatment Plant
10/12/2022	0.90 mg/L	Total Cl2	Crofton Treatment Plant
10/18/2022	0.29 mg/L	Total Cl2	Crofton Treatment Plant
10/26/2022	0.73 mg/L	Total Cl2	Crofton Treatment Plant
11/03/2022	1.18 mg/L	Total Cl2	Crofton Treatment Plant
11/07/2022	1.02 mg/L	Total Cl2	Crofton Treatment Plant
11/15/2022	0.92 mg/L	Total Cl2	Crofton Treatment Plant
11/21/2022	1.04 mg/L	Total Cl2	Crofton Treatment Plant
11/29/2022	0.80 mg/L	Total Cl2	Crofton Treatment Plant
12/06/2022	0.71 mg/L	Total Cl2	Crofton Treatment Plant
12/12/2022	0.71 mg/L	Total Cl2	Crofton Treatment Plant

# samples:	46	min:	0.29 mg/L
# detects:	46	max:	1.18 mg/L
# non-detects:	0	avg:	0.80 mg/L (based on 46 numerical results)
# of Exceedences:	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria
01/14/2022	0.67 mg/L	Total Cl2	1414 Tatlo
01/17/2022	0.70 mg/L	Total Cl2	1414 Tatlo
01/27/2022	0.66 mg/L	Total Cl2	1414 Tatlo
02/04/2022	0.56 mg/L	Total Cl2	1414 Tatlo
02/10/2022	0.70 mg/L	Total Cl2	1414 Tatlo
02/14/2022	0.51 mg/L	Total Cl2	1414 Tatlo
02/23/2022	0.72 mg/L	Total Cl2	1414 Tatlo
02/28/2022	0.66 mg/L	Total Cl2	1414 Tatlo
03/08/2022	0.85 mg/L	Total Cl2	1414 Tatlo
03/16/2022	0.84 mg/L	Total Cl2	1414 Tatlo
03/21/2022	0.07 mg/L	Total Cl2	1414 Tatlo
03/29/2022	0.70 mg/L	Total Cl2	1414 Tatlo
04/06/2022	0.62 mg/L	Total Cl2	1414 Tatlo
04/11/2022	0.67 mg/L	Total Cl2	1414 Tatlo
04/19/2022	0.50 mg/L	Total Cl2	1414 Tatlo
05/06/2022	0.38 mg/L	Total Cl2	1414 Tatlo
05/10/2022	0.51 mg/L	Total Cl2	1414 Tatlo



Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
05/16/2022	0.44 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
05/25/2022	0.69 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
06/07/2022	0.57 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
06/13/2022	0.66 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
06/20/2022	0.49 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
07/05/2022	0.63 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
07/11/2022	0.59 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
07/18/2022	0.67 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
07/26/2022	0.52 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
08/03/2022	0.56 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
08/11/2022	0.73 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
08/17/2022	0.50 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
08/23/2022	0.68 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
08/29/2022	0.46 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
09/07/2022	0.54 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
09/13/2022	0.51 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
09/20/2022	0.60 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
10/05/2022	0.50 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
10/14/2022	0.56 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
10/17/2022	0.41 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
10/24/2022	0.53 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
11/07/2022	0.56 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
11/15/2022	0.42 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
11/23/2022	0.56 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
11/29/2022	0.41 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
12/06/2022	0.50 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined
12/14/2022	1.03 mg/L	Total Cl2	1414 Tatlo	>=0.05, <=4	User-Defined

<b># samples:</b>	44	<b>min:</b>	0.07 mg/L
<b># detects:</b>	44	<b>max:</b>	1.03 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.58 mg/L (based on 44 numerical results)
<b># of Exceedences:</b>	0		

Total Cl2(Inline Instrument)	Measurement Name	Sampling Point Name	Criteria		
01/14/2022	0.71 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
01/20/2022	0.68 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
01/28/2022	0.74 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
02/04/2022	0.80 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
02/10/2022	0.94 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
02/24/2022	1.03 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/02/2022	0.95 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/18/2022	0.85 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
03/28/2022	0.48 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
04/07/2022	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
04/20/2022	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/06/2022	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/11/2022	0.74 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/19/2022	0.61 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
05/26/2022	0.68 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/08/2022	0.37 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/16/2022	0.59 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
06/21/2022	0.81 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/07/2022	0.70 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/13/2022	0.78 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/20/2022	0.50 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
07/26/2022	0.89 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/18/2022	0.71 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
08/23/2022	0.79 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined



Total Cl2(Inline Instrument)		Measurement Name	Sampling Point Name	Criteria	
09/08/2022	0.66 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/13/2022	0.73 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
09/21/2022	0.42 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/05/2022	0.67 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/14/2022	0.76 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
10/27/2022	0.99 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/03/2022	0.71 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/09/2022	0.81 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/16/2022	0.53 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/24/2022	1.01 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
11/30/2022	0.75 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined
12/16/2022	0.74 mg/L	Total Cl2	Osborne Bay Pump Station	>=0.05, <=4	User-Defined

<b># samples:</b>	36	<b>min:</b>	0.37 mg/L
<b># detects:</b>	36	<b>max:</b>	1.03 mg/L
<b># non-detects:</b>	0	<b>avg:</b>	0.73 mg/L (based on 36 numerical results)
<b># of Exceedences:</b>	0		

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
03/07/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Auto Service	<=0, OG, P User-Defined
04/04/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Auto Service	<=0, OG, P User-Defined
05/02/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Auto Service	<=0, OG, P User-Defined
07/04/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Auto Service	<=0, OG, P User-Defined
08/02/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Auto Service	<=0, OG, P User-Defined

<b># samples:</b>	5	<b>min:</b>	0 CFU/100ml
<b># detects:</b>	5	<b>max:</b>	0 CFU/100ml
<b># non-detects:</b>	0	<b>Geometric Mean:</b>	0 CFU/100ml (based on 5 numerical results)
<b># of Exceedences:</b>	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/17/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined
02/14/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined
03/21/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined
04/19/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined
06/20/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined
07/18/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined
08/15/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	1414 Tatlo	<=0, OG, P User-Defined

<b># samples:</b>	7	<b>min:</b>	0 CFU/100ml
<b># detects:</b>	7	<b>max:</b>	0 CFU/100ml
<b># non-detects:</b>	0	<b>Geometric Mean:</b>	0 CFU/100ml (based on 7 numerical results)
<b># of Exceedences:</b>	0		



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/10/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Treatment Plant	<=0, OG, P User-Defined
02/07/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Treatment Plant	<=0, OG, P User-Defined
03/15/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Treatment Plant	<=0, OG, P User-Defined
04/11/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Treatment Plant	<=0, OG, P User-Defined
07/11/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Treatment Plant	<=0, OG, P User-Defined
08/08/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Treatment Plant	<=0, OG, P User-Defined

<b># samples:</b>	6	<b>min:</b>	0 CFU/100ml
<b># detects:</b>	6	<b>max:</b>	0 CFU/100ml
<b># non-detects:</b>	0	<b>Geometric Mean:</b>	0 CFU/100ml (based on 6 numerical results)
<b># of Exceedences:</b>	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
03/07/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Camp Qwanoes	<=0, OG, P User-Defined
04/04/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Camp Qwanoes	<=0, OG, P User-Defined
05/02/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Camp Qwanoes	<=0, OG, P User-Defined
07/04/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Camp Qwanoes	<=0, OG, P User-Defined
08/02/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Camp Qwanoes	<=0, OG, P User-Defined

<b># samples:</b>	5	<b>min:</b>	0 CFU/100ml
<b># detects:</b>	5	<b>max:</b>	0 CFU/100ml
<b># non-detects:</b>	0	<b>Geometric Mean:</b>	0 CFU/100ml (based on 5 numerical results)
<b># of Exceedences:</b>	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
03/07/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #1	<=0, OG, P User-Defined
04/04/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #1	<=0, OG, P User-Defined



Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
05/02/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #1	<=0, OG, P User-Defined
07/04/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #1	<=0, OG, P User-Defined
08/02/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #1	<=0, OG, P User-Defined

<b># samples:</b>	5	<b>min:</b>	0 CFU/100ml
<b># detects:</b>	5	<b>max:</b>	0 CFU/100ml
<b># non-detects:</b>	0	<b>Geometric Mean:</b>	0 CFU/100ml (based on 5 numerical results)
<b># of Exceedences:</b>	0		

Escherichia coli / E. coli (Count)(Laboratory Report)	Measurement Name	Sampling Point Name	Criteria
01/17/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined
02/14/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined
03/21/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined
04/19/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined
06/20/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined
07/18/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined
08/15/2022 0 CFU/100ml	Escherichia coli / E. coli (Count)	Crofton Reservoir #2	<=0, OG, P User-Defined

<b># samples:</b>	7	<b>min:</b>	0 CFU/100ml
<b># detects:</b>	7	<b>max:</b>	0 CFU/100ml
<b># non-detects:</b>	0	<b>Geometric Mean:</b>	0 CFU/100ml (based on 7 numerical results)
<b># of Exceedences:</b>	0		

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded





1,1,1-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	1,1,1-Trichloroethane	Robert St Pump Station	<=0.2 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2,2-Tetrachloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.5 ug/L	1,1,2,2-Tetrachloroethane	Robert St Pump Station	

# samples:	1	min:	< 0.5 ug/L
# detects:	0	max:	< 0.5 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2-Trichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	1,1,2-Trichloroethane	Robert St Pump Station	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1-Dichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 1.0 ug/L	1,1-Dichloroethane	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1-Dichloroethylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	1,1-Dichloroethylene	Robert St Pump Station	<=0.007 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

# of Exceedences: 0

1,2-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0005 mg/L	1,2-Dichlorobenzene	Robert St Pump Station	<=0.6 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichloroethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	1,2-Dichloroethane	Robert St Pump Station	<=0.003 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichloropropane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	1,2-Dichloropropane	Robert St Pump Station	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 1.0 ug/L	1,3-Dichlorobenzene	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,3-Dichloropropene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 1.0 ug/L	1,3-Dichloropropene	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,4-Dichlorobenzene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	1,4-Dichlorobenzene	Robert St Pump Station	<=0.075 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	1-Methylnaphthalene	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.00050 mg/L	2,3,4,6-Tetrachlorop henol	Robert St Pump Station	<=0.001 AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	2,3,4-Trichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

# of Exceedences: 0

2,3,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	2,3,5-Trichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,6-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	2,3,6-Trichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.20 ug/L	2,3-Dichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.20 ug/L	2,4 + 2,5-Dichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	2,4,5-Trichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

**2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)**

Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.10 ug/L	2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T	Robert St Pump Station
<b># samples:</b>	1	<b>min:</b> < 0.10 ug/L
<b># detects:</b>	0	<b>max:</b> < 0.10 ug/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**2,4,6-Trichlorophenol(Lab Data Transfer)**

Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.00050 mg/L	2,4,6-Trichlorophenol	Robert St Pump Station <=0.002
<b># samples:</b>	1	<b>min:</b> < 0.00050 mg/L
<b># detects:</b>	0	<b>max:</b> < 0.00050 mg/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)**

Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.00010 mg/L	2,4-Dichlorophenoxyacetic acid / 2,4-D	Robert St Pump Station <=0.07 MCL
<b># samples:</b>	1	<b>min:</b> < 0.00010 mg/L
<b># detects:</b>	0	<b>max:</b> < 0.00010 mg/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**2,6-Dichlorophenol(Lab Data Transfer)**

Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.20 ug/L	2,6-Dichlorophenol	Robert St Pump Station
<b># samples:</b>	1	<b>min:</b> < 0.20 ug/L
<b># detects:</b>	0	<b>max:</b> < 0.20 ug/L
<b># non-detects:</b>	1	<b>avg:</b> n/a (based on 0 numerical results)
<b># of Exceedences:</b>	0	

**2-Chloronaphthalene(Lab Data Transfer)**

Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	2-Chloronaphthalene	Robert St Pump Station
<b># samples:</b>	1	<b>min:</b> < 0.100 ug/L
<b># detects:</b>	0	<b>max:</b> < 0.100 ug/L



# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.10 ug/L	2-Chlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.02 ug/L	2-methyl-4-chlorophe noxyacetic acid / MCPA	Robert St Pump Station	

# samples:	1	min:	< 0.02 ug/L
# detects:	0	max:	< 0.02 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Methylnaphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	2-Methylnaphthalene	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.10 ug/L	3 and 4-Chlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	3,4,5-Trichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.20 ug/L	3,4-Dichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,5-Dichlorophenol(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.20 ug/L	3,5-Dichlorophenol	Robert St Pump Station	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.50 ug/L	4-Chloro-3-methylphenol (Parachlorometacresol)	Robert St Pump Station	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acenaphthene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	Acenaphthene	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acenaphthylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.200 ug/L	Acenaphthylene	Robert St Pump Station	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Acridine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Acridine	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000100 mg/L	Alachlor	Robert St Pump Station	<=0.002 MCL

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aldrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.006 ug/L	Aldrin	Robert St Pump Station	

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.010 ug/L	alpha-BHC	Robert St Pump Station	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aluminum (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	0.0087 mg/L	Aluminum (total)	Robert St Pump Station	<=0.2 Secondary Standard





# samples:	1	min:	0.0087 mg/L
# detects:	1	max:	0.0087 mg/L
# non-detects:	0	avg:	0.0087 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.010 ug/L	Anthracene	Robert St Pump Station	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.00020 mg/L	Antimony (total)	Robert St Pump Station	<=0.006 MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1016(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	Aroclor 1016	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	Aroclor 1221	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	Aroclor 1232	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Aroclor 1242	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Aroclor 1248	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Aroclor 1254	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Aroclor 1260	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1262(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Aroclor 1262	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1268(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Aroclor 1268	Robert St Pump Station	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Arsenic (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.00050 mg/L	Arsenic (total)	Robert St Pump Station	<=0.010 MCL
# samples:	1	min:	< 0.00050 mg/L	
# detects:	0	max:	< 0.00050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Atrazine + N-dealkylated metabolites(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000100 mg/L	Atrazine + N-dealkylated metabolites	Robert St Pump Station	<=0.005 MAC
# samples:	1	min:	< 0.000100 mg/L	
# detects:	0	max:	< 0.000100 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Azinphos-methyl(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000200 mg/L	Azinphos-methyl	Robert St Pump Station	<=0.02 MAC
# samples:	1	min:	< 0.000200 mg/L	
# detects:	0	max:	< 0.000200 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Barium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.0050 mg/L	Barium (total)	Robert St Pump Station	<=2 MCL
# samples:	1	min:	< 0.0050 mg/L	
# detects:	0	max:	< 0.0050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			



Benzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0005 mg/L	Benzene	Robert St Pump Station	<=0.001 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0005 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0005 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Benzo(a)anthracene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.010 ug/L	Benzo(a)anthracene	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Benzo(a)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000010 mg/L	Benzo(a)pyrene	Robert St Pump Station	<=0.0002 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Benzo(b,j)fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Benzo(b,j)fluoranthene	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Benzo(g,h,i)perylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Benzo(g,h,i)perylene	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			



Benzo(k)fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Benzo(k)fluoranthene	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.00010 mg/L	Beryllium (total)	Robert St Pump Station	<=0.004 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

beta-BHC(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	beta-BHC	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.10 ug/L	Bismuth (total)	Robert St Pump Station	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.0500 mg/L	Boron (total)	Robert St Pump Station	<=5 MAC

# samples:	1	min:	< 0.0500 mg/L
# detects:	0	max:	< 0.0500 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromacil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.100 ug/L	Bromacil	Robert St Pump Station	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Bromate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.01 mg/L	Bromate	Robert St Pump Station	<=0.01 MAC
# samples:	1	min:	< 0.01 mg/L	
# detects:	0	max:	< 0.01 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0010 mg/L	Bromodichloromethane (dichlorobromomethane)	Robert St Pump Station	<=0.016 MAC
# samples:	1	min:	< 0.0010 mg/L	
# detects:	0	max:	< 0.0010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Bromoform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 1.0 ug/L	Bromoform	Robert St Pump Station	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Bromoxynil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000200 mg/L	Bromoxynil	Robert St Pump Station	<=0.005 MAC
# samples:	1	min:	< 0.000200 mg/L	
# detects:	0	max:	< 0.000200 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



# of Exceedences: 0

Butachlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.020 ug/L	Butachlor	Robert St Pump Station	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.000010 mg/L	Cadmium (total)	Robert St Pump Station	<=0.005 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 7,260 ug/L	Calcium (total)	Robert St Pump Station	

# samples:	1	min:	7,260 ug/L
# detects:	1	max:	7,260 ug/L
# non-detects:	0	avg:	7,260 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	Captan	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Carbon tetrachloride(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0005 mg/L	Carbon tetrachloride	Robert St Pump Station	<=0.003 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorobenzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0010 mg/L	Chlorobenzene	Robert St Pump Station	<=0.1 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloroethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 2.0 ug/L	Chloroethane	Robert St Pump Station	

# samples:	1	min:	< 2.0 ug/L
# detects:	0	max:	< 2.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chloroform(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	2.0 ug/L	Chloroform	Robert St Pump Station	

# samples:	1	min:	2.0 ug/L
# detects:	1	max:	2.0 ug/L
# non-detects:	0	avg:	2.0 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Chlorothalonil(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Chlorothalonil	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlorpyrifos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000010 mg/L	Chlorpyrifos	Robert St Pump Station	<=0.09 MAC

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.00050 mg/L	Chromium (total)	Robert St Pump Station	<=0.1 MCL





# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chrysene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	Chrysene	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

cis-1,2-Dichloroethylene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0010 mg/L	cis-1,2-Dichloroethylene	Robert St Pump Station	<=0.07 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.10 ug/L	Cobalt (total)	Robert St Pump Station	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 0.00325 mg/L	Copper (total)	Robert St Pump Station	<=1 Secondary Standard

# samples:	1	min:	0.00325 mg/L
# detects:	1	max:	0.00325 mg/L
# non-detects:	0	avg:	0.00325 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	Cyanazine	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
------------	---	------	--------------

# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.0020 mg/L	Cyanide (total)	Robert St Pump Station	<=0.2 MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.010 ug/L	DDT + metabolites	Robert St Pump Station	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

delta-BHC(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	delta-BHC	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Deltamethrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	Deltamethrin	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diazinon(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000020 mg/L	Diazinon	Robert St Pump Station	<=0.02 MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dibenzo(a,h)anthracene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.010 ug/L	Dibenzo(a,h)anthracene	Robert St Pump Station	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 1.0 ug/L	Dibromochloromethane (Chlorodibromomethane)	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dibromomethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 1.0 ug/L	Dibromomethane	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dicamba(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.00010 mg/L	Dicamba	Robert St Pump Station	<=0.12 MAC

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichloromethane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.0030 mg/L	Dichloromethane	Robert St Pump Station	<=0.005 MCL

# samples:	1	min:	< 0.0030 mg/L
# detects:	0	max:	< 0.0030 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichlorvos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.100 ug/L	Dichlorvos	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diclofop-methyl(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000100 mg/L	Diclofop-methyl	Robert St Pump Station	<=0.009 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.010 ug/L	Dieldrin	Robert St Pump Station	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000200 mg/L	Dimethoate	Robert St Pump Station	<=0.02 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dinoseb(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.00010 mg/L	Dinoseb	Robert St Pump Station	<=0.007 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L

# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Diquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.0100 mg/L	Diquat	Robert St Pump Station	<=0.02 MCL

# samples: 1 min: < 0.0100 mg/L  
# detects: 0 max: < 0.0100 mg/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Disulfoton(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.100 ug/L	Disulfoton	Robert St Pump Station	

# samples: 1 min: < 0.100 ug/L  
# detects: 0 max: < 0.100 ug/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Diuron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000200 mg/L	Diuron	Robert St Pump Station	<=0.15 MAC

# samples: 1 min: < 0.000200 mg/L  
# detects: 0 max: < 0.000200 mg/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Endosulfan (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.010 ug/L	Endosulfan (total)	Robert St Pump Station	

# samples: 1 min: < 0.010 ug/L  
# detects: 0 max: < 0.010 ug/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Endosulfan sulfate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Endosulfan sulfate	Robert St Pump Station	

# samples: 1 min: < 0.050 ug/L  
# detects: 0 max: < 0.050 ug/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Endrin aldehyde(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.020 ug/L	Endrin aldehyde	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.020 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.020 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Endrin ketone(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.020 ug/L	Endrin ketone	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.020 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.020 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Endrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000020 mg/L	Endrin	Robert St Pump Station	<=0.002 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Ethylbenzene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0010 mg/L	Ethylbenzene	Robert St Pump Station	<=0.7 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Ethylene dibromide / EDB(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0003 mg/L	Ethylene dibromide / EDB	Robert St Pump Station	<=0.00002 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0003 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0003 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			



Fenchlorphos(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.100 ug/L	Fenchlorphos	Robert St Pump Station	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluoranthene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.030 ug/L	Fluoranthene	Robert St Pump Station	
# samples:	1	min:	< 0.030 ug/L	
# detects:	0	max:	< 0.030 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluorene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Fluorene	Robert St Pump Station	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Fluoride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.1 mg/L	Fluoride	Robert St Pump Station	<=4.0 MCL
# samples:	1	min:	< 0.1 mg/L	
# detects:	0	max:	< 0.1 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Glyphosate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.05 mg/L	Glyphosate	Robert St Pump Station	<=0.7 MCL
# samples:	1	min:	< 0.05 mg/L	
# detects:	0	max:	< 0.05 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			



Hardness (total, as CaCO3)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	21.2 mg/L	Hardness (total, as CaCO3)	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	21.2 mg/L	
<b># detects:</b>	1	<b>max:</b>	21.2 mg/L	
<b># non-detects:</b>	0	<b>avg:</b>	21.2 mg/L (based on 1 numerical results)	
<b># of Exceedences:</b>	0			

Heptachlor epoxide(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000010 mg/L	Heptachlor epoxide	Robert St Pump Station	<=0.0002 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Heptachlor(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000010 mg/L	Heptachlor	Robert St Pump Station	<=0.0004 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.000010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Indeno(1,2,3-c,d)pyrene	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.050 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.050 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Iron(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	0.019 mg/L	Iron	Robert St Pump Station	<=0.3 Secondary Standard
<b># samples:</b>	1	<b>min:</b>	0.019 mg/L	
<b># detects:</b>	1	<b>max:</b>	0.019 mg/L	
<b># non-detects:</b>	0	<b>avg:</b>	0.019 mg/L (based on 1 numerical results)	
<b># of Exceedences:</b>	0			



Lead (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.00020 mg/L	Lead (total)	Robert St Pump Station	<=0.015 MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000050 mg/L	Lindane	Robert St Pump Station	<=0.0002 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Linuron(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.050 ug/L	Linuron	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lithium (dissolved)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.10 ug/L	Lithium (dissolved)	Robert St Pump Station	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 744 ug/L	Magnesium (total)	Robert St Pump Station	

# samples:	1	min:	744 ug/L
# detects:	1	max:	744 ug/L
# non-detects:	0	avg:	744 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000100 mg/L	Malathion	Robert St Pump Station	<=0.19 MAC



# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Manganese (total)	Robert St Pump Station	<=0.05 Secondary Standard

# samples:	1	min:	0.00079 mg/L
# detects:	1	max:	0.00079 mg/L
# non-detects:	0	avg:	0.00079 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Mercury (total)	Robert St Pump Station	<=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methoxychlor	Robert St Pump Station	<=0.04 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methyl parathion	Robert St Pump Station	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Measurement Name	Sampling Point Name	Criteria
Methyl tert-butyl ether / MTBE	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
------------	---	------	------------

# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000100 mg/L	Metolachlor	Robert St Pump Station	<=0.05 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000200 mg/L	Metribuzin	Robert St Pump Station	<=0.08 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.10 ug/L	Molybdenum (total)	Robert St Pump Station	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.200 ug/L	Naphthalene	Robert St Pump Station	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 0.00040 mg/L	Nickel (total)	Robert St Pump Station	<=0.1 MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

# of Exceedences: 0

Nitrate (as N)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	0.067 mg/L	Nitrate (as N)	Robert St Pump Station	<=10	MCL

# samples:	1	min:	0.067 mg/L
# detects:	1	max:	0.067 mg/L
# non-detects:	0	avg:	0.067 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	< 0.2 mg/L	Nitrilotriacetic acid / NTA	Robert St Pump Station	<=0.4	MAC

# samples:	1	min:	< 0.2 mg/L
# detects:	0	max:	< 0.2 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	< 0.0050 mg/L	Paraquat	Robert St Pump Station	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/20/2022 08:30	< 0.100 ug/L	Parathion	Robert St Pump Station		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pentachloronitrobenzene / PCNB(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.100 ug/L	Pentachloronitrobenzene / PCNB	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Pentachlorophenol / PCP(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
--	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.00050 mg/L	Pentachlorophenol / PCP	Robert St Pump Station	<=0.001 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.00050 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.00050 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Permethrin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
-------------------------------	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.010 ug/L	Permethrin	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.010 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.010 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Phenanthrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---------------------------------	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.100 ug/L	Phenanthrene	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Phorate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
----------------------------	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.000100 mg/L	Phorate	Robert St Pump Station	<=0.002 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.000100 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000100 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			



Picloram(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.00010 mg/L	Picloram	Robert St Pump Station	<=0.5 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
---	------------------	---------------------	----------

07/20/2022 08:30 < 0.150 ug/L	Polychlorinated Biphenyls / PCBs (as arochlor total)	Robert St Pump Station	
-------------------------------	--	------------------------	--

# samples:	1	min:	< 0.150 ug/L
# detects:	0	max:	< 0.150 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
--------------------------------------	------------------	---------------------	----------

02/07/2022 13:15 180 ug/L	Potassium (total)	Robert St Pump Station	
---------------------------	-------------------	------------------------	--

# samples:	1	min:	180 ug/L
# detects:	1	max:	180 ug/L
# non-detects:	0	avg:	180 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Prometon(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
-----------------------------	------------------	---------------------	----------

07/20/2022 08:30 < 0.300 ug/L	Prometon	Robert St Pump Station	
-------------------------------	----------	------------------------	--

# samples:	1	min:	< 0.300 ug/L
# detects:	0	max:	< 0.300 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometryn(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
------------------------------	------------------	---------------------	----------

07/20/2022 08:30 < 0.100 ug/L	Prometryn	Robert St Pump Station	
-------------------------------	-----------	------------------------	--

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		



Pyrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.020 ug/L	Pyrene	Robert St Pump Station	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Quinoline(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.050 ug/L	Quinoline	Robert St Pump Station	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.00050 mg/L	Selenium (total)	Robert St Pump Station	<=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	2,300 ug/L	Silicon (total, as Si)	Robert St Pump Station	

# samples:	1	min:	2,300 ug/L
# detects:	1	max:	2,300 ug/L
# non-detects:	0	avg:	2,300 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.000050 mg/L	Silver (total)	Robert St Pump Station	<=0.1 Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Simazine(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000200 mg/L	Simazine	Robert St Pump Station	<=0.004 MCL



# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	2.14 mg/L	Sodium (total)	Robert St Pump Station	<=160	MCL

# samples:	1	min:	2.14 mg/L
# detects:	1	max:	2.14 mg/L
# non-detects:	0	avg:	2.14 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	21.8 ug/L	Strontium (total)	Robert St Pump Station		

# samples:	1	min:	21.8 ug/L
# detects:	1	max:	21.8 ug/L
# non-detects:	0	avg:	21.8 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Styrene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/20/2022 08:30	< 0.0010 mg/L	Styrene	Robert St Pump Station	<=0.1	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/20/2022 08:30	< 0.100 ug/L	Sulfotep	Robert St Pump Station		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	< 3,000 ug/L	Sulfur (total)	Robert St Pump Station		

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L



# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Sulphate(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 1.7 mg/L	Sulphate	Robert St Pump Station	<=250 Secondary Standard

# samples: 1 min: 1.7 mg/L  
# detects: 1 max: 1.7 mg/L  
# non-detects: 0 avg: 1.7 mg/L (based on 1 numerical results)  
# of Exceedences: 0

Sulphide (total, as S)(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15 < 20 ug/L	Sulphide (total, as S)	Robert St Pump Station	

# samples: 1 min: < 20 ug/L  
# detects: 0 max: < 20 ug/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Tebuthiuron(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.200 ug/L	Tebuthiuron	Robert St Pump Station	

# samples: 1 min: < 0.200 ug/L  
# detects: 0 max: < 0.200 ug/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Temephos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.500 ug/L	Temephos	Robert St Pump Station	

# samples: 1 min: < 0.500 ug/L  
# detects: 0 max: < 0.500 ug/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Terbufos(Lab Data Transfer)	Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30 < 0.000100 mg/L	Terbufos	Robert St Pump Station	<=0.001 MAC

# samples: 1 min: < 0.000100 mg/L  
# detects: 0 max: < 0.000100 mg/L  
# non-detects: 1 avg: n/a (based on 0 numerical results)  
# of Exceedences: 0

Tetrachloroethylene / PCE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0010 mg/L	Tetrachloroethylene / PCE	Robert St Pump Station	<=0.003 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Thallium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.000020 mg/L	Thallium (total)	Robert St Pump Station	<=0.002 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.000020 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000020 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Tin (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.20 ug/L	Tin (total)	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.20 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.20 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Titanium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 5.0 ug/L	Titanium (total)	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 5.0 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 5.0 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Toluene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0010 mg/L	Toluene	Robert St Pump Station	<=1 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Total Chloramines (as combined chlorine)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---	--	------------------	---------------------	----------

02/07/2022 13:15	< 0.0400 mg/L	Total Chloramines (as combined chlorine)	Robert St Pump Station	<=3.0 MAC
<b># samples:</b>	1	<b>min:</b>	< 0.0400 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0400 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Total Chlordane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
------------------------------------	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.000050 mg/L	Total Chlordane	Robert St Pump Station	<=0.002 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.000050 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.000050 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

trans-1,2-Dichloroethylene(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
---	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.0010 mg/L	trans-1,2-Dichloroethylene	Robert St Pump Station	<=0.1 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Triallate(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
------------------------------	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.100 ug/L	Triallate	Robert St Pump Station	
<b># samples:</b>	1	<b>min:</b>	< 0.100 ug/L	
<b># detects:</b>	0	<b>max:</b>	< 0.100 ug/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	
<b># of Exceedences:</b>	0			

Trichloroethylene / TCE(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
--	--	------------------	---------------------	----------

07/20/2022 08:30	< 0.0010 mg/L	Trichloroethylene / TCE	Robert St Pump Station	<=0.003 MCL
<b># samples:</b>	1	<b>min:</b>	< 0.0010 mg/L	
<b># detects:</b>	0	<b>max:</b>	< 0.0010 mg/L	
<b># non-detects:</b>	1	<b>avg:</b>	n/a (based on 0 numerical results)	

# of Exceedences: 0

Trichlorofluoromethane(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 1.0 ug/L	Trichlorofluoromethane	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Trifluralin(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.000200 mg/L	Trifluralin	Robert St Pump Station	<=0.045 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Uranium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 0.000020 mg/L	Uranium (total)	Robert St Pump Station	<=0.02 MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
02/07/2022 13:15	< 1.0 ug/L	Vanadium (total)	Robert St Pump Station	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vinyl chloride(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria
07/20/2022 08:30	< 0.0010 mg/L	Vinyl chloride	Robert St Pump Station	<=0.001 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Xylenes (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
07/20/2022 08:30	< 0.0020 mg/L	Xylenes (total)	Robert St Pump Station	<=10	MCL

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	0.0042 mg/L	Zinc (total)	Robert St Pump Station	<=5	Secondary Standard

# samples:	1	min:	0.0042 mg/L
# detects:	1	max:	0.0042 mg/L
# non-detects:	0	avg:	0.0042 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)		Measurement Name	Sampling Point Name	Criteria	
02/07/2022 13:15	< 0.10 ug/L	Zirconium (total)	Robert St Pump Station		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded

