

October 15, 2020

File: 5630-55

Environmental Health Officer
Central Vancouver Island Health Region
1665 Grant Avenue
NANAIMO BC V9S 5K7

**Re: South End Water System Water Quality Report
Premises Number 1310818
Report for the Period Jan 1/19 to Dec 31/19**

Please find the Municipality of North Cowichan's Water quality report for the South-end Water System attached.

Sincerely

Clay Reitsma, M. Eng., P. Eng
Senior Manager, Engineering

clay.reitsma@northcowichan.ca



1 Operator Information

Contact Name Clay Reitsma, M.Eng. , P.Eng.
Phone 250-746-3100
Email clay.reitsma@northcowichan.ca

2 System Description

This is a groundwater supply. Water is pumped from the Boys Road wells. In 2018, Vancouver Island Health Authority amended the operating certificate for the South End Water System and the Municipality is now required to Chlorinate continuously to reduce bacterial growth in the distribution system. In December of 2019 a new sodium hypochlorite injection system was installed to replace the existing calcium hypochlorite system.

3 Boil Advisories

None.

4 Future Improvements

A UV disinfection system has been installed and has been operating since June of 2013.

5 Additional Comments

Should you have any questions regarding this report, please do not hesitate to contact the Municipality at (250) 746-3100.

Sincerely



Clay Reitsma, M.Eng., P.Eng.
Senior Manager, Engineering
cc: Robert Bell – Utilities, Manager

6 Results

See results below. ***Note* The reading on August 19, 2019 at 1820 Herd Rd of 880 (counts) of total coliforms was a result of a contaminated sampling location. The sample was retested and the original test was determined to erroneous.**

Report Name: South End Water Quality Report

Report Subtitle: South End Water Quality Report

	3908 Cowichan Lake Rd	Bell McKinnon Reservoir	Maple Bay Marina	Maple Mtn Reservoir	Boys Rd - Well 1	Boys Rd - Well 3	Boys Rd - Well 5	Boys Rd PS
January 2019	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Free Cl2 (mg/L)	Turbidity (NTU)	Turbidity (NTU)	Turbidity (NTU)	Flow (Volumetric Rate) (m³/d)
1								3,974
2	0.18	0.27	0.23	0.18	0.08			4,584
3								5,365
4								4,950
5								4,327
6								4,037
7	0.19	0.22	0.22	0.19				5,417
8								4,466
9								4,011
10								4,508
11								4,274
12								4,276
13								4,392
14		0.21	0.28	0.20		0.090		4,328
15	0.20							4,032
16								4,442
17								3,967
18								4,290
19								4,590
20								4,351
21			0.25	0.17			0.09	4,074
22	0.19	0.18						4,249
23								4,089
24								4,285
25								4,485
26								4,370
27								4,536
28	0.23	0.23	0.27	0.16				4,874
29								4,094
30								4,595
31								4,799
Average	0.20	0.22	0.25	0.18	0.08	0.090	0.09	4,420
Minimum	0.18	0.18	0.22	0.16	0.08	0.090	0.09	3,967
Maximum	0.23	0.27	0.28	0.20	0.08	0.090	0.09	5,417
Count	5	5	5	5	1	1	1	31
Total								137,031
95 Percentile					0.08	0.090	0.09	
Exceedences	0	0	0	0	0	0	0	0
Median	0.19	0.22	0.25	0.18	0.08	0.090	0.09	4,351

February 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								4,090
2								4,820
3								4,442
4								4,486
5	0.19	0.19	0.23	0.17	0.09			4,260
6								4,883
7								4,427
8								4,167
9								5,057
10								5,358
11								4,676
12								4,835
13								5,033
14								4,429
15								4,172
16								4,508
17								4,474
18								4,473
19				0.18		0.08		4,559
20	0.18	0.18	0.22					4,549
21								4,160
22								4,711
23								4,363
24								4,262
25			0.43	0.18			0.06	4,493
26								4,171
27								4,857
28		0.19						4,058

Average	0.19	0.19	0.29	0.18	0.09	0.08	0.06	4,528
Minimum	0.18	0.18	0.22	0.17	0.09	0.08	0.06	4,058
Maximum	0.19	0.19	0.43	0.18	0.09	0.08	0.06	5,358
Count	2	3	3	3	1	1	1	28
Total								126,773
95 Percentile					0.09	0.08	0.06	
Exceedences	0	0	0	0	0	0	0	0
Median	0.19	0.19	0.23	0.18	0.09	0.08	0.06	4,480

March 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1	0.19							4,553
2								4,649
3								5,017
4	0.20	0.18	0.39					4,420
5								4,565
6								4,646
7					0.08			4,240
8				0.16				4,121
9								4,776
10								4,490
11								4,235
12		0.19	0.36	0.17				4,371
13	0.21							4,370
14								4,321
15								4,481
16								4,655
17								4,665
18								4,693
19								4,574
20								4,548
21								4,803
22			0.32	0.18				4,257
23	0.18	0.16				0.07		4,560
24								4,563
25	0.25							4,947
26		0.28	0.29	0.22			0.101	4,130
27								4,747
28								4,853
29								4,621
30								5,270
31								4,754

Average	0.21	0.20	0.34	0.18	0.08	0.07	0.101	4,577
Minimum	0.18	0.16	0.29	0.16	0.08	0.07	0.101	4,121
Maximum	0.25	0.28	0.39	0.22	0.08	0.07	0.101	5,270
Count	5	4	4	4	1	1	1	31
Total								141,895
95 Percentile					0.08	0.07	0.101	
Exceedences	0	0	0	0	0	0	0	0
Median	0.20	0.19	0.34	0.18	0.08	0.07	0.101	4,565

April 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1	0.24	0.20	0.32	0.12	0.056			5,384
2								4,676
3								5,221
4								4,645
5								4,459
6								4,376
7								4,742
8								4,631
9	0.20							4,631
10		0.22	0.12	0.15				4,631
11								4,631
12								4,521
13								4,394
14								5,205
15	0.20	0.23	0.24	0.12		0.13		4,688
16								4,863
17								4,566
18								4,724
19								4,606
20								5,325
21								5,101
22								4,827
23			0.24	0.17			0.05	4,960
24								5,467
25								4,902
26								5,760
27								5,021
28								6,811
29								5,802
30	0.21	0.14	0.25	0.15				7,107

Average	0.21	0.20	0.23	0.14	0.056	0.13	0.05	5,023
Minimum	0.20	0.14	0.12	0.12	0.056	0.13	0.05	4,376
Maximum	0.24	0.23	0.32	0.17	0.056	0.13	0.05	7,107
Count	4	4	5	5	1	1	1	30
Total								150,677
95 Percentile Exceedences	0	0	0	0	0.056	0.13	0.05	0
Median	0.21	0.21	0.24	0.15	0.056	0.13	0.05	4,785

May 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								6,694
2								6,867
3								7,226
4								7,342
5								8,619
6	0.14	0.22	0.25	0.15	0.05			8,307
7								8,945
8								9,761
9								10,541
10								10,477
11								10,520
12								10,265
13								9,535
14			0.19	0.12				7,150
15		0.14						8,141
16								7,893
17	0.15							7,313
18								8,151
19								9,145
20		0.11	0.18	0.17				8,439
21								8,100
22	0.11					0.05		9,289
23								10,608
24								8,990
25								7,251
26								8,609
27			0.17	0.14			0.06	10,018
28	0.11	0.10						9,683
29								10,703
30								11,106
31								10,013

Average	0.13	0.14	0.20	0.15	0.05	0.05	0.06	8,894
Minimum	0.11	0.10	0.17	0.12	0.05	0.05	0.06	6,694
Maximum	0.15	0.22	0.25	0.17	0.05	0.05	0.06	11,106
Count	4	4	4	4	1	1	1	31
Total								275,701
95 Percentile					0.05	0.05	0.06	
Exceedences	0	0	0	0	0	0	0	0
Median	0.13	0.13	0.19	0.15	0.05	0.05	0.06	8,945

June 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								11,557
2								10,961
3		0.16						10,721
4	0.32		0.24	0.15				10,690
5								10,138
6								9,836
7								9,565
8								9,944
9								10,278
10								11,760
11	0.14	0.24	0.27	0.15				12,115
12								12,569
13								12,103
14								10,797
15								11,415
16								12,916
17						0.05		11,975
18	0.20	0.19	0.19	0.22				11,482
19								11,046
20								9,459
21								10,128
22								11,149
23								11,149
24	0.20	0.30	0.34	0.27			0.05	10,999
25								10,336
26								10,504
27								12,464
28								8,915
29								7,853
30								8,503

Average	0.22	0.22	0.26	0.20		0.05	0.05	10,778
Minimum	0.14	0.16	0.19	0.15		0.05	0.05	7,853
Maximum	0.32	0.30	0.34	0.27		0.05	0.05	12,916
Count	4	4	4	4	0	1	1	30
Total								323,327
95 Percentile Exceedences	0	0	0	0	0	0.05	0.05	0
Median	0.20	0.22	0.26	0.19		0.05	0.05	10,879

July 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								10,063
2		0.30						10,500
3	0.22		0.39	0.36				8,867
4								8,897
5								10,240
6								9,608
7								10,196
8			0.53	0.32				8,791
9	0.22	0.33						9,105
10								8,534
11								7,962
12								8,154
13								7,999
14								8,818
15								9,681
16	0.20	0.26	0.32	0.36		0.048		10,205
17								8,956
18								9,297
19								9,838
20								9,683
21								10,827
22								11,307
23	0.30		0.43	0.31			0.03	11,606
24		0.26						10,218
25								11,245
26								12,496
27								10,467
28								11,660
29		0.25		0.33				12,632
30	0.23		0.34					11,298
31								10,769

Average	0.23	0.28	0.40	0.34		0.048	0.03	9,997
Minimum	0.20	0.25	0.32	0.31		0.048	0.03	7,962
Maximum	0.30	0.33	0.53	0.36		0.048	0.03	12,632
Count	5	5	5	5	0	1	1	31
Total								309,919
95 Percentile						0.048	0.03	
Exceedences	0	0	0	0	0	0	0	0
Median	0.22	0.26	0.39	0.33		0.048	0.03	10,063

August 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								11,504
2								11,313
3								8,931
4								10,981
5								11,591
6								12,387
7					0.03			11,252
8	0.17	0.19	0.40	0.22				12,935
9								12,186
10								10,287
11								10,251
12								10,230
13								10,178
14	0.34	0.40	0.35	0.28				10,491
15								11,710
16								11,781
17								10,847
18								10,820
19						0.02		11,489
20			0.36	0.39				10,164
21	0.21	0.41						10,140
22								9,515
23								10,253
24								8,602
25								9,161
26	0.27		0.41	0.42				10,627
27							0.04	9,942
28								10,322
29								11,309
30								10,731
31								9,821

Average	0.25	0.33	0.38	0.33	0.03	0.02	0.04	10,702
Minimum	0.17	0.19	0.35	0.22	0.03	0.02	0.04	8,602
Maximum	0.34	0.41	0.41	0.42	0.03	0.02	0.04	12,935
Count	4	3	4	4	1	1	1	31
Total								331,751
95 Percentile					0.03	0.02	0.04	
Exceedences	0	0	0	0	0	0	0	0
Median	0.24	0.40	0.38	0.34	0.03	0.02	0.04	10,627

September 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								9,088
2								10,441
3	0.36	0.40	0.43	0.30	0.04			9,678
4								9,822
5								9,590
6								10,288
7								10,098
8								9,324
9			0.30	0.30				9,499
10								7,875
11	0.27	0.32						7,994
12								8,531
13								7,278
14								6,275
15								6,341
16	0.25		0.36	0.26		0.04		6,480
17								5,978
18		0.27						6,568
19								6,066
20								5,649
21								6,178
22		0.45						5,143
23	0.24		0.45	0.28				6,218
24								5,448
25								5,798
26								5,964
27								5,833
28								5,948
29								5,337
30	0.44		0.25					6,273

Average	0.31	0.36	0.36	0.29	0.04	0.04		7,367
Minimum	0.24	0.27	0.25	0.26	0.04	0.04		5,143
Maximum	0.44	0.45	0.45	0.30	0.04	0.04		10,441
Count	5	4	5	4	1	1	0	30
Total								221,003
95 Percentile Exceedences	0	0	0	0	0	0	0	0
Median	0.27	0.36	0.36	0.29	0.04	0.04		6,411

October 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1	0.21							5,560
2								5,848
3								5,223
4								5,817
5								5,193
6								5,081
7								5,989
8								5,118
9	0.36	0.32	0.37	0.22				5,634
10								5,056
11								5,741
12								4,827
13								5,228
14								5,199
15		0.27	0.42	0.21				5,709
16	0.38							5,597
17								4,452
18								5,406
19								5,221
20								5,998
21								7,695
22								6,136
23								4,927
24								4,892
25								5,079
26								4,988
27								4,911
28			0.34	0.21			0.74	5,273
29	0.39							5,205
30		0.20						4,771
31								4,935

Average	0.34	0.26	0.38	0.21			0.74	5,378
Minimum	0.21	0.20	0.34	0.21			0.74	4,452
Maximum	0.39	0.32	0.42	0.22			0.74	7,695
Count	4	3	3	3	0	0	1	31
Total								166,709
95 Percentile							0.74	
Exceedences	0	0	0	0	0	0	1	0
Median	0.37	0.27	0.37	0.21			0.74	5,221

November 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m³/d)
1								5,087
2								4,445
3								5,253
4								4,914
5	0.22		0.27	0.21	0.08			4,830
6								4,505
7		0.29						5,110
8								4,928
9								4,426
10								4,567
11								5,267
12								4,360
13	0.23		0.29	0.12				5,098
14		0.28						4,672
15								4,718
16								4,764
17								4,593
18	0.28	0.26	0.27	0.20		0.07		4,977
19								4,725
20								4,464
21								4,899
22								4,511
23								4,827
24								4,332
25							0.07	4,940
26								5,295
27								4,728
28								4,810
29								4,391
30								4,499

Average	0.24	0.28	0.28	0.18	0.08	0.07	0.07	4,765
Minimum	0.22	0.26	0.27	0.12	0.08	0.07	0.07	4,332
Maximum	0.28	0.29	0.29	0.21	0.08	0.07	0.07	5,295
Count	3	3	3	3	1	1	1	30
Total								142,935
95 Percentile Exceedences	0	0	0	0	0.08	0.07	0.07	0
Median	0.23	0.28	0.27	0.20	0.08	0.07	0.07	4,746

December 2019	3908 Cowichan Lake Rd Free Cl2 (mg/L)	Bell McKinnon Reservoir Free Cl2 (mg/L)	Maple Bay Marina Free Cl2 (mg/L)	Maple Mtn Reservoir Free Cl2 (mg/L)	Boys Rd - Well 1 Turbidity (NTU)	Boys Rd - Well 3 Turbidity (NTU)	Boys Rd - Well 5 Turbidity (NTU)	Boys Rd PS Flow (Volumetric Rate) (m ³ /d)
1								5,190
2	0.13							4,860
3		0.37	0.42		0.07			4,779
4								4,928
5				0.22				4,899
6								4,261
7								5,228
8								5,030
9	0.49	0.38	0.47	0.25				4,674
10								4,809
11								4,620
12								4,734
13								5,009
14								4,914
15								5,808
16			0.43	0.26				5,179
17	0.39	0.31						5,670
18								4,999
19								4,442
20								4,987
21								4,862
22								4,716
23		0.26	0.57	0.22				5,183
24	0.58							5,010
25								5,968
26								4,715
27								5,464
28								4,730
29								4,874
30			0.22	0.27				5,363
31	0.42	0.24						4,499

Average	0.40	0.31	0.42	0.24	0.07			4,981
Minimum	0.13	0.24	0.22	0.22	0.07			4,261
Maximum	0.58	0.38	0.57	0.27	0.07			5,968
Count	5	5	5	5	1	0	0	31
Total								154,404
95 Percentile					0.07			
Exceedences	0	0	0	0	0	0	0	0
Median	0.42	0.31	0.43	0.25	0.07			4,914

* indicates Geometric Mean
** indicates Intraday Average

Report Name: E.Coli and Total Coliforms

Water System	Facility	Sampling Point	Collection Date	Escherichia coli / E. coli (Count) Escherichia coli / E. coli (counts) Laboratory Report counts/100ml	Total Coliforms (count) Total Coliforms (counts) Laboratory Report counts/100ml
South End Drinking Water	Facility 1	1820 Herd Road	01/14/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	02/19/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	03/18/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	04/15/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	05/21/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	06/17/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	07/15/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	08/19/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	09/16/2019	0	880
South End Drinking Water	Facility 1	1820 Herd Road	10/22/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	11/18/2019	0	0
South End Drinking Water	Facility 1	1820 Herd Road	12/16/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	01/07/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	02/05/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	03/04/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	04/01/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	05/06/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	06/03/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	07/02/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	08/07/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	09/03/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	10/07/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	11/04/2019	0	0
South End Drinking Water	Facility 1	Bell McKinnon Reservoir	12/03/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	01/07/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	02/19/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	03/12/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	04/08/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	05/13/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	06/10/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	07/08/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	08/12/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	09/09/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	10/16/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	11/12/2019	0	0
South End Drinking Water	Facility 1	Lakeview Reservoir	12/09/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	01/21/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	02/25/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	03/25/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	04/23/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	05/27/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	06/24/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	07/23/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	08/26/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	09/24/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	10/28/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	11/25/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Marina	12/16/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	01/21/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	02/25/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	03/25/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	04/23/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	05/27/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	06/24/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	07/23/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	08/26/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	09/24/2019	0	0

South End Drinking Water	Facility 1	Maple Bay Reservoir #2	10/28/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	11/25/2019	0	0
South End Drinking Water	Facility 1	Maple Bay Reservoir #2	12/16/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	01/14/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	02/19/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	03/18/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	04/15/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	05/21/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	06/17/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	07/15/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	08/19/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	09/16/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	10/22/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	11/18/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Pump House	12/16/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	01/21/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	02/25/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	03/25/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	04/23/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	05/27/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	06/24/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	07/23/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	08/26/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	09/24/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	10/28/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	11/25/2019	0	0
South End Drinking Water	Facility 1	Maple Mtn Reservoir	12/16/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	01/07/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	02/19/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	03/12/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	04/08/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	05/13/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	06/10/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	07/08/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	08/12/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	09/09/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	10/16/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	11/12/2019	0	0
South End Drinking Water	Facility 1	Municipal Hall	12/09/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	01/07/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	02/19/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	03/12/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	04/08/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	05/13/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	06/10/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	07/08/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	08/12/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	09/09/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	10/16/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	11/12/2019	0	0
South End Drinking Water	Facility 1	North Rd Reservoir #2	12/09/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	01/21/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	02/25/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	03/25/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	04/23/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	05/27/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	06/24/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	07/23/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	08/26/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	09/24/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	10/28/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	11/25/2019	0	0
South End Drinking Water	Facility 1	Properties Reservoir	12/16/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	01/07/2019	0	0

South End Drinking Water	Facility 1	Properties Water Pump Station	02/05/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	03/04/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	04/01/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	05/06/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	06/03/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	07/02/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	08/07/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	09/03/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	10/07/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	11/04/2019	0	0
South End Drinking Water	Facility 1	Properties Water Pump Station	12/03/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	01/07/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	02/19/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	03/12/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	04/08/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	05/13/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	06/10/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	07/08/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	08/12/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	09/09/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	10/16/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	11/12/2019	0	0
South End Drinking Water	Facility 1	Stonehouse Reservoir	12/09/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	01/07/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	02/19/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	03/12/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	04/08/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	05/13/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	06/10/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	07/08/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	08/12/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	09/09/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	10/16/2019	0	0
South End Drinking Water	Facility 1	Vancouver Island Motorsports	12/09/2019	0	0

* indicates Geometric Mean
 ** indicates Intraday Average

Facility: Facility 1
Sampling Point: Bell McKinnon Reservoir (1-10-EP, 3B10E)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria	MCL
11/21/2019 00:00 0.00039 mg/L	Bell McKinnon Reservoir	Lead (total)	<=0.015	MCL

# samples: 1	min: 0.00039 mg/L
# detects: 1	max: 0.00039 mg/L
# non-detects: 0	avg: 0.00039 mg/L (based on 1 numerical results)
# of Exceedences: 0	

Facility: Facility 1
Sampling Point: Lakeview Reservoir (1-8-EP, 3B10C)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria	MCL
11/21/2019 00:00 0.00042 mg/L	Lakeview Reservoir	Lead (total)	<=0.015	MCL

# samples: 1	min: 0.00042 mg/L
# detects: 1	max: 0.00042 mg/L
# non-detects: 0	avg: 0.00042 mg/L (based on 1 numerical results)
# of Exceedences: 0	

Facility: Facility 1
Sampling Point: Maple Bay Reservoir #2 (1-19-EP, 3B117)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria	MCL
11/21/2019 00:00 0.00034 mg/L	Maple Bay Reservoir #2	Lead (total)	<=0.015	MCL

# samples: 1	min: 0.00034 mg/L
# detects: 1	max: 0.00034 mg/L
# non-detects: 0	avg: 0.00034 mg/L (based on 1 numerical results)
# of Exceedences: 0	

Facility: Facility 1
Sampling Point: Maple Mtn Pump House (1-2-EP, 3B106)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria	MCL
11/21/2019 00:00 0.00060 mg/L	Maple Mtn Pump House	Lead (total)	<=0.015	MCL

# samples: 1	min: 0.00060 mg/L
# detects: 1	max: 0.00060 mg/L

non-detects: 0 **avg:** 0.00060 mg/L (based on 1 numerical results)
of Exceedences: 0

Facility: Facility 1
Sampling Point: Maple Mtn Reservoir (1-9-EP, 3B10D)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
11/21/2019 00:00 0.00051 mg/L	Maple Mtn Reservoir	Lead (total)	<=0.015 MCL

samples: 1 **min:** 0.00051 mg/L
detects: 1 **max:** 0.00051 mg/L
non-detects: 0 **avg:** 0.00051 mg/L (based on 1 numerical results)
of Exceedences: 0

Facility: Facility 1
Sampling Point: North Rd Reservoir #2 (1-18-EP, 3B116)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
11/21/2019 00:00 0.00045 mg/L	North Rd Reservoir #2	Lead (total)	<=0.015 MCL

samples: 1 **min:** 0.00045 mg/L
detects: 1 **max:** 0.00045 mg/L
non-detects: 0 **avg:** 0.00045 mg/L (based on 1 numerical results)
of Exceedences: 0

Facility: Facility 1
Sampling Point: Properties Reservoir (1-7-EP, 3B10B)

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
* 11/21/2019 00:00 0.0337 mg/L	Properties Reservoir	Lead (total)	<=0.015 MCL
12/20/2019 09:15 < 0.00020 mg/L	Properties Reservoir	Lead (total)	<=0.015 MCL

samples: 2 **min:** < 0.00020 mg/L
detects: 1 **max:** 0.0337 mg/L
non-detects: 1 **avg:** 0.0337 mg/L (based on 1 numerical results)
of Exceedences: 1

Facility: Facility 1
Sampling Point: Properties Water Pump Station (1-3-EP, 3B107)

Lead (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
11/21/2019 00:00	0.00137 mg/L	Properties Water Pump Station	Lead (total)	<=0.015	MCL

# samples:	1	min:	0.00137 mg/L
# detects:	1	max:	0.00137 mg/L
# non-detects:	0	avg:	0.00137 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 1 (3-2-SR, 3B169)

Aluminum(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.0050 mg/L	Boys Rd - Well 1	Aluminum	<=0.2	Secondary Standard

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.00020 mg/L	Boys Rd - Well 1	Antimony (total)	<=0.006	MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.00050 mg/L	Boys Rd - Well 1	Arsenic (total)	<=0.010	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.0050 mg/L	Boys Rd - Well 1	Barium (total)	<=2	MCL

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)



of Exceedences: 0

Beryllium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.00010 mg/L	Boys Rd - Well 1	Beryllium (total)	<=0.004	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.10 ug/L	Boys Rd - Well 1	Bismuth (total)		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	0.0082 mg/L	Boys Rd - Well 1	Boron (total)	<=5	MAC

# samples:	1	min:	0.0082 mg/L
# detects:	1	max:	0.0082 mg/L
# non-detects:	0	avg:	0.0082 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Bromate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.01 mg/L	Boys Rd - Well 1	Bromate	<=0.01	MAC

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.000010 mg/L	Boys Rd - Well 1	Cadmium (total)	<=0.005	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00	6,940 ug/L	Boys Rd - Well 1	Calcium (total)	

# samples:	1	min:	6,940 ug/L
# detects:	1	max:	6,940 ug/L
# non-detects:	0	avg:	6,940 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00	1.6 mg/L	Boys Rd - Well 1	Chloride	<=250 Secondary Standard

# samples:	1	min:	1.6 mg/L
# detects:	1	max:	1.6 mg/L
# non-detects:	0	avg:	1.6 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00	< 0.00050 mg/L	Boys Rd - Well 1	Chromium (total)	<=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00	< 0.10 ug/L	Boys Rd - Well 1	Cobalt (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00	0.00395 mg/L	Boys Rd - Well 1	Copper (total)	<=1 Secondary Standard

# samples:	1	min:	0.00395 mg/L
# detects:	1	max:	0.00395 mg/L
# non-detects:	0	avg:	0.00395 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.0020 mg/L	Boys Rd - Well 1	Cyanide (total)	<=0.2	MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.0100 mg/L	Boys Rd - Well 1	Diquat	<=0.02	MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.1 mg/L	Boys Rd - Well 1	Fluoride	<=4.0	MCL

# samples:	1	min:	< 0.1 mg/L
# detects:	0	max:	< 0.1 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.05 mg/L	Boys Rd - Well 1	Glyphosate	<=0.7	MCL

# samples:	1	min:	< 0.05 mg/L
# detects:	0	max:	< 0.05 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Hardness (total, as CaCO3)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	20.4 mg/L	Boys Rd - Well 1	Hardness (total, as CaCO3)		

# samples:	1	min:	20.4 mg/L
# detects:	1	max:	20.4 mg/L
# non-detects:	0	avg:	20.4 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.01 mg/L	Boys Rd - Well 1	Iron (total)	<=0.3	Secondary Standard

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	0.00027 mg/L	Boys Rd - Well 1	Lead (total)	<=0.015	MCL

# samples:	1	min:	0.00027 mg/L
# detects:	1	max:	0.00027 mg/L
# non-detects:	0	avg:	0.00027 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lithium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.10 ug/L	Boys Rd - Well 1	Lithium (total)		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	744 ug/L	Boys Rd - Well 1	Magnesium (total)		

# samples:	1	min:	744 ug/L
# detects:	1	max:	744 ug/L
# non-detects:	0	avg:	744 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.00020 mg/L	Boys Rd - Well 1	Manganese (total)	<=0.05	Secondary Standard

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.000010 mg/L	Boys Rd - Well 1	Mercury (total)	<=0.002	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.10 ug/L	Boys Rd - Well 1	Molybdenum (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.00040 mg/L	Boys Rd - Well 1	Nickel (total)	<=0.1 MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 0.089 mg/L	Boys Rd - Well 1	Nitrate (as N)	<=10 MCL

# samples:	1	min:	0.089 mg/L
# detects:	1	max:	0.089 mg/L
# non-detects:	0	avg:	0.089 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrioltriacetic acid / NTA(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.2 mg/L	Boys Rd - Well 1	Nitrioltriacetic acid / NTA	<=0.4 MAC

# samples:	1	min:	< 0.2 mg/L
# detects:	0	max:	< 0.2 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.0050 mg/L	Boys Rd - Well 1	Paraquat	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
* 01/02/2019	6.31	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
02/05/2019	6.65	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
03/07/2019	6.8	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
04/01/2019	6.97	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
05/06/2019	6.99	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
* 08/07/2019	6.38	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
* 09/03/2019	6.3	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
11/05/2019	6.64	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard
12/03/2019	6.83	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard

# samples:	9	min:	6.3
# detects:	9	max:	6.99
# non-detects:	0	avg:	6.65 (based on 9 numerical results)
# of Exceedences:	3		

pH(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	7.05	Boys Rd - Well 1	pH	>=6.5, <=8.5	Secondary Standard

# samples:	1	min:	7.05
# detects:	1	max:	7.05
# non-detects:	0	avg:	7.05 (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	190 ug/L	Boys Rd - Well 1	Potassium (total)		

# samples:	1	min:	190 ug/L
-------------------	---	-------------	----------



# detects:	1	max:	190 ug/L
# non-detects:	0	avg:	190 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.00050 mg/L	Boys Rd - Well 1	Selenium (total)	<=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 2,100 ug/L	Boys Rd - Well 1	Silicon (total, as Si)	

# samples:	1	min:	2,100 ug/L
# detects:	1	max:	2,100 ug/L
# non-detects:	0	avg:	2,100 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.000050 mg/L	Boys Rd - Well 1	Silver (total)	<=0.1 Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 1.48 mg/L	Boys Rd - Well 1	Sodium (total)	<=160 MCL

# samples:	1	min:	1.48 mg/L
# detects:	1	max:	1.48 mg/L
# non-detects:	0	avg:	1.48 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 20.7 ug/L	Boys Rd - Well 1	Strontium (total)	

# samples:	1	min:	20.7 ug/L
# detects:	1	max:	20.7 ug/L
# non-detects:	0	avg:	20.7 ug/L (based on 1 numerical results)

of Exceedences: 0

Sulfur (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 3,000 ug/L	Boys Rd - Well 1	Sulfur (total)	

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 1.8 mg/L	Boys Rd - Well 1	Sulphate	<=250 Secondary Standard

# samples:	1	min:	1.8 mg/L
# detects:	1	max:	1.8 mg/L
# non-detects:	0	avg:	1.8 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 20 ug/L	Boys Rd - Well 1	Sulphide (total, as S)	

# samples:	1	min:	< 20 ug/L
# detects:	0	max:	< 20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
--------------------------------	---------------------	------------------	----------

* 01/02/2019	16.1 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
02/05/2019	11.9 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
03/07/2019	9.7 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
04/01/2019	13.1 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
05/06/2019	13 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
* 08/07/2019	15.3 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
* 09/03/2019	15.9 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
* 11/05/2019	16.3 degrees C	Boys Rd - Well 1	Temperature	<=15	AO
* 12/03/2019	17.1 degrees C	Boys Rd - Well 1	Temperature	<=15	AO

# samples:	9	min:	9.7 degrees C
# detects:	9	max:	17.1 degrees C
# non-detects:	0	avg:	14.3 degrees C (based on 9 numerical results)
# of Exceedences:	5		



Thallium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.000020 mg/L	Boys Rd - Well 1	Thallium (total)	<=0.002	MCL
# samples:	1	min:	< 0.000020 mg/L		
# detects:	0	max:	< 0.000020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Tin (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 0.20 ug/L	Boys Rd - Well 1	Tin (total)		
# samples:	1	min:	< 0.20 ug/L		
# detects:	0	max:	< 0.20 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Titanium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
01/28/2019 11:00	< 5.0 ug/L	Boys Rd - Well 1	Titanium (total)		
# samples:	1	min:	< 5.0 ug/L		
# detects:	0	max:	< 5.0 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Turbidity(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
01/02/2019	0.08 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
02/05/2019	0.09 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
03/07/2019	0.08 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
04/01/2019	0.056 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
05/06/2019	0.05 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
08/07/2019	0.03 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
09/03/2019	0.04 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
11/05/2019	0.08 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
12/03/2019	0.07 NTU	Boys Rd - Well 1	Turbidity	<=0.5	User-Defined
# samples:	9	min:	0.03 NTU		
# detects:	9	max:	0.09 NTU		
# non-detects:	0	avg:	0.064 NTU (based on 9 numerical results)		
# of Exceedences:	0	95th percentile:	0.090 NTU		



Uranium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.000020 mg/L	Boys Rd - Well 1	Uranium (total)	<=0.02 MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 1.3 ug/L	Boys Rd - Well 1	Vanadium (total)	

# samples:	1	min:	1.3 ug/L
# detects:	1	max:	1.3 ug/L
# non-detects:	0	avg:	1.3 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 0.0077 mg/L	Boys Rd - Well 1	Zinc (total)	<=5 Secondary Standard

# samples:	1	min:	0.0077 mg/L
# detects:	1	max:	0.0077 mg/L
# non-detects:	0	avg:	0.0077 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
01/28/2019 11:00 < 0.10 ug/L	Boys Rd - Well 1	Zirconium (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Facility:	Water - Raw; Water - Raw
Sampling Point:	Boys Rd - Well 3 (3-4-SR, 3B16B)

1,1,1-Trichloroethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,1,1-Trichloroethane	<=0.2 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

1,1,2,2-Tetrachloroethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.5 ug/L	Boys Rd - Well 3	1,1,2,2-Tetrachloroethane	

# samples:	1	min:	< 0.5 ug/L
# detects:	0	max:	< 0.5 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1,2-Trichloroethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,1,2-Trichloroethane	<=0.005 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1-Dichloroethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 1.0 ug/L	Boys Rd - Well 3	1,1-Dichloroethane	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,1-Dichloroethylene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,1-Dichloroethylene	<=0.007 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

1,2-Dichlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0005 mg/L	Boys Rd - Well 3	1,2-Dichlorobenzene	<=0.6 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)



of Exceedences: 0

1,2-Dichloroethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,2-Dichloroethane	<=0.003 MCL

# samples: 1	min: < 0.0010 mg/L
# detects: 0	max: < 0.0010 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

1,2-Dichloropropane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,2-Dichloropropane	<=0.005 MCL

# samples: 1	min: < 0.0010 mg/L
# detects: 0	max: < 0.0010 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

1,3-Dichlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 1.0 ug/L	Boys Rd - Well 3	1,3-Dichlorobenzene	

# samples: 1	min: < 1.0 ug/L
# detects: 0	max: < 1.0 ug/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

1,3-Dichloropropene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 1.0 ug/L	Boys Rd - Well 3	1,3-Dichloropropene	

# samples: 1	min: < 1.0 ug/L
# detects: 0	max: < 1.0 ug/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

1,4-Dichlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	1,4-Dichlorobenzene	<=0.075 MCL

# samples: 1	min: < 0.0010 mg/L
# detects: 0	max: < 0.0010 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

1-Methylnaphthalene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	1-Methylnaphthalene	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6 + 2,3,5,6-Tetrachlorophenol(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.50 ug/L	Boys Rd - Well 3	2,3,4,6 + 2,3,5,6-Tetrachlorop henol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4,6-Tetrachlorophenol(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.00050 mg/L	Boys Rd - Well 3	2,3,4,6-Tetrachlorop henol	<=0.001 AO (MAC is 0.1 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,4-Trichlorophenol(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.50 ug/L	Boys Rd - Well 3	2,3,4-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3,5-Trichlorophenol(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.50 ug/L	Boys Rd - Well 3	2,3,5-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)



of Exceedences: 0

2,3,6-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,3,6-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,3-Dichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.20 ug/L	Boys Rd - Well 3	2,3-Dichlorophenol	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4 + 2,5-Dichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.20 ug/L	Boys Rd - Well 3	2,4 + 2,5-Dichlorophenol	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.50 ug/L	Boys Rd - Well 3	2,4,5-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.10 ug/L	Boys Rd - Well 3	2,4,5-Trichlorophenoxyacetic acid / 2,4,5-T	

# samples:	1	min:	< 0.10 ug/L
-------------------	---	-------------	-------------



# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4,6-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.00050 mg/L	Boys Rd - Well 3	2,4,6-Trichlorophenol	<=0.002 AO (MAC is 0.005 mg/L)

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,4-Dichlorophenoxyacetic acid / 2,4-D(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.00010 mg/L	Boys Rd - Well 3	2,4-Dichlorophenoxy acetic acid / 2,4-D	<=0.07 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2,6-Dichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.20 ug/L	Boys Rd - Well 3	2,6-Dichlorophenol	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chloronaphthalene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.100 ug/L	Boys Rd - Well 3	2-Chloronaphthalene	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Chlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.10 ug/L	Boys Rd - Well 3	2-Chlorophenol	



# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-methyl-4-chlorophenoxyacetic acid / MCPA(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.20 ug/L	Boys Rd - Well 3	2-methyl-4-chlorophe noxyacetic acid / MCPA	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

2-Methylnaphthalene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.100 ug/L	Boys Rd - Well 3	2-Methylnaphthalene	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3 and 4-Chlorophenol (Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.10 ug/L	Boys Rd - Well 3	3 and 4-Chlorophenol	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4,5-Trichlorophenol(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.50 ug/L	Boys Rd - Well 3	3,4,5-Trichlorophenol	

# samples:	1	min:	< 0.50 ug/L
# detects:	0	max:	< 0.50 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

3,4-Dichlorophenol(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.20 ug/L	Boys Rd - Well 3	3,4-Dichlorophenol	
# samples:	1	min:	< 0.20 ug/L	
# detects:	0	max:	< 0.20 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

3,5-Dichlorophenol(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.20 ug/L	Boys Rd - Well 3	3,5-Dichlorophenol	
# samples:	1	min:	< 0.20 ug/L	
# detects:	0	max:	< 0.20 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

4-Chloro-3-methylphenol (Parachlorometacresol)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.50 ug/L	Boys Rd - Well 3	4-Chloro-3-methylphenol (Parachlorometacresol)	
# samples:	1	min:	< 0.50 ug/L	
# detects:	0	max:	< 0.50 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Acenaphthene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Acenaphthene	
# samples:	1	min:	< 0.050 ug/L	
# detects:	0	max:	< 0.050 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Acenaphthylene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.200 ug/L	Boys Rd - Well 3	Acenaphthylene	
# samples:	1	min:	< 0.200 ug/L	
# detects:	0	max:	< 0.200 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Acridine(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Acridine	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alachlor(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000100 mg/L	Boys Rd - Well 3	Alachlor	<=0.002 MCL

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aldrin(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.006 ug/L	Boys Rd - Well 3	Aldrin	

# samples:	1	min:	< 0.006 ug/L
# detects:	0	max:	< 0.006 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

alpha-BHC(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.010 ug/L	Boys Rd - Well 3	alpha-BHC	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aluminum (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0050 mg/L	Boys Rd - Well 3	Aluminum (total)	<=0.2 Secondary Standard

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Anthracene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.010 ug/L	Boys Rd - Well 3	Anthracene	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.00020 mg/L	Boys Rd - Well 3	Antimony (total)	<=0.006 MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1016(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1016	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1221(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1221	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1232(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1232	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1242(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Aroclor 1242	



# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1248(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1248	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1254(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1254	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1260(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1260	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1262(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1262	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Aroclor 1268(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Aroclor 1268	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.00050 mg/L	Boys Rd - Well 3	Arsenic (total)	<=0.010	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Atrazine + N-dealkylated metabolites(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
--	--	----------------------------	-------------------------	-----------------	--

08/06/2019 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Atrazine + N-dealkylated metabolites	<=0.005	MAC
------------------	-----------------	------------------	--------------------------------------	---------	-----

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Azinphos-methyl(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Azinphos-methyl	<=0.02	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0050 mg/L	Boys Rd - Well 3	Barium (total)	<=2	MCL

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0005 mg/L	Boys Rd - Well 3	Benzene	<=0.001	MCL

# samples:	1	min:	< 0.0005 mg/L
-------------------	---	-------------	---------------

# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)anthracene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.010 ug/L	Boys Rd - Well 3	Benzo(a)anthracene	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(a)pyrene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000010 mg/L	Boys Rd - Well 3	Benzo(a)pyrene	<=0.0002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(b,j)fluoranthene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Benzo(b,j)fluoranthene	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(g,h,i)perylene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Benzo(g,h,i)perylene	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Benzo(k)fluoranthene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Benzo(k)fluoranthene	

# samples:	1	min:	< 0.050 ug/L
-------------------	---	-------------	--------------

# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Beryllium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Beryllium (total)	<=0.004 MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

beta-BHC(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	beta-BHC	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bismuth (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.10 ug/L	Boys Rd - Well 3	Bismuth (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Boron (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	0.0169 mg/L	Boys Rd - Well 3	Boron (total)	<=5 MAC

# samples:	1	min:	0.0169 mg/L
# detects:	1	max:	0.0169 mg/L
# non-detects:	0	avg:	0.0169 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Bromacil(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Bromacil	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Bromate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.01 mg/L	Boys Rd - Well 3	Bromate	<=0.01 MAC

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromodichloromethane (dichlorobromomethane)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
--	--	---------------------	------------------	----------

08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Bromodichloromethane (dichlorobromomethane)	<=0.016 MAC
------------------	---------------	------------------	---	-------------

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoform(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
------------------------------	--	---------------------	------------------	----------

08/06/2019 13:30	< 1.0 ug/L	Boys Rd - Well 3	Bromoform	
------------------	------------	------------------	-----------	--

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Bromoxynil(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
-------------------------------	--	---------------------	------------------	----------

08/06/2019 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Bromoxynil	<=0.005 MAC
------------------	-----------------	------------------	------------	-------------

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Butachlor(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
------------------------------	--	---------------------	------------------	----------

08/06/2019 13:30	< 0.020 ug/L	Boys Rd - Well 3	Butachlor	
------------------	--------------	------------------	-----------	--

# samples:	1	min:	< 0.020 ug/L
-------------------	---	-------------	--------------

# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cadmium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000010 mg/L	Boys Rd - Well 3	Cadmium (total)	<=0.005 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 8,150 ug/L	Boys Rd - Well 3	Calcium (total)	

# samples:	1	min:	8,150 ug/L
# detects:	1	max:	8,150 ug/L
# non-detects:	0	avg:	8,150 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Captan(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.100 ug/L	Boys Rd - Well 3	Captan	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Carbon tetrachloride(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0005 mg/L	Boys Rd - Well 3	Carbon tetrachloride	<=0.003 MCL

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Chlordane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000050 mg/L	Boys Rd - Well 3	Chlordane	<=0.002 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Chloride(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 2.24 mg/L	Boys Rd - Well 3	Chloride	<=250 Secondary Standard

# samples: 1	min: 2.24 mg/L
# detects: 1	max: 2.24 mg/L
# non-detects: 0	avg: 2.24 mg/L (based on 1 numerical results)
# of Exceedences: 0	

Chlorobenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	Chlorobenzene	<=0.1 MCL

# samples: 1	min: < 0.0010 mg/L
# detects: 0	max: < 0.0010 mg/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Chloroethane(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 2.0 ug/L	Boys Rd - Well 3	Chloroethane	

# samples: 1	min: < 2.0 ug/L
# detects: 0	max: < 2.0 ug/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Chloroform(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 1.0 ug/L	Boys Rd - Well 3	Chloroform	

# samples: 1	min: < 1.0 ug/L
# detects: 0	max: < 1.0 ug/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	

Chlorothalonil(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Chlorothalonil	

# samples: 1	min: < 0.050 ug/L
# detects: 0	max: < 0.050 ug/L
# non-detects: 1	avg: n/a (based on 0 numerical results)
# of Exceedences: 0	



Chlorpyrifos(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000010 mg/L	Boys Rd - Well 3	Chlorpyrifos	<=0.09	MAC
# samples:	1	min:	< 0.000010 mg/L		
# detects:	0	max:	< 0.000010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chromium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.00050 mg/L	Boys Rd - Well 3	Chromium (total)	<=0.1	MCL
# samples:	1	min:	< 0.00050 mg/L		
# detects:	0	max:	< 0.00050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Chrysene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Chrysene		
# samples:	1	min:	< 0.050 ug/L		
# detects:	0	max:	< 0.050 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

cis-1,2-Dichloroethylene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	cis-1,2-Dichloroethylene	<=0.07	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Cobalt (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.10 ug/L	Boys Rd - Well 3	Cobalt (total)		
# samples:	1	min:	< 0.10 ug/L		
# detects:	0	max:	< 0.10 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				



Copper (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	0.00539 mg/L	Boys Rd - Well 3	Copper (total)	<=1 Secondary Standard

# samples:	1	min:	0.00539 mg/L
# detects:	1	max:	0.00539 mg/L
# non-detects:	0	avg:	0.00539 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanazine(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Cyanazine	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.0020 mg/L	Boys Rd - Well 3	Cyanide (total)	<=0.2 MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

DDT + metabolites(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.010 ug/L	Boys Rd - Well 3	DDT + metabolites	

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

delta-BHC(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	delta-BHC	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Deltamethrin(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Deltamethrin	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Diazinon(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.000020 mg/L	Boys Rd - Well 3	Diazinon	<=0.02 MAC
# samples:	1	min:	< 0.000020 mg/L	
# detects:	0	max:	< 0.000020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibenzo(a,h)anthracene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.010 ug/L	Boys Rd - Well 3	Dibenzo(a,h)anthracene	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane (Chlorodibromomethane)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 1.0 ug/L	Boys Rd - Well 3	Dibromochloromethane (Chlorodibromomethane)	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromomethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 1.0 ug/L	Boys Rd - Well 3	Dibromomethane	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	



of Exceedences: 0

Dicamba(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Dicamba	<=0.12	MAC

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichloromethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0030 mg/L	Boys Rd - Well 3	Dichloromethane	<=0.005	MCL

# samples:	1	min:	< 0.0030 mg/L
# detects:	0	max:	< 0.0030 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dichlorvos(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Dichlorvos		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diclofop-methyl(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Diclofop-methyl	<=0.009	MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dieldrin(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.010 ug/L	Boys Rd - Well 3	Dieldrin		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dimethoate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Dimethoate	<=0.02	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dinoseb(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Dinoseb	<=0.007	MCL

# samples:	1	min:	< 0.00010 mg/L
# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0100 mg/L	Boys Rd - Well 3	Diquat	<=0.02	MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Disulfoton(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Disulfoton		

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diuron(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Diuron	<=0.15	MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.010 ug/L	Boys Rd - Well 3	Endosulfan (total)		

# samples:	1	min:	< 0.010 ug/L
# detects:	0	max:	< 0.010 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endosulfan sulfate(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Endosulfan sulfate	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin aldehyde(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.020 ug/L	Boys Rd - Well 3	Endrin aldehyde	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin ketone(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.020 ug/L	Boys Rd - Well 3	Endrin ketone	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Endrin(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000020 mg/L	Boys Rd - Well 3	Endrin	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Ethylbenzene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0010 mg/L	Boys Rd - Well 3	Ethylbenzene	<=0.7 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Ethylene dibromide / EDB(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.0003 mg/L	Boys Rd - Well 3	Ethylene dibromide / EDB	<=0.00002 MCL

# samples:	1	min:	< 0.0003 mg/L
# detects:	0	max:	< 0.0003 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fenclorphos(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.100 ug/L	Boys Rd - Well 3	Fenclorphos	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoranthene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.030 ug/L	Boys Rd - Well 3	Fluoranthene	

# samples:	1	min:	< 0.030 ug/L
# detects:	0	max:	< 0.030 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluorene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Fluorene	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.1 mg/L	Boys Rd - Well 3	Fluoride	<=4.0 MCL

# samples:	1	min:	< 0.1 mg/L
# detects:	0	max:	< 0.1 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Glyphosate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.05 mg/L	Boys Rd - Well 3	Glyphosate	<=0.7	MCL

# samples:	1	min:	< 0.05 mg/L
# detects:	0	max:	< 0.05 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Hardness (total, as CaCO3)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	24.5 mg/L	Boys Rd - Well 3	Hardness (total, as CaCO3)		

# samples:	1	min:	24.5 mg/L
# detects:	1	max:	24.5 mg/L
# non-detects:	0	avg:	24.5 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Heptachlor epoxide(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000010 mg/L	Boys Rd - Well 3	Heptachlor epoxide	<=0.0002	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Heptachlor(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000010 mg/L	Boys Rd - Well 3	Heptachlor	<=0.0004	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Indeno(1,2,3-c,d)pyrene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Indeno(1,2,3-c,d)pyrene		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Iron (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.01 mg/L	Boys Rd - Well 3	Iron (total)	<=0.3	Secondary Standard

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	0.00035 mg/L	Boys Rd - Well 3	Lead (total)	<=0.015	MCL

# samples:	1	min:	0.00035 mg/L
# detects:	1	max:	0.00035 mg/L
# non-detects:	0	avg:	0.00035 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lindane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000050 mg/L	Boys Rd - Well 3	Lindane	<=0.0002	MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Linuron(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.050 ug/L	Boys Rd - Well 3	Linuron		

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lithium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.10 ug/L	Boys Rd - Well 3	Lithium (total)		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 1,000 ug/L	Boys Rd - Well 3	Magnesium (total)	

# samples:	1	min:	1,000 ug/L
# detects:	1	max:	1,000 ug/L
# non-detects:	0	avg:	1,000 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Malathion(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000100 mg/L	Boys Rd - Well 3	Malathion	<=0.19 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.00020 mg/L	Boys Rd - Well 3	Manganese (total)	<=0.05 Secondary Standard

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Mercury (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000010 mg/L	Boys Rd - Well 3	Mercury (total)	<=0.002 MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methoxychlor(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000050 mg/L	Boys Rd - Well 3	Methoxychlor	<=0.04 MCL

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl parathion(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.100 ug/L	Boys Rd - Well 3	Methyl parathion	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Methyl tert-butyl ether / MTBE(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 1.0 ug/L	Boys Rd - Well 3	Methyl tert-butyl ether / MTBE	

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metolachlor(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000100 mg/L	Boys Rd - Well 3	Metolachlor	<=0.05 MAC

# samples:	1	min:	< 0.000100 mg/L
# detects:	0	max:	< 0.000100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Metribuzin(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000200 mg/L	Boys Rd - Well 3	Metribuzin	<=0.08 MAC

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.10 ug/L	Boys Rd - Well 3	Molybdenum (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Naphthalene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.200 ug/L	Boys Rd - Well 3	Naphthalene	

# samples:	1	min:	< 0.200 ug/L
-------------------	---	-------------	--------------

# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.00040 mg/L	Boys Rd - Well 3	Nickel (total)	<=0.1	MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	0.088 mg/L	Boys Rd - Well 3	Nitrate (as N)	<=10	MCL

# samples:	1	min:	0.088 mg/L
# detects:	1	max:	0.088 mg/L
# non-detects:	0	avg:	0.088 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitritotriacetic acid / NTA(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.2 mg/L	Boys Rd - Well 3	Nitritotriacetic acid / NTA	<=0.4	MAC

# samples:	1	min:	< 0.2 mg/L
# detects:	0	max:	< 0.2 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0050 mg/L	Boys Rd - Well 3	Paraquat	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Parathion(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Parathion	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Pentachloronitrobenzene / PCNB(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Pentachloronitrobenzene / PCNB	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Pentachlorophenol / PCP(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.00050 mg/L	Boys Rd - Well 3	Pentachlorophenol / PCP	<=0.001 MCL
# samples:	1	min:	< 0.00050 mg/L	
# detects:	0	max:	< 0.00050 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Permethrin(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.010 ug/L	Boys Rd - Well 3	Permethrin	
# samples:	1	min:	< 0.010 ug/L	
# detects:	0	max:	< 0.010 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

pH(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria
* 01/14/2019	6.34	Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
02/19/2019	6.82	Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
03/23/2019	6.87	Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
04/15/2019	6.73	Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard
05/22/2019	6.76	Boys Rd - Well 3	pH	>=6.5, <=8.5 Secondary Standard



pH(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
* 06/17/2019	6.34	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard
07/16/2019	6.55	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard
08/19/2019	6.59	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard
* 09/16/2019	6.35	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard
11/18/2019	6.8	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard
# samples:	10	min:	6.34		
# detects:	10	max:	6.87		
# non-detects:	0	avg:	6.62	(based on 10 numerical results)	
# of Exceedences:	3				

pH(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	7.13	Boys Rd - Well 3	pH	>=6.5, <=8.5	Secondary Standard
# samples:	1	min:	7.13		
# detects:	1	max:	7.13		
# non-detects:	0	avg:	7.13	(based on 1 numerical results)	
# of Exceedences:	0				

Phenanthrene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Phenanthrene		
# samples:	1	min:	< 0.100 ug/L		
# detects:	0	max:	< 0.100 ug/L		
# non-detects:	1	avg:	n/a	(based on 0 numerical results)	
# of Exceedences:	0				

Phorate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Phorate	<=0.002	MAC
# samples:	1	min:	< 0.000100 mg/L		
# detects:	0	max:	< 0.000100 mg/L		
# non-detects:	1	avg:	n/a	(based on 0 numerical results)	
# of Exceedences:	0				

Picloram(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.00010 mg/L	Boys Rd - Well 3	Picloram	<=0.5	MCL
# samples:	1	min:	< 0.00010 mg/L		

# detects:	0	max:	< 0.00010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Polychlorinated Biphenyls / PCBs (as arochlor total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Polychlorinated Biphenyls / PCBs (as arochlor total)	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 260 ug/L	Boys Rd - Well 3	Potassium (total)	

# samples:	1	min:	260 ug/L
# detects:	1	max:	260 ug/L
# non-detects:	0	avg:	260 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Prometon(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.300 ug/L	Boys Rd - Well 3	Prometon	

# samples:	1	min:	< 0.300 ug/L
# detects:	0	max:	< 0.300 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Prometryn(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.100 ug/L	Boys Rd - Well 3	Prometryn	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Pyrene(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.020 ug/L	Boys Rd - Well 3	Pyrene	

# samples:	1	min:	< 0.020 ug/L
# detects:	0	max:	< 0.020 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Quinoline(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.050 ug/L	Boys Rd - Well 3	Quinoline	

# samples:	1	min:	< 0.050 ug/L
# detects:	0	max:	< 0.050 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.00050 mg/L	Boys Rd - Well 3	Selenium (total)	<=0.05 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 3,000 ug/L	Boys Rd - Well 3	Silicon (total, as Si)	

# samples:	1	min:	3,000 ug/L
# detects:	1	max:	3,000 ug/L
# non-detects:	0	avg:	3,000 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000050 mg/L	Boys Rd - Well 3	Silver (total)	<=0.1 Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Simazine(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.000200 mg/L	Boys Rd - Well 3	Simazine	<=0.004 MCL

# samples:	1	min:	< 0.000200 mg/L
# detects:	0	max:	< 0.000200 mg/L

# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	1.9 mg/L	Boys Rd - Well 3	Sodium (total)	<=160 MCL

# samples:	1	min:	1.9 mg/L
# detects:	1	max:	1.9 mg/L
# non-detects:	0	avg:	1.9 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	28.2 ug/L	Boys Rd - Well 3	Strontium (total)	

# samples:	1	min:	28.2 ug/L
# detects:	1	max:	28.2 ug/L
# non-detects:	0	avg:	28.2 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Styrene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Styrene	<=0.1 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfotep(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Sulfotep	

# samples:	1	min:	< 0.100 ug/L
# detects:	0	max:	< 0.100 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulfur (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 3,000 ug/L	Boys Rd - Well 3	Sulfur (total)	

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 1.6 mg/L	Boys Rd - Well 3	Sulphate	<=250 Secondary Standard

# samples:	1	min:	1.6 mg/L
# detects:	1	max:	1.6 mg/L
# non-detects:	0	avg:	1.6 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 20 ug/L	Boys Rd - Well 3	Sulphide (total, as S)	

# samples:	1	min:	< 20 ug/L
# detects:	0	max:	< 20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Tebuthiuron(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.200 ug/L	Boys Rd - Well 3	Tebuthiuron	

# samples:	1	min:	< 0.200 ug/L
# detects:	0	max:	< 0.200 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temephos(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30 < 0.500 ug/L	Boys Rd - Well 3	Temephos	

# samples:	1	min:	< 0.500 ug/L
# detects:	0	max:	< 0.500 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
* 01/14/2019 15.7 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
02/19/2019 10.1 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
03/23/2019 11.2 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
04/15/2019 12.4 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
05/22/2019 12.4 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
06/17/2019 13.5 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
07/16/2019 13.9 degrees C	Boys Rd - Well 3	Temperature	<=15 AO
* 08/19/2019 15.7 degrees C	Boys Rd - Well 3	Temperature	<=15 AO

Temperature(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
* 09/16/2019	16.1 degrees C	Boys Rd - Well 3	Temperature	<=15	AO
* 11/18/2019	16 degrees C	Boys Rd - Well 3	Temperature	<=15	AO
# samples:	10	min:	10.1 degrees C		
# detects:	10	max:	16.1 degrees C		
# non-detects:	0	avg:	13.7 degrees C (based on 10 numerical results)		
# of Exceedences:	4				

Terbufos(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000100 mg/L	Boys Rd - Well 3	Terbufos	<=0.001	MAC
# samples:	1	min:	< 0.000100 mg/L		
# detects:	0	max:	< 0.000100 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Tetrachloroethylene / PCE(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Tetrachloroethylene / PCE	<=0.003	MCL
# samples:	1	min:	< 0.0010 mg/L		
# detects:	0	max:	< 0.0010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Thallium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000020 mg/L	Boys Rd - Well 3	Thallium (total)	<=0.002	MCL
# samples:	1	min:	< 0.000020 mg/L		
# detects:	0	max:	< 0.000020 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Time(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria
01/14/2019	920	Boys Rd - Well 3	Time	
02/19/2019	1,135	Boys Rd - Well 3	Time	
03/23/2019	950	Boys Rd - Well 3	Time	
04/15/2019	900	Boys Rd - Well 3	Time	
06/17/2019	1,320	Boys Rd - Well 3	Time	
07/16/2019	1,330	Boys Rd - Well 3	Time	
08/19/2019	1,015	Boys Rd - Well 3	Time	

Time(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria
09/16/2019	815	Boys Rd - Well 3	Time	
11/18/2019	1,140	Boys Rd - Well 3	Time	

# samples:	9	min:	815
# detects:	9	max:	1,330
# non-detects:	0	avg:	1,058 (based on 9 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.20 ug/L	Boys Rd - Well 3	Tin (total)	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 5.0 ug/L	Boys Rd - Well 3	Titanium (total)	

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Toluene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Toluene	<=1 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

trans-1,2-Dichloroethylene(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	trans-1,2-Dichloroethylene	<=0.1 MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Triallate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.100 ug/L	Boys Rd - Well 3	Triallate	
# samples:	1	min:	< 0.100 ug/L	
# detects:	0	max:	< 0.100 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Trichloroethylene / TCE(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Trichloroethylene / TCE	<=0.003 MCL
# samples:	1	min:	< 0.0010 mg/L	
# detects:	0	max:	< 0.0010 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Trichlorofluoromethane(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 1.0 ug/L	Boys Rd - Well 3	Trichlorofluoromethane	
# samples:	1	min:	< 1.0 ug/L	
# detects:	0	max:	< 1.0 ug/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Trifluralin(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
08/06/2019 13:30	< 0.000200 mg/L	Boys Rd - Well 3	Trifluralin	<=0.045 MAC
# samples:	1	min:	< 0.000200 mg/L	
# detects:	0	max:	< 0.000200 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Turbidity(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria
01/14/2019	0.090 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined
02/19/2019	0.08 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined
03/23/2019	0.07 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined
04/15/2019	0.13 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined
05/22/2019	0.05 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined
06/17/2019	0.05 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined
07/16/2019	0.048 NTU	Boys Rd - Well 3	Turbidity	<=0.5 User-Defined



Turbidity(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
08/19/2019	0.02 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
09/16/2019	0.04 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined
11/18/2019	0.07 NTU	Boys Rd - Well 3	Turbidity	<=0.5	User-Defined

# samples:	10	min:	0.02 NTU
# detects:	10	max:	0.13 NTU
# non-detects:	0	avg:	0.065 NTU (based on 10 numerical results)
# of Exceedences:	0	95th percentile:	0.130 NTU

Uranium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.000020 mg/L	Boys Rd - Well 3	Uranium (total)	<=0.02	MAC

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vanadium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 1.0 ug/L	Boys Rd - Well 3	Vanadium (total)		

# samples:	1	min:	< 1.0 ug/L
# detects:	0	max:	< 1.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Vinyl chloride(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0010 mg/L	Boys Rd - Well 3	Vinyl chloride	<=0.001	MCL

# samples:	1	min:	< 0.0010 mg/L
# detects:	0	max:	< 0.0010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Xylenes (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.0020 mg/L	Boys Rd - Well 3	Xylenes (total)	<=10	MCL

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	0.0073 mg/L	Boys Rd - Well 3	Zinc (total)	<=5	Secondary Standard

# samples:	1	min:	0.0073 mg/L
# detects:	1	max:	0.0073 mg/L
# non-detects:	0	avg:	0.0073 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Zirconium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
08/06/2019 13:30	< 0.10 ug/L	Boys Rd - Well 3	Zirconium (total)		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Facility: Water - Raw; Water - Raw
Sampling Point: Boys Rd - Well 5 (3-6-SR, 3B16D)

Aluminum (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.0050 mg/L	Boys Rd - Well 5	Aluminum (total)	<=0.2	Secondary Standard

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Antimony (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.00020 mg/L	Boys Rd - Well 5	Antimony (total)	<=0.006	MCL

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.00050 mg/L	Boys Rd - Well 5	Arsenic (total)	<=0.010	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.0050 mg/L	Boys Rd - Well 5	Barium (total)	<=2	MCL
# samples:	1	min:	< 0.0050 mg/L		
# detects:	0	max:	< 0.0050 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Beryllium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.00010 mg/L	Boys Rd - Well 5	Beryllium (total)	<=0.004	MCL
# samples:	1	min:	< 0.00010 mg/L		
# detects:	0	max:	< 0.00010 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Bismuth (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.10 ug/L	Boys Rd - Well 5	Bismuth (total)		
# samples:	1	min:	< 0.10 ug/L		
# detects:	0	max:	< 0.10 ug/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Boron (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	0.0207 mg/L	Boys Rd - Well 5	Boron (total)	<=5	MAC
# samples:	1	min:	0.0207 mg/L		
# detects:	1	max:	0.0207 mg/L		
# non-detects:	0	avg:	0.0207 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Bromate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.01 mg/L	Boys Rd - Well 5	Bromate	<=0.01	MAC
# samples:	1	min:	< 0.01 mg/L		
# detects:	0	max:	< 0.01 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Cadmium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.000010 mg/L	Boys Rd - Well 5	Cadmium (total)	<=0.005	MCL



# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Calcium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	7,920 ug/L	Boys Rd - Well 5	Calcium (total)	

# samples:	1	min:	7,920 ug/L
# detects:	1	max:	7,920 ug/L
# non-detects:	0	avg:	7,920 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Chloride(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	2.15 mg/L	Boys Rd - Well 5	Chloride	<=250 Secondary Standard

# samples:	1	min:	2.15 mg/L
# detects:	1	max:	2.15 mg/L
# non-detects:	0	avg:	2.15 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Chromium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	< 0.00050 mg/L	Boys Rd - Well 5	Chromium (total)	<=0.1 MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Cobalt (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	< 0.10 ug/L	Boys Rd - Well 5	Cobalt (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Copper (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	0.00444 mg/L	Boys Rd - Well 5	Copper (total)	<=1 Secondary Standard

# samples:	1	min:	0.00444 mg/L
# detects:	1	max:	0.00444 mg/L



# non-detects:	0	avg:	0.00444 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cyanide (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.0020 mg/L	Boys Rd - Well 5	Cyanide (total)	<=0.2	MAC for Cyanide (free)

# samples:	1	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Diquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.0100 mg/L	Boys Rd - Well 5	Diquat	<=0.02	MCL

# samples:	1	min:	< 0.0100 mg/L
# detects:	0	max:	< 0.0100 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.1 mg/L	Boys Rd - Well 5	Fluoride	<=4.0	MCL

# samples:	1	min:	< 0.1 mg/L
# detects:	0	max:	< 0.1 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Glyphosate(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.05 mg/L	Boys Rd - Well 5	Glyphosate	<=0.7	MCL

# samples:	1	min:	< 0.05 mg/L
# detects:	0	max:	< 0.05 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Hardness (dissolved, as CaCO3)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
--	--	----------------------------	-------------------------	-----------------

10/29/2019 11:05	23.6 mg/L	Boys Rd - Well 5	Hardness (dissolved, as CaCO3)	
# samples:	1	min:	23.6 mg/L	

# detects:	1	max:	23.6 mg/L
# non-detects:	0	avg:	23.6 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Iron (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 < 0.01 mg/L	Boys Rd - Well 5	Iron (total)	<=0.3 Secondary Standard

# samples:	1	min:	< 0.01 mg/L
# detects:	0	max:	< 0.01 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Lead (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 0.00030 mg/L	Boys Rd - Well 5	Lead (total)	<=0.015 MCL

# samples:	1	min:	0.00030 mg/L
# detects:	1	max:	0.00030 mg/L
# non-detects:	0	avg:	0.00030 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Lithium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 < 0.10 ug/L	Boys Rd - Well 5	Lithium (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Magnesium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 919 ug/L	Boys Rd - Well 5	Magnesium (total)	

# samples:	1	min:	919 ug/L
# detects:	1	max:	919 ug/L
# non-detects:	0	avg:	919 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Manganese (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 < 0.00020 mg/L	Boys Rd - Well 5	Manganese (total)	<=0.05 Secondary Standard

# samples:	1	min:	< 0.00020 mg/L
# detects:	0	max:	< 0.00020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Mercury (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.000010 mg/L	Boys Rd - Well 5	Mercury (total)	<=0.002	MCL

# samples:	1	min:	< 0.000010 mg/L
# detects:	0	max:	< 0.000010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.10 ug/L	Boys Rd - Well 5	Molybdenum (total)		

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nickel (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.00040 mg/L	Boys Rd - Well 5	Nickel (total)	<=0.1	MCL

# samples:	1	min:	< 0.00040 mg/L
# detects:	0	max:	< 0.00040 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	0.104 mg/L	Boys Rd - Well 5	Nitrate (as N)	<=10	MCL

# samples:	1	min:	0.104 mg/L
# detects:	1	max:	0.104 mg/L
# non-detects:	0	avg:	0.104 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrilotriacetic acid / NTA(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.2 mg/L	Boys Rd - Well 5	Nitrilotriacetic acid / NTA	<=0.4	MAC

# samples:	1	min:	< 0.2 mg/L
# detects:	0	max:	< 0.2 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Paraquat(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.0050 mg/L	Boys Rd - Well 5	Paraquat	<=0.007	MAC for Paraquat ion. Equivalent to 0.01 mg/L for paraquat as dichloride

# samples:	1	min:	< 0.0050 mg/L
# detects:	0	max:	< 0.0050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
01/21/2019	6.61	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
02/25/2019	6.55	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
03/26/2019	6.99	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
04/23/2019	6.98	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
05/27/2019	6.85	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
* 06/24/2019	6.48	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
07/23/2019	6.56	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
08/27/2019	6.57	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
10/28/2019	6.9	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard
11/25/2019	6.8	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard

# samples:	10	min:	6.48
# detects:	10	max:	6.99
# non-detects:	0	avg:	6.73 (based on 10 numerical results)
# of Exceedences:	1		

pH(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	7.06	Boys Rd - Well 5	pH	>=6.5, <=8.5	Secondary Standard

# samples:	1	min:	7.06
# detects:	1	max:	7.06
# non-detects:	0	avg:	7.06 (based on 1 numerical results)
# of Exceedences:	0		

Potassium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	210 ug/L	Boys Rd - Well 5	Potassium (total)		

# samples:	1	min:	210 ug/L
-------------------	---	-------------	----------



# detects:	1	max:	210 ug/L
# non-detects:	0	avg:	210 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.00050 mg/L	Boys Rd - Well 5	Selenium (total)	<=0.05	MCL

# samples:	1	min:	< 0.00050 mg/L
# detects:	0	max:	< 0.00050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Silicon (total, as Si)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	2,800 ug/L	Boys Rd - Well 5	Silicon (total, as Si)		

# samples:	1	min:	2,800 ug/L
# detects:	1	max:	2,800 ug/L
# non-detects:	0	avg:	2,800 ug/L (based on 1 numerical results)
# of Exceedences:	0		

Silver (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	< 0.000050 mg/L	Boys Rd - Well 5	Silver (total)	<=0.1	Secondary Standard

# samples:	1	min:	< 0.000050 mg/L
# detects:	0	max:	< 0.000050 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sodium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	2.08 mg/L	Boys Rd - Well 5	Sodium (total)	<=160	MCL

# samples:	1	min:	2.08 mg/L
# detects:	1	max:	2.08 mg/L
# non-detects:	0	avg:	2.08 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Strontium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	26.4 ug/L	Boys Rd - Well 5	Strontium (total)		

# samples:	1	min:	26.4 ug/L
# detects:	1	max:	26.4 ug/L
# non-detects:	0	avg:	26.4 ug/L (based on 1 numerical results)

of Exceedences: 0

Sulfur (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 < 3,000 ug/L	Boys Rd - Well 5	Sulfur (total)	

# samples:	1	min:	< 3,000 ug/L
# detects:	0	max:	< 3,000 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Sulphate(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 1.7 mg/L	Boys Rd - Well 5	Sulphate	<=250 Secondary Standard

# samples:	1	min:	1.7 mg/L
# detects:	1	max:	1.7 mg/L
# non-detects:	0	avg:	1.7 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Sulphide (total, as S)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 < 20 ug/L	Boys Rd - Well 5	Sulphide (total, as S)	

# samples:	1	min:	< 20 ug/L
# detects:	0	max:	< 20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Temperature(Inline Instrument)	Sampling Point Name	Measurement Name	Criteria
--------------------------------	---------------------	------------------	----------

* 01/21/2019	15.3 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
02/25/2019	13.5 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
03/26/2019	9.5 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
04/23/2019	11.9 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
05/27/2019	12.5 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
06/24/2019	12.2 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
07/23/2019	14.5 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
* 08/27/2019	16.2 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
* 10/28/2019	17 degrees C	Boys Rd - Well 5	Temperature	<=15	AO
11/25/2019	15 degrees C	Boys Rd - Well 5	Temperature	<=15	AO

# samples:	10	min:	9.5 degrees C
# detects:	10	max:	17 degrees C
# non-detects:	0	avg:	13.8 degrees C (based on 10 numerical results)

of Exceedences: 3

Thallium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	< 0.000020 mg/L	Boys Rd - Well 5	Thallium (total)	<=0.002 MCL

# samples:	1	min:	< 0.000020 mg/L
# detects:	0	max:	< 0.000020 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Time(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria
01/21/2019	1,020	Boys Rd - Well 5	Time	
02/25/2019	1,115	Boys Rd - Well 5	Time	
03/26/2019	840	Boys Rd - Well 5	Time	
04/23/2019	920	Boys Rd - Well 5	Time	
05/27/2019	1,050	Boys Rd - Well 5	Time	
06/24/2019	910	Boys Rd - Well 5	Time	
07/23/2019	1,100	Boys Rd - Well 5	Time	
08/27/2019	915	Boys Rd - Well 5	Time	
10/28/2019	1,305	Boys Rd - Well 5	Time	
11/25/2019	915	Boys Rd - Well 5	Time	

# samples:	10	min:	840
# detects:	10	max:	1,305
# non-detects:	0	avg:	1,009 (based on 10 numerical results)
# of Exceedences:	0		

Tin (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	< 0.20 ug/L	Boys Rd - Well 5	Tin (total)	

# samples:	1	min:	< 0.20 ug/L
# detects:	0	max:	< 0.20 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Titanium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05	< 5.0 ug/L	Boys Rd - Well 5	Titanium (total)	

# samples:	1	min:	< 5.0 ug/L
# detects:	0	max:	< 5.0 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Turbidity(Inline Instrument)		Sampling Point Name	Measurement Name	Criteria	
01/21/2019	0.09 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
02/25/2019	0.06 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
03/26/2019	0.101 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
04/23/2019	0.05 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
05/27/2019	0.06 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
06/24/2019	0.05 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
07/23/2019	0.03 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
08/27/2019	0.04 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
* 10/28/2019	0.74 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined
11/25/2019	0.07 NTU	Boys Rd - Well 5	Turbidity	<=0.5	User-Defined

samples: 10 min: 0.03 NTU
 # detects: 10 max: 0.74 NTU
 # non-detects: 0 avg: 0.129 NTU (based on 10 numerical results)
 # of Exceedences: 1 95th percentile: 0.740 NTU

Uranium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	0.000051 mg/L	Boys Rd - Well 5	Uranium (total)	<=0.02	MAC

samples: 1 min: 0.000051 mg/L
 # detects: 1 max: 0.000051 mg/L
 # non-detects: 0 avg: 0.000051 mg/L (based on 1 numerical results)
 # of Exceedences: 0

Vanadium (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	1.7 ug/L	Boys Rd - Well 5	Vanadium (total)		

samples: 1 min: 1.7 ug/L
 # detects: 1 max: 1.7 ug/L
 # non-detects: 0 avg: 1.7 ug/L (based on 1 numerical results)
 # of Exceedences: 0

Zinc (total)(Lab Data Transfer)		Sampling Point Name	Measurement Name	Criteria	
10/29/2019 11:05	0.0051 mg/L	Boys Rd - Well 5	Zinc (total)	<=5	Secondary Standard

samples: 1 min: 0.0051 mg/L
 # detects: 1 max: 0.0051 mg/L
 # non-detects: 0 avg: 0.0051 mg/L (based on 1 numerical results)



of Exceedences: 0

Zirconium (total)(Lab Data Transfer)	Sampling Point Name	Measurement Name	Criteria
10/29/2019 11:05 < 0.10 ug/L	Boys Rd - Well 5	Zirconium (total)	

# samples:	1	min:	< 0.10 ug/L
# detects:	0	max:	< 0.10 ug/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded

